

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	3	2	3	2	3	2			
2	NLG	150	948		10		10		10			
3	MDK	87	828	1	6	1	6	1	6			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	4	18	4	18	4	18	0	0	
	Grand Total	908	6149	4	23	4	23	4	23	0	0	

TSSPDCL - LMRC / Corporate office

Date: 21.07.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Peddandandigama	33KV	Mahabubnagar	15.00	18.30	03.30	E/L	for Pin Insulater Replacement at Hamsanpally to 28 Pole No	Peddandandigama	-
2		Gadwal	Alwalpad	33KV	Gadwal	07.01	09.20	02.19	E/L	for 33KV Codoctor Snapped near Changunpally (vi)	Alwalpad	-
3		Amarchintha	Amarchintha	33KV	Gadwal	00.44	09.00	08.16	E/L	for 33KV SS Breker Problem	Amarchintha	-
1	MDK	Medak	B.Bpur	33KV	Medak	08.50	09.30	00.40		B/D due to Tree branches fallen on the line.	B.Bpur	-

TSSPDCL - LMRC / Corporate office

Date: 21.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nawabpet	Kondapur	11KV	Mahabubnagar	07.30	10.30	03.00		11KV Conductor cut at Hajilapur Thanda (Vi)	-
2		Atmakur	Mullamalla	11KV	Mahabubnagar	04.40	10.00	05.20		11KV Conductor cut at Singampet (Vi)	-
1	NLG	Aipoor	Isthalapuram	11KV	Suryapet	05.30	09.00	03.30	E/L	Tree Branch fallen	-
2		Nakrekal	Marrur	11KV	Suryapet	11.00	13.00	02.00	E/L	11Kv Insulator failed	-
3		Y.Singaram	Magdum nagar	11KV	Huzurnagar	09.15	12.00	02.45	EL	11Kv line cutted near Magdum nagar village	-
4		Thogarrai	Ganapavaram	11KV	Huzurnagar	07.10	10.00	02.50	OL	11kv Snapped near Ganapavaram village	-
5		Mukundhapuram	Dacharam	11KV	Huzurnagar	10.39	13.20	02.41	EL/OL	11Kv jumper cutted near Dacharam village	-
6		Mungala	Kokkireni-II	11KV	Huzurnagar	10.30	12.45	02.15	EL/OL	11Kv jumper cutted near Kokkireni-II village	-
7		Thipparthy	G.G.palem	11KV	Nalgonda	08.00	12.00	04.00	E/L	11 KV Insulator Failure at SS-25	-
8		Ramannapeta	Siri Puram	11KV	Nalgonda	06.00	10.00	04.00	E/L	11 KV Line Melting at SS-6	-
9		Marriguda	R.R.Pally	11KV	Devarakonda	02.00	06.00	04.00	EL	11KV Jumper cut	-
10		Angadipet	R.R.Gudem	11KV	Devarakonda	15.00	17.30	02.30	EL	Insulator failure	-
1	MDK	Yeldurthy	Elkapally	11KV	Toopran	06.00	07.30	01.30		B/D due to Jumper Cut	-
2		Yeldurthy	Kukunoorpally	11KV	Toopran	09.00	13.30	04.30		B/D due to Jumper Cut	-
3		Ramaipally SS	Shetpally	11KV	Toopran	09.40	10.40	01.00		B/D due to Jumper Cut	-
4		Ramayampet	Ramayampet	11KV	Toopran	03.30	07.20	03.50		B/D due to Jumper Cut	-
5		Chegunta	Beemraopally	11KV	Toopran	09.00	11.00	02.00		B/D due to Insulater Failed	-
6		Narsingi	Sherpally	11KV	Toopran	09.30	13.00	03.30		B/D due to Jumper Cut	-
1	RR N	Uddamarry	Yellaguda	11KV	Medchal	13.10	16.00	02.50		11KV HG Fuse Insulator and Copper Patti Failed at Ponnam Bavi,Adraspally	-
2		Jeedimetla SS I	Phase I	11KV	Kukatpally	00.35	02.09	01.34		11 kv Jumper cut near Hyd bus body at phase I & Jumper cut at SS Yard	-
1	RR E	AUTO NAGAR	HUDA SAI NAGAR	11KV	SRNR	17.58	19.10	01.12		11KV INSULATOR FAIL AT SAHARA ROAD	-
2		Cherlapally	Rampally	11KV	Keesara	17.00	19.00	02.00		11KV line touched to 9.1Mt Pole at Kareemguda	-
1	HYD S	Salarjung	Q.Q.Stadium	11KV	III	12.25	13.40	01.15	EL,OL-R&Bph	2No. Cable Jumpers cut at City College	-