

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		3		3		3			
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828	2	1	2	1	2	1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	5	2	5	2	5	0	0	
	Grand Total	908	6149	2	11	2	11	2	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Penpahad	Anajipuram	11KV	Suryapet	12.00	13.45	01.45	EL	Jumper cut	-
2		Mattampally	Allipuram	11KV	Huzurnagar	09.00	12.00	03.00	EL	11Kv line Snapped near Allipuram village	-
3		Karvirala	Keshavapuram	11KV	Huzurnagar	15.00	17.50	02.50	EL	11Kv line Snapped near Allipuram village	-
4		Angadipet	Chilkamarri	11KV	Devarakonda	06.00	08.30	02.30	EL	insulator failure	-
1	MDK	Chandaipet	Makkarajpet	11KV	Toopran	14.05	16.10	02.05		B/D due to Jumper cut	-
1	RR N	Kandlakoya	Godrej	11KV	Medchal	11.15	12.15	01.00	BD	Tree Branch fallen on the 11KV Line at Ushalliddin Form Gate Opposite	-
1	RR E	RR COURT	Chitralayout	11KV	SRNR	17.53	18.31	00.38	EL	11KV Jumper cut at Chitralayout	-
2		Moula-Ali	Moulali	11KV	Sainikpuri	08.30	10.22	01.52		Copper Patti cut at Roshan Plaza Apt Old Moulali (AE/OP	-
3		Pocharam	Pocharam	11KV	HBG	08.50	11.00	02.10		HT Line cut at Pocharam Village	-
1	HYD S	Kandikalgate	Rakshapuram	11KV	III	08.15	09.40	01.25	EL	Coconut tree branches fallen on lines at Rakshapuram	
2		Santosh Nagar	Jahingir Nagar	11KV	VIII	20.38	22.18	01.40	EL	HT/LT Line snapped at Moin Bagh	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Thukkapur	Lingapur	33KV	Siddipet	10.25	11.20	00.55		B/D due to Tree brances fallen on the line	Lingapur	-
2		Gajwel	Shivams	33KV	Toopran	19.55	20.50	00.55		B/D due to Jumper cut	Shivams	-