

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Velugupally	Velugupally	11KV	Suryapet	9:20	11:05	1:45	E/L	Jumpur cut	No
2		Dirsincherla	Somaram	11KV	Huzurnagar	12.20	13.55	01.35	EL	Due to 11Kv line Snapped near Somaram village	No
3		Nampally	Peddapuram	11KV	Devarakonda	13.00	16.00	03.00	EL	11kv jumper cutting	No
1	MDK	Kallakal	Delay feeder	11KV	Toopran	16:40	17:45	1:05		Tree branches fallen on the line	No
2		Laxmapur	Laxmapur	11KV	Toopran	12.40	16.30	03.50		B/D due to Jumper Cut	No
3		Suraram	Dharpally	11KV	Medak	06.00	10.00	04.00		Jumper & Disc failed at Dharpally village	No
1	RR N	IIIT	Jayabheri	11KV	Gachibowli	9:03	10:03	1:00		11KV AB switch failed	No
2		Vikas	Kendriya Vihar	11KV	Kukatpally	18.25	19.18	00.53		Stick fallen on the HG fuse set box	No
3		Gowravelly	IDA	11KV	Medchal	08.20	09.40	01.20		11KV Brass patti cut Gowravelly	No
4		Shameerpet	Nalsar	11KV	Medchal	13.00	14.10	01.10		11KV Conductor snapped	No
5		Medicity	Munidabad	11KV	Medchal	19:20	20:40	1:20		11KV Pin insulator failed	No
1	HYD S	Malakpet	Municipal Colony	11KV	Asmangadh	18.25	19.45	01.20	EL,OL-R,Y&Bph	AB Switch sparking at Municipal Colony	No
2		Yakuthpura	Saleema Khatoon	11KV	Asmangadh	18:25	19:44	1:19	EL	Kite Sticks on lines at Saleema Khatoon	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		5		5		5			
6	RR(E)	38	360									
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		3		3		3			
3	MDK	87	828		3		3		3			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	6	0	6	0	6	0	0	
	Grand Total	908	6149	0	13	0	13	0	13	0	0	