

TSSPDCL - LMRC / Corporate office

Date: 25.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Edloor	Kurumarthy	11KV	Suryapet	12.30	15.00	02.30	E/L	11KV Line cut & Insulator faild	-
2		Munagala	Tadvai	11KV	Huzurnagar	11.10	14.10	03.00	E/L	11Kv jumper cut near Tadvai village	-
3		Palakeedu	Nagireddigudam	11KV	Huzurnagar	03.00	06.00	03.00	E/L	11Kv jumper cut near Nagireddigudam village	-
4		Choutuppal	Chinnakondur	11KV	Nalgonda	08.30	11.40	03.10	E/L	HT / LT Line Melting	-
5		Thimmannagude	T.K.Gudem	11KV	Nalgonda	07.00	10.40	03.40	E/L	11KV Line Jumper Cut SS-5	-
6		Bhongir Town	Town III	11KV	Bhongir	01.30	05.30	04.00	E/L	11KV Line conductor snapped at takarama Nagar	-
1	MDK	Kallakal	Imampur	11KV	Toopran	16.10	18.40	02.30		B/D due to PT Prablam	-
2		Laxmapur	J Lingapur	11KV	Toopran	06.30	10.30	04.00		B/D due to Jumper Cut at J Lingapur	-
3		Moosapet	Nagulapally	11KV	Medak	11.45	17.00	05.15		B/D due to Disk failed	-
1	RR S	Jalpally	Mamidipally	11KV	CPT	09.35	12.00	02.25	EL/OL	DTR Brass patti cut at SC Colony, Mamidipally	-
2		Leninnagar	Janapriya nagar	11KV	CPT	11.10	12.18	01.08	OL	Tree fallen on 11KV line at New Balaji Nagar	-
3		Mallapur	Shaheen Nagar	11KV	CPT	17.34	19.10	01.36	EL/OL	Tree fallen on 11KV line at Sai Baba Temple Shaheen Nagar	-
4		Saheb Nagar	Sachavalaya Nagar	11KV	CPT	17.45	18.50	01.05	EL/OL	Line AB Switch Problem at Athidhi Biryani Centre (Post of insulator failed)	-
1	RR E	Fruitmarket	Shivalayam	11KV	Saroor Nagar	12.20	12.50	00.30	EL/OL	11KV Line snaped at DSNR Bus depot beside	-
2		Narapally	P.Singaram	11KV	Keesar	08.15	09.10	00.55		100KVA T/F copper patti cut at Taineguda village	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		4		4		4			
5	RR(N)	82	407									
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014									
	Total	504	2929	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		6		6		6			
3	MDK	87	828		3		3		3			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	9	0	9	0	9	0	0	
	Grand Total	908	6149	0	15	0	15	0	15	0	0	