

TSSPDCL - LMRC / Corporate office

Date: 26.07.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Minpur	Minpur	33KV	Jogipet	13.30	17.10	03.40		B/D Due to Conductor snapped		-
2		Tukkapur	Dommat	33KV	Siddipet	12.15	13.30	01.15		B/D Due to tree branch fallen on the line		-
1	HYD N	132KV J' Hills	Road No.22	33KV	Kalyan Ngr	04.22	04.32	00.10	EL,OL-Bph	Cable End Kit failed near 132KV J' Hills SS		Loads transferred onto 132KV J' Hills SS vai 33KV Yousufguda SS

TSSPDCL - LMRC / Corporate office

Date: 26.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kotha Molgara	Elikicherla	11KV	Jadcherla	08.35	10.45	02.10		Tree Fallen On the 11KV Line Near Elikicherla (V)	-
2		Udithyal	Macharam	11KV	Jadcherla	14.40	17.20	02.40		11KV Jumper Cut Near Suraram( V)	-
1	NLG	Penpahad	Annaram	11KV	Suryapet	09.00	11.30	02.30	E/L	Jumper cut	-
2		Palakeedu	Bothalapalem	11KV	Huzurnagar	15.00	18.00	03.00	EL	11 kv line snapped at Bothalapalem village	-
3		Beelyanaik thanda	Pathathanda	11KV	Huzurnagar	09.30	12.00	02.30	EL	LT Line snapped at Pathathanda village	-
4		Marriguda	Thamadapally	11KV	Devarakonda	04.00	07.00	03.00	EL	11kv jumper cut	-
5		Yennaram	Suraram	11KV	Nallagonda	13.00	14.45	01.45	E/L	HT/LT lines melting at SS-32	-
1	MDK	Regode	Jagriai	11KV	Medak	07.00	11.00	04.00		B/D Due to Insulator failure	-
2		Cheryal	Kalivemula	11KV	Sangareddy	03.05	06.25	03.20		B/D Due to Jumper Cut	-
3		Patancheru	Allween	11KV	Sangareddy	12.35	13.40	01.05		B/D Due to Insulator failure	-
1	RR S	Ibrahimbagh	Peddangalaram(I BGH)	11KV	RJNR	07.50	09.00	01.10	B/D	11KV insulator failed at Kapil nagar	-
2		NPA	Shivarampally	11KV	RJNR	12.56	14.10	01.14	B/D	LAB Switch sparking at Shivarampally	-
1	RR N	Laxmapur	Laxmapur	11KV	Medchal	07.34	09.25	01.51		11KV Disc Failed at Kushi Foultry Form near Bala Reddy Bhavi	-
1	HYD S	Miralam	Zoo Park	11KV	Charminar	03.05	04.25	01.20	EL,OL-Bph	Faulty DTR at Dhanamma Jopdi	-
1	HYD N	Kalyan Nagar	A.G.Colony	11KV	Banjarahills	10.27	11.46	01.19	EL,OL-Rph	Jumper cut at City Stores, Kalyan Nagar	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		2		2		2			
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360									
7	Hyd	186	1014	1	2	1	2	1	2			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		2		2		2			
2	NLG	150	948		5		5		5			
3	MDK	87	828	2	3	2	3	2	3			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>3</b>	<b>15</b>	<b>3</b>	<b>15</b>	<b>3</b>	<b>15</b>	<b>0</b>	<b>0</b>	