

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360									
7	Hyd	186	1014									
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	3	3	3	3	3	3			
2	NLG	150	948									
3	MDK	87	828	4		4		4				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>7</b>	<b>3</b>	<b>7</b>	<b>3</b>	<b>7</b>	<b>3</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>7</b>	<b>3</b>	<b>7</b>	<b>3</b>	<b>7</b>	<b>3</b>	<b>0</b>	<b>0</b>	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthy	Kodair	33KV	Wanaparthy	01.30	02.30	01.00	E/L&O/L	No Visible fault	Kodair	-
2		Gadwal	Dharoor	33KV	Gadwal	01.15	08.35	07.20	E/L	Flash over Pin insulator replaced at Gudemdoddicenal	Dharoor	-
3		Balanagar	G.R.Cable	33KV	Jadcherla	11.00	12.10	01.10	O/L	Tree Branches Touched to the 33KV Line	G.R.Cable	-
1	MDK	Thukkapur	Lingapur	33KV	Siddpet	18.40	20.50	02.10		B/D due to Conductor snapped at Beemlagattu Village	Lingapur	-
2		Kandhi	HFC II	33KV	Sangareddy	20.15	00.15	04.00	B/D due to	B/D due to Pin Insulator failed	HFC II	-
3		Pashamailaram	Manjeera	33KV	Sangareddy	05.30	10.30	05.00		B/D due to Bird fallen on line	Manjeera	-
4		Gummadidal	GPHS-I	33KV	Sangareddy	18.30	19.30	01.00		B/D due to Jumper cut & supply given from 220KV Shapur nagar.	GPHS-I	-

## TSSPDCL - LMRC / Corporate office

Date: 30.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Devarkadra	Gudibanda	11KV	Mahabubnagar	07.00	11.00	04.00		11KV Conductor cut at Gopanpally (Vi)	-
2		Devarkadra	Koilsagar	11KV	Mahabubnagar	10.00	11.00	01.00		11KV Jumper cut near Gurakonda (vi)	-
3		Eklaspur	Jinnaram	11KV	Mahabubnagar	06.30	09.00	02.30		11KV Jumper cut near Jinnaram (vi)	-