

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		3		3		3			
5	RR(N)	82	407									
6	RR(E)	38	360		3		3		3			
7	Hyd	186	1014		3		3		3			
	Total	504	2929	0	9	0	9	0	9	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828	1		1		1				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	4	1	4	1	4	0	0	
	Grand Total	908	6149	1	13	1	13	1	13	0	0	

TSSPDCL - LMRC / Corporate office

Date: 21.06.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Zaheerabad	Old Allahna	33KV	Zaheerabad	05.20	06.30	01.10		B/D due to cable kit failure & Alternate supply arranged to Jharasangam feeder		-

TSSPDCL - LMRC / Corporate office

Date: 21.06.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Bopparam	Bopparam	11KV	Suryapet	03.00	07.00	04.00	E/L	Disk Failed	-
2		Ch.Mamidi	Kompally	11KV	Nalgonda	04.00	07.30	03.30	E/L	11KV Discs failed	-
3		Choutuppal	Thangadapally	11KV	Nalgonda	11.20	14.30	03.10	E/L	11KV Jumper cut	-
4		Marriguda	Thamadapally	11KV	Devarakonda	08.00	11.00	03.00	E/L	11KV Jumper cut	-
1	RR S	Mamidipally	Pahadishareef	11KV	Champapet	10.40	13.00	02.20	EL	DTR Failed at Bada Masjid Shaheen nagar	-
2		Mamidipally	Quba Colony	11KV	Champapet	16.11	17.11	01.00	EL	Breaker relay problem	-
3		Turkayamjal	kammaguda	11KV	Champapet	14.30	17.10	02.40	EL	11KV Line touched to pole at Turkayamzal	-
1	RR E	Mallapur	IDA	11KV	HBG	01.10	02.10	01.00		11KV Pin Insulator failed near PJ Chemiclas at IDA Mallapur	-
2		Mallapur-2	AP Colony	11KV	HBG	18.40	20.10	01.30		11KV Post Of Insulator failed near Myflower Park	-
3		ABDULLAPURMET	BATASINGARAM	11KV	SRNR	02.00	04.30	02.30		TREE BRANCHES FALLOW ON 11KV LINE AT ABDULLAPERMET	-
1	HYD S	Kanchan Bagh	Jamal Colony	11KV	Asmangadh	01.11	02.40	01.29	EL,OL-Rph	Brass Patti & HG fuse burntout at Bannaka	-
2	HYD C	Lake View	Vijaya Hospital	11KV	Saifabad	04.11	05.35	01.24	EL	HG fuse blown at Add Show Room	-
3	HYD N	Sanjeevaiah Park	Police Lines	11KV	Sec-Bad	07.30	08.56	01.26	EL,OL-Rph	Cable damaged at Usha Godown	Partial loads arranged B/F on 11KV Rani Bagh feeder