

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|--|
| 1 | MBNR | Kondapur | Kondapur | 11KV | Mahabubnagar | 09.50 | 12.00 | 02.10 | | 11KV Phase to Phase at Thimareddy Kunta (V) | No |
| 1 | NLG | Sh.Gowraram | Gurajala | 11KV | Suryapet | 6:30 | 8:00 | 1:30 | E/L | 11Kv Insulator failed | No |
| 2 | | Thipparthy | Sarvaram | 11KV | Nallagonda | 13.00 | 15.00 | 02.00 | E/L | 11KV line cut at nearby Suraram(V) | No |
| 3 | | Mamillagudem | Anantharam | 11KV | Nallagonda | 07.30 | 09.30 | 02.00 | E/L | 11KV Jumper cut at SS-2 | No |
| 4 | | Chandampet | Chitriyala | 11KV | Devarakonda | 09.00 | 12.00 | 03.00 | E/L | 11Kv Jumper cut | No |
| 5 | | Palakeedu | Nagireddy gudem | 11KV | Huzurnagar | 02.10 | 05.00 | 02.50 | E/L | 11Kv Jumper cut near Nagireddy gudem | No |
| 6 | | Munagala | Munagala | 11KV | Huzurnagar | 02.00 | 05.00 | 03.00 | E/L | 11KV line Snapped near Munagala | No |
| 7 | | Garidepally | Appannapet | 11KV | Huzurnagar | 05.00 | 08.00 | 03.00 | E/L | 11KV line cut near Appannapet | No |
| 8 | | Ponugodu | Velidanda 02 | 11KV | Huzurnagar | 02.15 | 06.00 | 03.45 | E/L | 11Kv insulator Failure near Velidanda 02 | No |
| 9 | | Siripuram | Siripuram | 11KV | Huzurnagar | 2:00 | 6:00 | 4:00 | E/L | 11Kv insulator Failure near Siripuram | No |
| 1 | RR N | Balajinagar | Lodha | 11KV | Gachibowli | 10:32 | 16:34 | 6:02 | | UG Cable Damaged Near Shishu Vihar Mandir School At Church. | No |
| 2 | | Papireddy Colony | Papireddy Colony | 11KV | Gachibowli | 15.25 | 17.20 | 01.55 | | 11KV Pin Insulator Failed At Placida Company. | No |
| 3 | | Hafeezpet | Aditya Nagar | 11KV | Gachibowli | 16.00 | 18.05 | 02.05 | | 11KV Conductor Snapped On Road No 13 At Aditya Nagar. | No |
| 4 | | Medchal | Rural Medchal | 11KV | Medchal | 01.30 | 05.50 | 04.20 | | Tree fallen on 11KV Line and PinInsulators Failed at near by Ganga Kavari | No |
| 5 | | Subash Nagar | Jeedimetla | 11KV | Medchal | 4:50 | 5:50 | 1:00 | | Tree fallen on 11KV Line at Dandamudi Enclave | No |
| 1 | RR E | Narapally | AP Meat | 11KV | Habsiguda | 10:30 | 11:10 | 0:40 | | 11KV Pin insulator failed at Narapally Gram Panchayat | No |
| 2 | | Abdullapurmet | MET Town | 11KV | Saroor Nagar | 23.30 | 02.30 | 03.00 | | 11KV Jumper cut | No |
| 1 | HYD N | Road No.22 | Jubilee Hills PS | 11KV | Jubilee Hills | 10.53 | 12.10 | 01.17 | EL | Cable End Kit fault at TV-5, Road No.9 | No |
| 1 | HYD S | Khilwath | Charminar | 11KV | Charminar | 09.03 | 10.15 | 01.12 | All Indication | Cable fault at Shah Function Hall | Partial fdr charged & Remaining fdr B/F on 11KV Khilwath fdr |
| 2 | | Attapur | Shareef Nagar | 11KV | Charminar | 19:53 | 21:25 | 1:32 | EL,OL-Rph | No Visible fault due to Rain | No |
| 3 | | Attapur | Kishan Bagh OH | 11KV | Charminar | 19:55 | 21:20 | 1:25 | EL,OL-Rph | No Visible fault due to Rain | No |
| 4 | | Attapur | Puranapool | 11KV | Charminar | 19:59 | 21:05 | 1:06 | EL,OL-Rph | No Visible fault due to Rain | No |
| 5 | | Aliabad | Shamsheer Gunj | 11KV | Charminar | 20:09 | 22:14 | 2:05 | EL | 2No DTR's isolated at Goshala | No |
| 6 | | Karwan | Karwan | 11KV | Begumbazar | 21:05 | 22:45 | 1:40 | EL | Cable end Kit failed at SS | Arranged B/F on 11KV Tallagadda OH fdr |
| 7 | | Seetharam Bagh | Hari Darga | 11KV | Begumbazar | 22.05 | 00.10 | 02.05 | EL | Kite Stick fallen at Nalla Pochamma Temple | No |
| 1 | HYD C | Langer House | Prashanth Nagar | 11KV | Mehdipatnam | 21.45 | 23.25 | 01.40 | EL | No Visible fault due to Rain | No |
| 2 | | Asif Nagar | Padmanabha Nagar | 11KV | Mehdipatnam | 22.24 | 00.09 | 01.45 | EL | No Visible fault due to Rain | No |
| 3 | | Nampally | Nampally Hospital | 11KV | Mehdipatnam | 21.06 | 00.52 | 03.46 | EL,OL-Rph | Conductor snapped at Nampally Hospital | No |

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 48 | 158 | | | | | | | | | |
| 2 | NLG | 18 | 406 | | | | | | | | | |
| 3 | MDK | 92 | 383 | | | | | | | | | |
| 4 | RR(S) | 40 | 201 | | | | | | | | | |
| 5 | RR(N) | 82 | 407 | | 5 | | 5 | | 5 | | | |
| 6 | RR(E) | 38 | 360 | | 2 | | 2 | | 2 | | | |
| 7 | Hyd | 186 | 1014 | | 11 | | 11 | | 11 | | | |
| | Total | 504 | 2929 | 0 | 18 | 0 | 18 | 0 | 18 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 110 | 969 | 3 | 1 | 3 | 1 | 3 | 1 | | | |
| 2 | NLG | 150 | 948 | | 9 | | 9 | | 9 | | | |
| 3 | MDK | 87 | 828 | 2 | | 2 | | 2 | | | | |
| 4 | RR(S) | 31 | 338 | | | | | | | | | |
| 5 | RR(N) | 8 | 48 | | | | | | | | | |
| 6 | RR(E) | 18 | 89 | | | | | | | | | |
| | Total | 404 | 3220 | 5 | 10 | 5 | 10 | 5 | 10 | 0 | 0 | |
| | Grand Total | 908 | 6149 | 5 | 28 | 5 | 28 | 5 | 28 | 0 | 0 | |