

TSSPDCL - LMRC / Corporate office

Date: 27.06.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthy	Wanaparthy	33KV	Wanaparthy	13.15	14.25	01.10	E/L	11KV Jumper Cut at 132KV Wanaparthy SS		No
1	NLG	Marriguda	Shivannagudem	33KV	Nalgonda	06.00	07.20	01.20		Trea fallen on line		-
2		Ramannapet	Veliminedu	33KV	Nalgonda	12.00	13.05	01.05		33 KV insulator failed		-
1	MDK	Gajwel	Shivams	33KV	Toopran	15.10	15.40	00.30		B/D due to Disk failed		-
2		Medak	NSF	33KV	Medak	10.53	12.40	01.47		B/D Due to Jumpercut		-
1	RR S	132kv RC Puram	33kv Giridharispat	33KV	RJNR	11.36	16.15	04.39	B/D	33KV 2span lines snapped at kollur village		-
2		220kv Shivarampally	33kv Steel Mill	33KV	RJNR	19.20	22.47	03.27	B/D	33KV Disc Failed and Line Snapped at sheetal Drop company		-

TSSPDCL - LMRC / Corporate office

Date: 27.06.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Devarkadra	Gudibanda	11KV	Mahabubnagar	06.00	10.00	04.00		11KV Phase to Phase Near Gudibanda (Vi)	-
2		Hamsanipally	Hamsanipally	11KV	Mahabubnagar	12.30	16.50	04.20		11KV Phase to Phase Near Hamsanipally(Vi)	-
3		Rajapur	Chinnavelly	11KV	Jadcherla	11.00	17.00	06.00		HT/LT near Kucherkal (V)	-
1	NLG	Nakrekal	Chandampally	11KV	Suryapet	06.00	09.00	03.00	EL	Jumper Cut	-
2		Alingapuram	Raghavapuram	11KV	Huzurnagar	12.30	16.00	03.30	EL	Due to 11Kv Line Cut occur near Raghavapuram village	-
3		Ramannapet	Siripuram	11KV	Nalgonda	10.10	13.00	02.50	E/L	11 KV Line Jumper Cut	-
4		Chinthapally	Vijamuru	11KV	Devarakonda	08.00	11.00	03.00	E/L	Jumper Cut	-
1	MDK	Pillykottal	Pillikotta	11KV	Medak	02.00	06.00	04.00		B/D Due to Jumpercut	-
2		BB Pur	BB Pur	11KV	Medak	05.00	09.20	04.20		B/D Due to Tree branches fallen on the line	-
3		BB Pur	Muthaipally	11KV	Medak	05.00	07.40	02.40		B/D Due to Insulator failed.	-
4		Kowdipally	Yelmakanna	11KV	Medak	02.00	08.50	06.50		B/D Due to Insulator failed.	-
5		Hathnoora	Nawabpet	11KV	Medak	02.00	06.00	04.00		B/D Due to 11KV Condcutor snapped	-
1	RR S	Ibrahimbagh	Military-II	11KV	RJNR	18.44	20.36	01.52	B/D	11KV Insulator Failed at PNT Colony	-
2		Ibrahimbagh	Osmansagar	11KV	RJNR	18.42	20.30	01.48	B/D	No Visible Fault Due To Rain	-
3		Puppalaguda	Alkapuri	11KV	RJNR	01.30	03.00	01.30	B/D	No Visible Fault Due To Rain	-
4		Puppalaguda	Alkapuri	11KV	RJNR	18.45	20.20	01.35	B/D	silk cloth Fallen on 11KV Line at Alkapur supermarket	-
5		MD Pally	Brundavan colony	11KV	RJNR	11.05	12.10	01.05	B/D	11KV Line Twisted at Babulreddy nagar bus stop	-
6		Kokapet	Kokapet	11KV	RJNR	12.50	13.40	00.50	B/D	No Visible Fault	-
1	RR N	Ayyappa Society	Allapur	11KV	Gachibowli	18.40	20.10	01.30	BD	Line petrolling, No Visible fault found(Due to heavy wind and rain)	-
2		Jeedimetla-I	JETL	11KV	Kukatpally	00.10	02.00	01.50	BD	11kv line AB Cable Endkit failure at VIP Foods,phase-I	-
3		Mayurinagar	Cable	11KV	Kukatpally	10.35	11.55	01.20	BD	11kv line Pole touch the HT line at Hydernagar Cheroow	-
4		Bahadurpally	IDA-II	11KV	Kukatpally	19.06	19.57	00.51	BD	Tree Branchesh Fallen the 11kv line at Reddy polmars Company Suraram	-
5		Jeedimetla-I	NITCO	11KV	Kukatpally	20.25	00.04	03.39	BD	11kv AB Cable Endkit failure	-
6		GP Pally	GP Pally	11KV	Medchal	10.20	13.00	02.40	BD	11KV Pin Insulator failedat GP Pally	-
7		Medchal	Housing Board	11KV	Medchal	12.36	13.23	00.47	BD	Line petrolling, No Visible fault found	-
8		Aliabad	Ravileela	11KV	Medchal	13.30	15.00	01.30	BD	Tree Fallen on the 11KV Line at St Joseph School Backside, Aliabad	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	Rampally Dayara	Vanneguda	11KV	HBG	14.20	15.25	01.05		Lizard fallen on 11Kv line near Ankuram Hostel	-
2		ABDULLAPERMET	BATASINGARAM	11KV	SAROOR NAGAR	19.30	20.50	01.20	OL	TREE BRCHANS FALLOW ON 11KV LINE BATASINGARAM	-
3		ABDULLAPERMET	SANGHI	11KV	SAROOR NAGAR	19.30	21.15	01.45	EL/OL	TREE BRCHANS FALLOW ON 11KV LINE GEDI CHERU	-
4		RFC	ANAJ PER	11KV	SAROOR NAGAR	19.40	20.40	01.00	EL/OL	TREE BRCHANS FALLOW ON 11KV LINE ANAJPER	-
1	HYD N	Road No.13	Namdari	11KV	Banjarahills	18.56	20.35	01.39	EL,OL	Pin Insulator flash over at Road No.10	-
2		N.I.M.S	Andhra Jyothi	11KV	Banjarahills	19.20	20.46	01.26	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV Nagarjuna Hills feeder
1	HYD S	Salarjung	Yakuthpura	11KV	Asmangadh	18.57	21.25	02.28	EL,OL	Cable Jumpers cut at Yakuthpura & Darulshifa Hospital	-
1	HYD C	Nizam College	Big Bazar	11KV	Saifabad	03.40	05.25	01.45	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Rang Mahal feeder
2		Asif Nagar	Water Works	11KV	Mehdipatanam	15.05	16.35	01.30	EL,OL-Bph	CT PT blasted at Water Works	-
3		Mothi Mahal	Saleh Nagar	11KV	Mehdipatanam	18.48	20.30	01.42	All Indication	Conductor snapped at Khaji Gally	-
4		S.D.Hospital	Police Mess	11KV	Mehdipatanam	18.49	19.58	01.09	OL-Rph	No Visible Fault	-
5		Langer House	Military Hospital	11KV	Mehdipatanam	19.00	20.45	01.45	EL,OL-Rph	Tree branches fallen on lines at Councillor DTR	-
6		Bathkammakunta	D.D.Colony	11KV	Azamabad	19.20	20.21	01.01	EL,OL-Rph	No Visible Fault	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201	2	6	2	6	2	6			
5	RR(N)	82	407		8		8		8			
6	RR(E)	38	360		4		4		4			
7	Hyd	186	1014		9		9		9			
	Total	504	2929	2	27	2	27	2	27	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	3	1	3	1	3			
2	NLG	150	948	2	4	2	4	2	4			
3	MDK	87	828	2	5	2	5	2	5			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	5	12	5	12	5	12	0	0	
	Grand Total	908	6149	7	39	7	39	7	39	0	0	