

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407	1	1	1	1	1	1			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014									
	Total	504	2929	1	2	1	2	1	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948		6		6		6			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	7	0	7	0	7	0	0	
	Grand Total	908	6149	1	9	1	9	1	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 30.06.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	Shapurnagar	DP Pally	33KV	Kukatpally	03.06	04.55	01.49	BD	Tripped on EL&OL Y indication BD declared tree branches fallen	DP Pally	-

TSSPDCL - LMRC / Corporate office

Date: 30.06.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Machanpally	Pothanpally	11KV	Mahabubnagar	09.46	14.00	04.14		11KV Conductor cut at Venkataipally (Vi)	-
1	NLG	Chedella	Mukundapuram	11KV	Suryapet	07.00	09.20	02.20	E/L	Jumper cut	-
2		Keethavarigudem	Rainigudem	11KV	Huzurnagar	05.30	09.30	04.00	EL	Jumperr cut near Rainigudam Village	-
3		Arjalabavi	Marrigudem	11KV	Nalgonda	07.35	10.10	02.35	E/L	11 KV Jumper Cut	-
4		Thimmanagudem	Thelakantigudem	11KV	Nalgonda	04.00	08.00	04.00	E/L	11 KV Insulator Failed	-
5		Velgupally	lthavarigudem	11KV	Nalgonda	08.00	11.20	03.20	E/L	11 KV Insulator Failed	-
6		Azeempet	Azeempet	11KV	Bhongir	10.40	14.00	03.20	EL	11KV Jumper Snapped	-
1	RR N	Bahadurpally	Laxminagar	11KV	Kukatpally	09.17	10.45	01.28	BD	Tree Branchesh fallon the 11kv line at Laxminagar	-
1	RR E	Keesara	Ankireddypally	11KV	Habsiguda	12.00	13.20	01.20		11kv line cut at Peddamma temple cherruvu	-