

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201	1		1		1				
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360									
7	Hyd	186	1014		1		1		1			
	Total	504	2929	1	2	1	2	1	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		2		2		2			
3	MDK	87	828		8		8		8			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	10	0	10	0	10	0	0	
	Grand Total	908	6149	1	12	1	12	1	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 01.11.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR S	Pargi	SMS	33KV	VKB	07.10	11.40	04.30	B/D	Bird fallen on 33kv Line Near by SMS Company		-

TSSPDCL - LMRC / Corporate office

Date: 01.11.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Motakondur	Vartoor	11KV	Bhongir	03.10	06.50	03.40	E/L	11KV Line snapped at (V)	-
2		Gudimalkapuram	Chintalapalem	11KV	Huzurnagar	07.30	10.00	02.30	E/L	1phase DTR failure near Chintalapalem (v)	-
1	MDK	Siddipet	Raghavapur	11KV	Bachaipally	06.30	10.30	04.00		B/D due to Insulater failed	-
2		Siddipet	Chellapur	11KV	Rajakkapeta	14.18	15.10	00.52		B/D due to 11 Jumper cut	-
3		Medak	NSF	11KV	Chityala	09.00	13.20	04.20		B/D due to HT/LT	-
4		Medak	Pathur	11KV	Shamnapur	12.50	14.00	01.10		B/D due to Insulator faile	-
5		Medak	Pathur	11KV	Pathur-II	01.00	10.00	09.00		B/D due to Disc faile	-
6		Medak	Gadipeddapur	11KV	Muslapur	11.30	14.35	03.05		B/D due to HT/LT at Moosapur SS-I	-
7		Sangareddy	Cheryal	11KV	Kalivemula	04.20	06.45	02.25	B/D Due to 11kv conductor snapped	B/D Due to 11kv conductor snapped	-
8		Sangareddy	Isnapur	11KV	Weddia	15.40	16.10	00.30	B/D Due to LT Line cut	B/D Due to LT Line cut	-
1	RR N	Bahadurpally	Indiramma Colony	11KV	Jeedimetla	20.10	21.15	01.05	EL	Garden Lizard Fallon the 11kv line at Bahdurpally Forest	-
1	HYD S	Kanchanbagh	Riyasath Nagar	11KV	Charminar	08.55	10.40	01.45	All Indication	Cable fault	-