

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		4		4		4			
7	Hyd	186	1014	1	2	1	2	1	2			
	Total	504	2929	1	7	1	7	1	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2		2		2				
2	NLG	150	948		7		7		7			
3	MDK	87	828	1	5	1	5	1	5			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	12	3	12	3	12	0	0	
	Grand Total	908	6149	4	19	4	19	4	19	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.11.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Kothur	33KV	Mahabubnagar	02.20	03.05	00.45	E/L	Isolator open towards Bomraspet (Flash over insulator conductor snapped)		-
2		Wanaparthy	Pabbair	33KV	Wanaparthy	11.42	14.50	03.08	E/L	33KV Conductor Snapped near Srinivaspur		-
1	MDK	Gummadidala	Dundigal	33KV	Sangareddy	10.35	12.55	02.20		B/D Due to tree branch fallen on the line		-
1	HYD N	132KV J' Hills	Ravindra Society	33KV	Kalyan Ngr	00.53	01.02	00.09	EL,OL-Rph	Cable fault	132KV J' Hills	Loads transferred onto 132KV Madhapur SS

TSSPDCL - LMRC / Corporate office

Date: 03.11.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mukundapuram	Mukundapuram	11KV	Huzurnagar	14.25	17.00	02.35	EL	Due to 11Kv Jumper cutted near Mukundapuram village	-
2		Dirsincherla	Dirsincherla	11KV	Huzurnagar	06.30	09.00	02.30	EL	Due to 11 Kv line Cutted near Dirsincherla village	-
3		Biravunibanda	Biravunibanda	11KV	Nalgonda	12.20	14.40	02.20	EL	11KV Line Jumper Cut	-
4		Pamangundla	Pittampally	11KV	Nalgonda	09.00	10.40	01.40	EL	Insulator Failed	-
5		Rajapet	Renikunta	11KV	Bhongir	14.30	17.00	02.30	EL	11KV KV Line snapped Renikunta	-
6		Rajapet	Rajapeta agl	11KV	Bhongir	14.00	15.30	01.30	EL	11KV Diskfailed & Line snapped	-
7		Yennaram	Surram	11KV	Choutuppal	15.40	18.15	02.35	EL	11KV Line snapped Baschuppal	-
1	MDK	J.Shivanoor	J. Shivnoor	11KV	Medak	11.16	13.55	02.39		B/D Due to Insulator Failure	-
2		J.Shivanoor	Kaslapur	11KV	Medak	11.40	16.27	04.47		B/D Due to Jumper Cut	-
3		Amsanpally	Amsanpally	11KV	Medak	06.45	07.45	01.00		B/D Due to Insulator Failure	-
4		Podchanpally	Yellapur	11KV	Medak	07.50	08.30	00.40		B/D Due to Insulator Failure	-
5		Thogita	Kuchanpally	11KV	Medak	01.50	11.30	09.40		B/D Due to Jumper Cut	-
1	RR N	Bachupally	Nizampet	11KV	Kukatpally	19.10	19.40	00.30	EL	11kv Disk Failure At GOVT High School Bachupally	-
1	RR E	Chakripuram	Shilpa Nagar	11KV	Habsiguda	16.20	17.00	00.40		Lizard fallen on 160KVA T/F at Shilpa Nagar	-
2		Rampally Dayaram	Vanneguda	11KV	Keesara	19.52	21.30	01.38		11KV Pin Insulater Failed at Barshaguda	-
3		HAYATH NAGAR	KALVANCHA	11KV	SAROORNAGAR	09.35	11.35	02.00	EL	Line Petroling Done No Visible Fault	-
4		PEDDAMBERPET	PUSUMAMALA	11KV	SAROORNAGAR	11.35	12.40	01.05	EL	DTR CUPPER PATTI CUT AT PUSUMAMALA	-
1	HYD S	Aliabad	Musrath Function Hall	11KV	Charminar	09.56	12.00	02.04	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Jangammett AB Cable fdr
2		Aliabad	Boys Town	11KV	Charminar	09.56	12.00	02.04	EL	Cable fault	Arranged B/F on 11KV Jangammett AB Cable fdr