

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014									
	Total	504	2929	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2	2	2	2	2	2			
2	NLG	150	948		1		1		1			
3	MDK	87	828	2		2		2				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	4	3	4	3	4	3	0	0	
	Grand Total	908	6149	4	8	4	8	4	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 05.11.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Palkonda	Janampet	33KV	Mahabubnagar	08.46	10.48	02.02	E/L	Alternate Supply Taken to 33KV Bhoothpur Feeder Supply Stud Ok	Janampet	Alternate Supply Taken to 33KV Bhoothpur Feeder Supply Stud Ok at 10:48Hrs
2		Alampur	Shanthinagar-I	33KV	Gadwal	18.50	19.57	01.07	O/L	AB Swtich open at Ramapuram Village	Shanthinagar-I	-
1	MDK	Siddipet	Mittapally	33KV	Siddipet	05.15	07.15	02.00		B/D due to 33KV Pole damaged	Mittapally	-
2		Zaheerabad	Mannapur	33KV	Zaheerabad	15.05	22.00	06.55		B/D due to Coductor snaped at Kashimpur	Mannapur	-

TSSPDCL - LMRC / Corporate office

Date: 05.11.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgara	Karvena	11KV	Jadcherla	09.00	12.00	03.00		Tree Branch Fallen on the 11 KV Line Near Kothamolgara(Vi).	-
2		Rajapur	Mallepally	11KV	Jadcherla	14.00	16.00	02.00		11KV wire Cut Near Ebrahimpally(Vi).	-
1	NLG	Dirsenpally	Alugunoor	11KV	Suryapet	03.35	06.00	02.25	E/L	11Kv Jumper cut	-
1	RR N	Subash Nagar	Jairam Nagar	11KV	Medchal	14.25	14.55	00.30	BD	Tree Fallen on the11KV Line at Gayathri Nagar	-
2		GP Pally	Malla Reddy	11KV	Medchal	04.25	07.25	03.00	BD	11KV Pin Insulator failed at Mallareddy Collage	-
3		Medicity	IDA-I	11KV	Medchal	08.05	08.45	00.40	BD	11KV Pin Insulator failed at Pudur Village	-
1	RR E	TARAMATHIPET	GOWRELLY	11KV	IBRAHIMPATNAM	15.40	17.10	01.30	EL/OL	TREE BRACHANS FALL ON 11KV LINE AT TARAMATHIPET	-
2		Aushapur	Aushapur	11KV	Habsiguda	15.30	16.30	01.00		Bird fallen 11kv Line Near Arora College	-