

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201	1		1		1				
5	RR(N)	82	407									
6	RR(E)	38	360									
7	Hyd	186	1014	1		1		1				
	Total	504	2929	2	0	2	0	2	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828	1		1		1				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	4	1	4	1	4	0	0	
	Grand Total	908	6149	3	4	3	4	3	4	0	0	

TSSPDCL - LMRC / Corporate office

Date: 12.11.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Thunkibollaram	Markook	33KV	Siddipet	11.15	14.40	03.25		B/D due to Underline cable cut	Markook	-
1	RR S	132kv RC Puram	33kv Giridarispatt	33KV	RJNR	13.43	15.50	02.07	B/D	No visible fault found	33kv Giridarispatt	Back feeding taken by 33kv Shankarpally
1	HYD N	132KV Erragadda	Kundanbagh (Idle)	33KV	Allwyn	10.30	17.15	06.45	EL	Cable straight through Joint failed at S.R.Nagar X Road	Kundanbagh (Idle)	-

TSSPDCL - LMRC / Corporate office

Date: 12.11.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kandagatla	Guttakinda	11KV	Suryapet	07.50	09.05	01.15	E/L	11Kv Jumper cut	-
2		Azeempet	Kanchanpally	11KV	Bhongir	02.00	06.00	04.00	E/L	11Kv Line snapped at Sadarsha pur	-
3		Maryala	Wadaparthu	11KV	Bhongir	04.50	07.50	03.00	E/L	Bird Fallen On Line at Near Wadaparthu	-
4		Rajapet	Ranikunta Agl	11KV	Bhongir	09.30	12.20	02.50	E/L	11KV Line snapped & Insulator failed at Ranikunta	-