

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360									
7	Hyd	186	1014									
	Total	504	2929	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2		2		2				
2	NLG	150	948		8		8		8			
3	MDK	87	828	1	1	1	1	1	1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	9	3	9	3	9	0	0	
	Grand Total	908	6149	3	12	3	12	3	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.11.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Hamsanpally	33KV	Mahabubnagar	13.25	17.05	03.40	E/L	Squirrel fallen on the line near Hamsanpally SS	Hamsanpally	-
2		Maddur	Vepur	33KV	Mahabubnagar	17.50	20.45	02.55	E/L	Alternate Supply Arranged to 33KV Maddur Feeder Supply Stud Ok	Vepur	Alternate Supply Arranged to 33KV Maddur Feeder Supply Stud Ok at 20:45Hrs
1	MDK	Narayankhed	Poosalpad	33KV	Jogipet	14.15	15.55	01.40		B/D due to Jumper cut	Poosalpad	-

TSSPDCL - LMRC / Corporate office

Date: 13.11.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Bibigudem	Bibigudem AGL	11KV	Suryapet	07.45	09.00	01.15	E/L	11Kv Jumper cut	-
2		Cheruvupally	Dacharam	11KV	Nalgonda	07.46	09.58	02.12	E/L	11 KV Line Insulator Failed	-
3		Alingapuram	Gundlapahad	11KV	Huzurnagar	13.05	16.45	03.40	E/L	11 KV Line snapped at Gundlapally (v)	-
4		Keethavarigudem	Velidanda	11KV	Huzurnagar	03.05	07.00	03.55	E/L	11 kv jumper cut at j p Gudem (v)	-
5		Huzurnagar	Lakkaram	11KV	Huzurnagar	10.00	12.00	02.00	E/L	Phase to phase Touched at Lakkaram (v)	-
6		Azeempet	Kanchapally	11KV	Bhongir	07.00	10.15	03.15	E/L	11KV Jumper snapped at Boddugudem (V)	-
7		Peddathanda	Pallepahad	11KV	Bhongir	13.20	17.15	03.55	E/L	11KV Insulator failed at Gollagudem	-
8		Azeempet	Kanchanpally	11KV	Bhongir	07.00	10.15	03.15	E/L	11KV Jumper snapped at Boddugudem (V)	-
1	MDK	Kondapur	Gangaram	11KV	Sangareddy	13.45	16.50	03.05		B/D due to Jumper cut at Haridaspur cross road	-
1	RR N	Chinthal	Surya Nagar	11KV	MDCL	03.47	05.05	01.18	BD	11KV UG Cable Failed at Hanuman Temple, Ramreddy Nagar(Backfeeding arranged from 11KV Padma Nagar Feeder)	-
2		Athiwelly	Ravalkole Thanda	11KV	MDCL	16.06	17.15	01.09	BD	11KV Pole damaged at Rekulabavi (Back feeding Arranged to 11KV Ravalkole Feeder)	-
3		Athiwelly	PHI Seeds	11KV	MDCL	16.06	18.15	02.09	BD	11KV Pole damaged at Rekulabavi (Back feeding Arranged to 11KV IDA Yellampet Feeder)	-