

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407	1	2	1	2	1	2			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	1	4	1	4	1	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828	3	4	3	4	3	4			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	8	3	8	3	8	0	0	
	Grand Total	908	6149	4	12	4	12	4	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.11.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Habsipur	Dubbak	33KV	Siddipet	07.23	07.50	00.27		B/D Due to Tree Branches Fallen on line	Habsipur	-
2		Medak	Narsapur	33KV	Reddypally	06.15	11.15	05.25		B/D Due to Disk Change near Reddypally SS	Medak	-
3		Toopran	Gajwel	33KV	Pregnapur	13.50	17.30	03.40		B/D Due to Jumper cut at SPM	Toopran	-
1	RR N	LGM Pet	ICICI	33KV	Medchal	09.12	10.46	01.34	BD	VCB Problem(Tripped on EL Indication)	LGM Pet	-

TSSPDCL - LMRC / Corporate office

Date: 17.11.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Penpahad	SingireddyPalem	11KV	Suryapet	07.00	09.10	02.10	E/L	Jumper cut	-
2		Pamanagundla	Yerrasanigudem	11KV	Nalgonda	06.00	09.30	03.30	E/L	11 KV Jumper Cut Under SS-4	-
3		Repala	Kalakova	11KV	Huzurnagar	03.30	06.45	03.15	el	11 kv line snapped at Kalakova village	-
4		Alair	Ch.Kandukur	11KV	Bhongir	05.00	07.30	02.30	EL	Jumper cut	-
1	MDK	H Ghanpur	H Ghanpur	11KV	Medak	07.45	13.30	05.45		B/D due to Phase to Phase	-
2		Ch.Ghanpur	Ch.Ghanpur	11KV	Medak	10.10	11.20	01.10		B/D Due to Lightning errection Failed	-
3		Narsingi	Pappannapet AGL	11KV	Medak	15.20	17.05	01.45		B/D Due to 33 KV LINE Problam	-
4		Burugupally	Yelupgonda	11KV	Medak	07.28	10.03	02.35		B/D Due to Bird Fallen on line	-
1	RR N	J D M SS-II	Phase-V	11KV	JDM	12.12	14.15	02.03	BD	11kv AB Cable ENDY Kit Failure at AVYAS Industrea Phase-V	-
2		Gowdavelly	Ayodhya	11KV	Medchal	07.00	09.10	02.10	BD	11KV Pin Insulator failed at Ayodhya Road, Saketh Venture	-
1	RR E	Moula ali	Mirjalguda	11KV	Sainikpuri	05.47	07.40	01.53		11Kv AB Cable faile dt Ganesh Nagar near Upper Guda (FOC Arif)	-
1	HYD C	Lake View	Vijaya Hospital	11KV	Saifabad	15.58	17.10	01.12	EL	Conductor snapped at Vijaya Hospital	-