

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 48 | 158 | | | | | | | | | |
| 2 | NLG | 18 | 406 | | | | | | | | | |
| 3 | MDK | 92 | 383 | | | | | | | | | |
| 4 | RR(S) | 40 | 201 | | 1 | | 1 | | 1 | | | |
| 5 | RR(N) | 82 | 407 | | 1 | | 1 | | 1 | | | |
| 6 | RR(E) | 38 | 360 | | | | | | | | | |
| 7 | Hyd | 186 | 1014 | | | | | | | | | |
| | Total | 504 | 2929 | 0 | 2 | 0 | 2 | 0 | 2 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 110 | 969 | 1 | | 1 | | 1 | | | | |
| 2 | NLG | 150 | 948 | | 4 | | 4 | | 4 | | | |
| 3 | MDK | 87 | 828 | 1 | | 1 | | 1 | | | | |
| 4 | RR(S) | 31 | 338 | | | | | | | | | |
| 5 | RR(N) | 8 | 48 | | | | | | | | | |
| 6 | RR(E) | 18 | 89 | | | | | | | | | |
| | Total | 404 | 3220 | 2 | 4 | 2 | 4 | 2 | 4 | 0 | 0 | |
| | Grand Total | 908 | 6149 | 2 | 6 | 2 | 6 | 2 | 6 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 18.11.2017

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|-----------------------|---------------------------|
| 1 | MBNR | Balanagar | G.R Cable | 33KV | Jadcherla | 10.15 | 11.50 | 01.35 | E/L | for AB Switch Open an Tree Cutting at Rangareddy Guda Viillage | | - |
| 1 | MDK | Chegunta | Bonala | 33KV | Toopran | 09.40 | 11.05 | 01.25 | | B/D due to Disk fail near Annasagar Village. | | - |

TSSPDCL - LMRC / Corporate office

Date: 18.11.2017

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | NLG | Kattangur | Kattangur | 11KV | Nalgonda | 03.10 | 07.10 | 04.00 | EL | 11kV Line Insulator Failed | - |
| 2 | | Kethapally | Kethapally | 11KV | Nalgonda | 09.20 | 10.50 | 01.30 | EL | 11kV Line Jumper Cut | - |
| 3 | | Gaddipaly | Medaram | 11KV | Huzurnagar | 13.20 | 15.30 | 02.10 | EL | Due to 11Kv line Snapped near Medaram Village | - |
| 4 | | Mukundapuram | Mukundapuram | 11KV | Huzurnagar | 15.35 | 17.30 | 01.55 | EL | Due to 11Kv line Snapped near Mukundapuram Village | - |
| 1 | RR S | Ibrahimbagh | Osmansagar | 11KV | IBGH | 04.30 | 06.03 | 01.33 | | 11kv Pole Broken at Hanuman temple jumper opened | - |
| 1 | RR N | KPHB | AdityaNagar | 11KV | KKP | 11.25 | 13.26 | 02.01 | EL&OL | 11kv AB Cable Failure At J N T U C | - |