

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360									
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948		7		7		7			
3	MDK	87	828	3		3		2		1		1 No.33kv still
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	8	3	8	2	8	1	0	
	Grand Total	908	6149	3	11	3	11	2	11	1	0	

TSSPDCL - LMRC / Corporate office

Date: 22.11.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothapally (C.C.K)	Dupally	11KV	Mahabubnagar	14.00	16.20	02.20		11KV Phase to Phase at Kothapally (Vi)	-
1	NLG	Tekumatla	Pillalamarry	11KV	Suryapet	04.30	07.00	02.30	E/L	11Kv Jumper cut	-
2		B.ramaram	Malyala	11KV	Bhongir	11.00	13.00	02.00	EL	11Kv Pin insulator failure	-
3		Maryala	Chouderpally	11KV	Bhongir	14.15	16.15	02.00	EL	11KV Lighting Erester Failed	-
4		Munugode	Velmakanne	11KV	Nalgonda	11.45	13.00	01.15	EL	Insulator failed & Jumper cut	-
5		Gollaguda	RTC feeder	11KV	Nalgonda	13.00	14.30	01.30	EL	11 KV line touch the pole	-
6		Dirsincherla	Somaram	11KV	Huzurnagar	08.00	09.40	01.40	EL	Due to 11Kv line cutted near Somaram village	-
7		Nadigudem	Brundavanapuram	11KV	Huzurnagar	16.10	18.00	01.50	EL	11kv jumper cutted near Brundavanapuram village	-
1	RR N	GP Pally	GP Pally	11KV	Medchal	03.00	04.45	01.45	BD	11KV Conductor Snapped at Ayodhya X Road	-
2		Devarayamjal	DMC	11KV	Medchal	07.40	09.40	02.00	BD	Bird fallen on the 11KV Line at 6th Pole DP & 11KV Jumper Cut at Kesav Reddy Venture	-
1	HYD S	Asmangadh	Saibaba Temple	11KV	VIII	16.30	17.45	01.15	EL,OL-Rph	2No DTR'S Kep off at Konark Daignostic	

TSSPDCL - LMRC / Corporate office

Date: 22.11.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Habsipur	Ragothampally	33KV	Siddipet	08.45	09.45	01.00		B/d due to Tree branches fallen on the line.	Ragothampally	-
2		Bollaram	Bollaram-III	33KV	Sangareddy	06.30	08.25	01.55		B/d due to Jumper cut.	Bollaram-III	-
3		Sadashivapet	Koheer	33KV	Sangareddy	20.30	00.00	03.30		B/d Continue.	Koheer	-