

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828	1		1		1				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	4	1	4	1	4	0	0	
	Grand Total	908	6149	1	8	1	8	1	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.11.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Habsipur	Dubbak	33KV	Siddipet	01.35	09.55	08.20		B/D due to Insulator fail near Chervvapur (V).		-

TSSPDCL - LMRC / Corporate office

Date: 23.11.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cheedella	Gajula malkapuram	11KV	Suryapet	07.15	10.40	03.25	EL	Line melt	-
2		Mkundapuram	Somaram	11KV	Huzurnagar	09.48	11.56	02.08	EL	Due to 11kv jumper cutted near Somaram village	-
3		Raghunadapalem	Gundlapally	11KV	Huzurnagar	15.30	17.00	01.30	EL	Due to Bird fall on 11kv near Gundlapally village	-
4		RAJAPET	RENIKUNTA	11KV	Bhongiri	02.00	05.00	03.00	EL	11 KV JUMPAR CUT AT RENIKUNTA VI	-
1	RR S	Gaganpahad	Gaganpahad	11KV	RJNR	17.15	20.15	03.00		11kv insulator Failed and Line snapped at bindu sariya instrumental Gaganpahad Due To Lorry Dashed	-
1	RR N	Athiwelly	Ravalkole Thanda	11KV	Medchal	11.00	14.15	03.15		Bird fallen on the 11KV Line at Rekulabavi	-
1	RR E	AUTONAGAR	AUTONAGAR	11KV	SAROORNAGAR	14.25	15.25	01.00	EL/OL	11KV INSULATER FAIL AT AUTONAGAR	-
1	HYD N	Nehru Nagar	Contonment	NT	V	23.54	01.05	01.11	EL	Twisted lines at Post Office DTR	-