

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360									
7	Hyd	186	1014		3		3		3			
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2		2		2				
2	NLG	150	948		6		6		6			
3	MDK	87	828	1	6	1	6	1	6			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	12	3	12	3	12	0	0	
	Grand Total	908	6149	3	16	3	16	3	16	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.11.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Paspula	33KV	Mahabubnagar	06.50	08.45	01.55	E/L	No Visible Fault	Paspula	Mustipally Jumpers Opened supply OK
2		Wanaparthi	Gopalpet	33KV	Wanaparthi	02.55	03.47	00.52	E/L	No Visible Fault	Gopalpet	11KV Line Opened
1	MDK	Thunki Bollaram	Sitharampally	33KV	Siddipet	02.00	08.35	06.35		B/D Due to Disc failiure and Jumper Cut	Sitharampally	-

TSSPDCL - LMRC / Corporate office

Date: 25.11.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Durajpally	Khasimpet	11KV	Suryapet	10.20	12.10	01.50	E/L	11Kv Jumper cut	-
2		Dirincherla	Somaram	11KV	Huzurnagar	03.00	06.00	03.00	E/L	1ps DTR Failed at Batvanikunta village	-
3		Urlagonda	N S Puram	11KV	Huzurnagar	11.00	13.00	02.00	E/L	11 inslater failed at N S Puram village	-
4		Janpahad	Shunyapahad	11KV	Huzurnagar	12.00	14.50	02.50	E/L	11 kv line snapped at Shunyapaha village	-
5		M.T.Pally	Dathaipally	11KV	Bhongir	12.00	14.45	02.45	E/L	11Kv Jumpersnapped at Dathaipally	-
6		Motakondur	Cholluru	11KV	Bhongir	09.00	10.10	01.10	E/L	11KV Jumper snapped at Mahububpet	-
1	MDK	Ramaipally	Uppulingapur	11KV	Toopran	09.05	16.20	07.15		B/D Due to Jumper Cut	-
2		Narsapur	Reddypally	11KV	Medak	07.11	11.00	03.49		B/D Due to Disc failiure	-
3		Amsanpally	Amsanpally	11KV	Medak	09.00	12.00	03.00		B/D Due to Jumper Cut	-
4		Shankarampet	Uthloor	11KV	Medak	11.50	13.00	01.10		B/D Due to Jumper Cut	-
5		Isnapur	IDA-1	11KV	Sangareddy	17.30	18.05	00.35		B/D Due to thonda fallain on 11kv line at GVK Co.	-
6		Cheryal	Indrakaran	11KV	Sangareddy	08.40	09.45	01.05		B/D Due to Jumper Cut	-
1	RR N	JTPL	KSR Enclave	11KV	Kukatpally	06.40	07.35	00.55	OL	Line Petroling No Visible Falt	-
1	HYD N	Bhudevi Nagar	Yadamma Nagar	11KV	VI	17.45	19.00	01.15	EL	Insulator flash over & HT Jumper cut at Shiva Nagar	Partial B/F on 11KV Kanajiguda feeder
1	HYD S	Kanchanbagh	Jamal Colony	11KV	VIII	06.16	08.20	02.04	EL	UG Cable fault at Royal Hotel	Arranged B/F on 11KV Jahangir Nagar feeder
2		C.R.P.F	Baba Nagar	11KV	III	20.25	21.30	01.05	EL,OL	End Kit failed at Makaramsabi DTR	-