

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407	1	2	1	2	1	2			
6	RR(E)	38	360									
7	Hyd	186	1014		1		1		1			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>1</b>	<b>3</b>	<b>1</b>	<b>3</b>	<b>1</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		3		3		3			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 26.11.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV LGM Pet	33KV LGM Pet	33KV	MDCL	05.25	06.35	01.10		33KV Pin Insulator failed at Monsanto company	33KV LGM Pet	-

## TSSPDCL - LMRC / Corporate office

Date: 26.11.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Sharajipet	Gouthami indus	11KV	Bhongir	10.10	11.40	01.30	EL	Insulator failure	-
2		Gurraladandi	Ramugunta thanda	11KV	Bhongir	12.00	15.55	03.55	EL	11KV Conductor Snapped at ramugunthanda	-
3		Bopparam	Midthanapally	11KV	Suryapet	05.00	07.40	02.40	E/L	Line cut	-
1	RR N	Shameerpet	Leo Meridian	11KV	MDCL	07.45	09.32	01.47		11KV Conductor Snapped at Upparapally Village	-
2		Aliabad	LGM Pet	11KV	MDCL	09.45	10.25	00.40		No Visible Fault	-
1	HYD N	Osm. University	Ravindra Nagar	11KV	V	04.15	06.35	02.20	EL,OL-Yph	Jumper cut & Bat fallen on lines at Opp: SS	-