

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360									
7	Hyd	186	1014		3		3		3			
	Total	504	2929	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2	1	2	1	2	1			
2	NLG	150	948		3		3		3			
3	MDK	87	828	1		1		1				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	4	3	4	3	4	0	0	
	Grand Total	908	6149	3	10	3	10	3	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.11.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Eklaspur	Eklaspur	11KV	Jadcherla	07.30	08.00	00.30		11KV Phase to Phase at Eklaspur (Vi)	-
1	NLG	Gaddipaly	Medaram	11KV	Huzurnagar	04.40	07.45	03.05	OL	Due to 1PH DTR Failure near Medaram village	-
2		Huzurnagar	Burugadda	11KV	Huzurnagar	07.00	09.00	02.00	EL	Due to bird fall on 11Kv line near Burugadda village	-
3		Repala	V R Puram	11KV	Huzurnagar	08.55	15.40	06.45	EL	Due to HT Jumper cutted near V R Puram village	-
1	RR N	Suraram	Venkatram Nagar	11KV	Jeedimetla	02.25	04.15	01.50	BD	11kv line Disk Failure at opp:M.Raju House,Venkatram Nagar	-
2		J D M SS-I	Phase-V	11KV	Jeedimetla	11.10	12.10	01.00	BD	11kv Line Cut At K R D Industrial Pipe Line road	-
3		Bandamadaram	Barmajiguda	11KV	Medchal	19.35	20.45	01.10	BD	11KV Pole Damaged at Airtel Tower,Dabeerpur(V)	-
1	HYD S	Santosh Nagar	Moinbagh	11KV	Asmangadh	06.18	08.48	02.30	EL,OL	Cat fallen on Insulator at Shivaji Nagar	Partial fdr charged & remaining loads added on 11KV Patel Nagar fdr
2		Attapur	Kishan Bagh AB	11KV	Asmangadh	13.55	15.40	01.45	EL	Cable End Kit sparking & Insulator flash over at Dall Mandi	-----
1	HYD C	Langer House	Prashanth Nagar (Langer House UG)	11KV	Mehdipatnam	15.05	17.12	02.07	EL,OL-Rph	Cable fault at Govt. School	(Kept off 2No. DTR's)

TSSPDCL - LMRC / Corporate office

Date: 28.11.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Oil Seeds	33kv	Gadwal	09.20	13.40	04.20	E/L	33KV Line Phase to Phase Near Beerelly(V)	Oil Seeds	-
2		Nagarkurnool	Peddakothapally	33kv	Nagarkurnool	12.55	16.30	03.35	E/L	Leserd follen on the line at Itikyala Village	Peddakothapally	-
3	MDK	Palamakula	Gonepally	33kv	Siddipet	07.20	09.15	01.55		B/D due to Pin Insulator fail.	Gonepally	-