

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014									
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	4	0	4	0	4	0	0	
	Grand Total	908	6149	0	8	0	8	0	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 30.11.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nuthankal	Somlathanda	11KV	Suryapet	07.00	09.30	02.30	E/L	11Kv Jumper cut	-
2		Peddathanda	Pallephad	11KV	Bhongir	10.00	11.40	01.40	E/L	HT/LT	-
3		Palakaveedu	Palakeedu	11KV	Huzurnagar	03.00	06.00	03.00	O/L	11Kv Insulator failure near Palakeedu (v)	-
4		Mattampally	Allipuram	11KV	Huzurnagar	06.00	10.00	04.00	E/L	11Kvline cutted near Allipuram village	-
1	RR S	NPA	Saibabanagar	11KV	RJRN	06.20	07.53	01.33	B/D	11KV Cable failed at Aramghar Railway track B/F Given on 11KV Babulreddy nagar	-
1	RR N	Kolthur	Kolthur	11KV	Medchal	13:10	14:40	1:30		11KV Jumper Opened at Basavappa Bhavi, Jaganguda Road	-
1	RR E	FRUITMARKET	JANIMANDIR	11KV	SAROORNAGAR	09.45	10.45	01.00	OL/EL	11KV CUBLE FAIL& 11kKV JANIMANDIR LOAD BACK FEDDING TO 11KV CHAITANYAPURI	-
2		RAJIVSWAGRU	JAIPURICOLONY	11KV	SAROORNAGAR	10.05	11.28	01.23	EL/OL	DTR FAIL& 11KV JUMPER CUT AT JAIPURICOLONY	-