

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Nawabpet	33KV	Mahabubnagar	14.15	16.05	01.50	E/L	No visuble fault found I so later open at KCR SS feeder charge	Mahabubnagar	No
2		Makthal	Jaklair	33KV	Mahabubnagar	05.40	13.45	08.05	E/L	Y Phase insulator damaged replacemnt near 33/11KV Makthal SS	Makthal	No
3		Makthal	Paspula	33KV	Mahabubnagar	07.50	10.40	02.50	E/L	Pole no 125, 119 and 2no insulators damaged replacement new one insulators near Chinnagogulapuram (V)	Makthal	AB Switch Open at Mustipally Village at 10:40Hrs
4		Makthal	Manganoor	33KV	Mahabubnagar	04.25	11.10	06.45	E/L	Tree branches follen on the line and Cutting Work near Chandapur Villge	Makthal	No
5		Maddur	Mogalmadka	33KV	Mahabubnagar	06.30	12.40	06.10	E/L	Tree Fallen on the 33Kv Line and 4Nos Insulator Replasment at Ashanpally Chervu	Maddur	No
6		Gadwal	Alwalpad	33KV	Gadwal	04.50	08.48	03.58	E/L	2no insulators failed and Tree follen on the line and removed	Gadwal	Alternate supply arranged from 33KV Nandinne feeder at 8:48Hrs
7		Alampur	Shanthinagar -1	33KV	Gadwal	09.40	10.25	00.45	E/L	33KV insulator replaced on 33KV Shanthinagar1 at near Shanthinagar Town.	Alampur	33KV Line AB Switch Open at Paipad Village
8		Polepally	Gangapur	33KV	Jadcherla	14.45	16.32	01.47	E/L	Tree branches follen on the line and Cutting Work	Polepally	NO
9		Singotam	Kollapur	33KV	Nagarkurnool	01.26	02.55	01.29	E/L	Insulator failed and replaced	Singotam	NO
1	MDK	Gummadidala	GPSS-1	33KV	Sangareddy	18.50	19.50	01.00		B/D Due to Heavy wing and Gail tripped on O/L B Phase	Gummadidala	NO
2		Kandi	Sangareddy - II	33KV	Sangareddy	19.20	24.00	04.40		Due to Under Breakdown	Kandi	NO
3		Kandi	HFC-II	33KV	Sangareddy	21.20	24.00	02.40		Due to Under Breakdown	Kandi	NO
4		Kandi	BDL	33KV	Sangareddy	17.30	21.15	03.45		B/D Due to Insulator failure	Kandi	NO
5		Zaheerabad	Allana	33KV	Sangareddy	20.40	24.00	03.20		Due to Under Breakdown	Zaheerabad	NO
6		Zaheerabad	Chota Hyderabad	33KV	Sangareddy	19.40	24.00	04.20		Due to Under Breakdown	Zaheerabad	NO
7		Pashamailaram	Manjeera	33KV	Sangareddy	16.24	20.50	04.26		B/D Due to tree branches fallen on the line	Pashamailaram	NO
8		Pashamailaram	Mylan	33KV	Sangareddy	16.45	24.00	07.15		Due to Under Breakdown	Pashamailaram	NO
9		Pashamailaram	APL IV	33KV	Sangareddy	16.45	24.00	07.15		Due to Under Breakdown	Pashamailaram	NO
10		Pashamailaram	Nandigama	33KV	Sangareddy	19.20	24.00	04.40		Due to Under Breakdown	Pashamailaram	NO
11		Ramayampet	Laxmapur	33KV	Toopran	17.55	18.45	00.50		B/D Due to Conductor Snapped	Ramayampet	NO
12		Siddipet	Komuravelly	33KV	Siddipet	21.00	23.00	01.29		B/D Due to alternate supply given to Tharigopulla fedder	Siddipet	NO

TSSPDCL - LMRC / Corporate office

Date: 02.10.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Devarkadra	Koilsagar	11KV	Mahabubnagar	00.00	08.00	08.00		11KV Tree fallen on conductor Near RaaKonda (V)	-
2		Devarkadra	Lalkota	11KV	Mahabubnagar	08.00	10.30	02.30		11KV Conductor cut at Goplapur (Vi)	-
3		Devarkadra	Chowderpally	11KV	Mahabubnagar	10.00	12.00	02.00		11KV Tree fallen on conductor Near Devarkadra (V)	-
4		Devarkadra	Gudibanda	11KV	Mahabubnagar	03.30	09.00	05.30		11KV Phase to Phase Near Devarkadra V)	-
5		Nagaramgate	Nagaram	11KV	Mahabubnagar	08.20	12.00	03.40		11KV Jumper cut at Peddarajmoor (vi)	-
6		Kondapur	Hanmanpally	11KV	Mahabubnagar	04.00	10.00	06.00		11KV Insulator Damage near Aakur Thanda (V)	-
7		Rajapur	Salguti	11KV	Jadcherla	06.10	08.15	02.05		Tree fallen on 11 kv line near Kucharkal	-
8		Kothamolgara	Town	11KV	Jadcherla	01.30	07.10	05.40		11 kv wire cut near Pathamolgara	-
9		Kavaram pet	Bandamidi pally	11KV	Jadcherla	14.40	17.40	03.00		11 kv insulator fail near jayaprakash nagar	-
1	NLG	Nuthankal	Yerrapahad	11KV	Suryapet	07.30	09.20	01.50	E/L	11Kv Jumper Cut	-
2		Kethepally	Inupamula	11KV	Nalgonda	15.45	17.00	01.15	E/L	11Kv Insulator failed	-
3		Kattangur	Duginelly	11KV	Nalgonda	17.00	19.00	02.00	E/L	11KV Jumper cut	-
4		Rajupeta	Rajupeta	11KV	Nalgonda	14.10	15.15	01.05	E/L	Tree fallen on line	-
5		Arlagaddagudem	Chinna Suraram	11KV	Nalgonda	12.00	13.10	01.10	E/L	11Kv Insulator failed	-
6		Narketpally	Mandra	11KV	Nalgonda	13.00	15.30	02.30	E/L	11KV Jumper cut	-
7		Narketpally	M.Yedavally	11KV	Nalgonda	13.10	15.00	01.50	E/L	11Kv Insulator failed	-
8		Narketpally	Yellareddygudem	11KV	Nalgonda	13.20	14.45	01.25	E/L	11Kv Insulator failed	-
1	MDK	Thogita	Kuchanpally	11KV	Medak	15.12	16.45	01.33		B/D Due to Insulator failure	-
1	RR S	CBIT	Movietower	11KV	IBGH	19.00	21.02	02.02		Tree Branches fallen on 11 KV Line at CBIT Gate	-
2		Kokapet	Ocean park	11KV	IBGH	20.10	21.34	01.24		Tree Branches fallen on 11 KV Line at Ocean park	-
1	KPHB	KPHB	Jalavahivihar	11KV	KKp	18.01	19.25	01.24	OI	T/F Brass patti Cut & Tach the pole at Arjun Theater ,bhagyanagar	-
2		Shemshiguda	Janaboomi Colony	11KV	KKp	17.30	20.00	02.30	EI&OL	11kv line Cut at Shivamma Colony	-
3		Vijayanagar	Aruna Socity	11KV	KKp	18.10	20.30	02.20	OI	Tree fallon the 11kv line Cybar Auto Moblies, aruna Socity	-
4		Nizampet	Journalist Colony	11KV	KKp	19.30	21.00	01.30	EI	Tree Fallon the 11kv line Road No:10A Rajadhani School	-
5		Mayurinagar	Cable	11KV	KKp	17.55	19.40	01.45	OI	Due To Rain	-
6		Mayurinagar	Mayurinagar	11KV	KKp	17.58	19.40	01.42	EI&OL	Due To Rain	-
7		Mayurinagar	G R R R	11KV	KKp	18.10	19.10	01.00	EI&OL	Due To Rain	-
8		Madinaguda	JPN Nagar	11KV	KKp	09.57	10.40	00.43	EL	Sperial Fallon the 11kv line at Janapriya West City, Miyapur	-
9		Madinaguda	miyapur	11KV	KKp	18.05	20.30	02.25	EL	Tree Fallon the 11kv line at Lakyview Enclave ,mipur	-
10		Vikas	Vikas	11KV	KKp	18.15	18.50	00.35	EI&OL	Due To Rain	-
11		Vijayanagar	Jalakanya	11KV	KKp	18.10	18.40	00.30	EL	Due To Rain	-
12		KPHB	HMT	11KV	KKp	18.02	18.53	00.51	EL	Due To Rain	-

13	RR N	KPHB	Gowthaminagar	11KV	KKp	18.05	19.00	00.55	EI&OL	Due To Rain	-	
14		Vijayanagar	Jayanagar	11KV	KKp	20.20	21.30	01.10	EL	Tree Fallon the 11kv line at monta Seri School, Huda park ,Vijayanagar colony	-	
15		Vijayanagar	Sapthagiri Colony	11KV	KKp	20.30	21.00	00.30	EI&OL	Due To Rain	-	
16		Vikas	Co-ca-Cola	11KV	KKp	20.30	21.50	01.20	EL	Due To Rain	-	
17		Jeedimetla-l	Balaji	11KV	JDM	18.10	18.45	00.35	EL	Due To Rain	-	
18		Jeedimetla-l	NITCO	11KV	JDM	18.35	20.35	02.00	EL	11kv line Phase to Phase at 40 feet road ,phase-l	-	
19		Jeedimetla-l	Thirumala	11KV	JDM	19.07	20.40	01.33	EL	Due To Rain	-	
20		Jeedimetla-l	JETL	11KV	JDM	18.40	21.20	02.40	EL	11kv line Jumper Opend {Due To Rain}	-	
21		Jeedimetla-l	Shapurnagar	11KV	JDM	21.50	22.50	01.00	EI&OL	11kv line phase to phase at L L B nagar	-	
22		Aleap	Doctors Colony	11KV	JDM	19.10	21.10	02.00	EL	Tree Fallon the 11kv line at plot no:1342,1362 Doctors colony	-	
23		Aleap	Cable	11KV	JDM	19.10	20.10	01.00	EL	Tree Fallon the 11kv line at plot no:1347 Doctors colony	-	
24		Dppally	Ganddimaisamma	11KV	JDM	19.05	20.05	01.00	EL	11kv line Cut at Ganddimaisamma X road	-	
25		Bowrampet	Co-ca-Cola	11KV	JDM	19.20	20.30	01.10	EL	11kv line PinInsulater failure & Replecment at Hamara Dhaba,Bowrampet	-	
26		Subash Nagar	Jeedimetla	11KV	Medchal	18.50	20.10	01.20	EL	11KV Pin Insulator failed at HDFC Bank	-	
27		Kompally	Jaibheri	11KV	Medchal	20.10	20.55	00.45	EL	Tree fallen on the 11KV Line at Dulapally Road	-	
28		Ravalkole	IDA	11KV	Medchal	15.55	18.05	02.10	EL	11KV Cable failed at Kashimbavi Thanda	-	
29		Kandlakoya	Godrej	11KV	Medchal	19.20	22.30	03.10	EL	11KV Pin Insulator failed at Asian Paints Company	-	
30		Aliabad	Majeedpur	11KV	Medchal	21.40	22.40	01.00	EL	11KV Disc failed at Aliabad X Road	-	
1		RR E	Moula-Ali	Spectra	11KV	Sainikpuri	17.20	20.40	03.20		Ground Petroling done but no Visible fault found	-
2			Malkajgiri	Durga Nagar Over Head	11KV	Sainikpuri	17.24	21.00	03.36		Big Stik Fallen on 11Kv line at Getha Nagar (LM Badri)	-
3			IDA Uppal	Srikrishna	11KV	Habsiguda	16.51	18.40	01.49		Tree fallen on 11kv line near Sarathi Company	-
4			Ramanthapur	Gokhale nagar	11KV	Habsiguda	18.10	19.40	01.30		11KV line twisted near Church godham DTR	-
5			St.no.08	Ravindra Nagar	11KV	Habsiguda	18.14	20.09	01.55		Tree branches fallen near Hyd public schhol & 11KV line snapped near SR Apartment at Ravindra Nagar Colony	-
6			Singapur	IT Park	11KV	Keesara	06.20	08.15	01.55		11KV Cable failed near Aravinda Flex at Annojiguda	-
7			P&T Colony	NIN	11KV	Keesara	19.30	20.30	01.00		11KV Pin Insulator failed near Tirumala Apartment	-
8			Peerzathiguda	Shankar Nagar	11KV	Keesara	19.00	20.15	01.15		11KV Disc failed at Bhavi Krishna Nagar	-
9			Rampally Dayara	Vanneguda AGL	11KV	Keesara	20.10	22.22	02.12		Line patrolling but no visible fault & AB Switch opened near RR Poultry Form	-
1			H.P.S.	RBI Quarters	11KV	Erragada	17.15	18.55	01.40	EL,OL-Rph	No Visible Fault	-----
2			Sanjeevaiah Park	Patigadda Quarters	11KV	Erragada	17.32	18.58	01.26	EL	Tree branches fallen on lines at Govt.School	-----
3			Prakash Nagar	Prakash Nagar Ext.	11KV	Erragada	17.35	18.50	01.15	OL	Tree branches fallen on lines at Prakash Nagar	-----
4	Bora Banda		Saradhi Nagar	11KV	Erragada	17.45	18.55	01.10	OL	No Visible Fault	-----	
5	Begumpet		S.R Nagar	11KV	Erragada	18.00	19.30	01.30	EL	Tree branches fallen on lines at S.R Nagar	-----	
6	Begumpet		Shanthi Bagh	11KV	Erragada	18.10	19.35	01.25	EL	Tree branches fallen on lines at Shanthi Bagh	-----	
7	Begumpet		Green Park	11KV	Erragada	18.10	19.35	01.25	EL	Tree branches fallen on lines at Green Park	-----	

8		Kundanbagh	Shanthi Shikara	11KV	Erragada	18.20	20.50	02.30	All Indication	Tree branches fallen on lines at Babu Khan Millinium	----
9		Lodha	Crown Casting	11KV	Erragada	19.48	22.30	02.42	EL	Tree branches fallen on lines near SS	----
10		K.I.M.S	Krishna Nagar	11KV	Sec-Bad	17.40	21.26	03.46	EL	No Visible Fault	----
11		James Street	P.G Road	11KV	Sec-Bad	17.42	19.30	01.48	EL	Tree branches fallen on lines at P.G Road	----
12		Gymkhana	Balamrai	11KV	Sec-Bad	17.50	23.12	05.22	EL,OL	DTR fault at Balamrai	----
13		Gymkhana	Vikrampuri	11KV	Sec-Bad	17.55	23.10	05.15	EL,OL	Tree branches fallen on lines at Vikrampuri	----
14		Gymkhana	Mud Fort	11KV	Sec-Bad	18.05	20.35	02.30	All Indication	Tree branches fallen on lines at Mud Fort	----
15		James Street	Chikoti Complex	11KV	Sec-Bad	18.25	19.45	01.20	EL	CT PT fault at South India Shopping Mall	----
16		Osm. University	Mettuguda	11KV	Sec-Bad	18.45	20.15	01.30	OL-Rph	No Visible Fault	----
17		Gymkhana	Vasavi Nagar	11KV	Sec-Bad	19.05	23.55	04.50	EL,OL-Bph	Tree branches fallen on lines at Vasavi Nagar	----
18		Gymkhana	Apollo	11KV	Sec-Bad	19.10	23.50	04.40	EL,OL-Bph	Tree branches fallen on lines at Apollo	----
19		Chikalguda	Pragatools	11KV	Sec-Bad	19.20	20.43	01.23	EL	Tree branches fallen on lines at Mekala Mandi	----
20		Marredpally	Ramsar Café	11KV	Sec-Bad	19.55	21.15	01.20	EL,OL-Bph	Tree branches fallen on lines at Road No.2	----
21	HYD N	Sanjeevaiah Park	Police Lines	11KV	Sec-Bad	19.56	21.45	01.49	EL	Sparkings on CT at SS	Arranged B/F on 11KV My Fair Complex feeder
22		Gunrock	Bowenpally	11KV	Sec-Bad	21.40	23.55	02.15	EL,OL-Rph	Under Breakdown	Arranged B/F on 11KV Mud Fort feeder
23		I.D.P.L	Shivalayam	11KV	Bowenpally	17.40	19.00	01.20	EL,OL-Bph	No Visible Fault	----
24		I.D.P.L	Wonder Plast	11KV	Bowenpally	17.50	19.30	01.40	EL	No Visible Fault	----
25		Raheja	Gafoor Nagar	11KV	Banjarahills	17.30	19.00	01.30	EL	Pin Insulator flash over at Mohanbabu Guest House	----
26		Yellareddyguda	Engineers Colony	11KV	Banjarahills	17.35	22.25	04.50	EL	Tree branches fallen on lines at R.B.I Quarters	----
27		Yellareddyguda	Maruthi Nagar	11KV	Banjarahills	17.40	23.30	05.50	EL	Pin Insulator flash over at Opp: RBI Quarters	----
28		Road No.2	Arora Colony	11KV	Banjarahills	17.42	21.00	03.18	OL-Rph	Tree branches fallen on lines at Arora Colony Park	----
29		Toli Chowki	Hanuman Temple	11KV	Banjarahills	17.44	19.12	01.28	EL	No Visible Fault	----
30		Yellareddyguda	Akber Form	11KV	Banjarahills	17.45	22.30	04.45	EL	Tree branches fallen on lines at Akber Form	----
31		Road No.2	Lumbini Mall	11KV	Banjarahills	19.05	23.20	04.15	OL-R&Bph	HT Jumper cut at Sagar Society	----
32		LV Prasad Marg	Gymkhana Club	11KV	Banjarahills	19.08	23.50	04.42	EL,OL	HT Line snapped at Road No.2	----
33		Srinagar Colony	Kamma Sangam	11KV	Banjarahills	19.17	20.40	01.23	EL,OL	Pin Insulator flash over at Anand Apts	----
34		Yousufguda	Stadium	11KV	Banjarahills	19.57	23.50	03.53	EL	No Visible Fault	----
35		Srinagar Colony	Kamma Sangam	11KV	Banjarahills	22.45	01.30	02.45	EL,OL-Bph	UG Cable End Kit failed near SS	----
36		Yellareddyguda	Akber Form	11KV	Banjarahills	23.50	01.30	01.40	EL	No Visible Fault	----
1		Falaknuma	Fathima Nagar	11KV	Charminar	16.55	20.30	03.35	EL	Tree branches fallen on lines at Urdu School	----
2		C.R.P.F.	Baba Nagar	11KV	Charminar	17.25	18.55	01.30	EL,OL	Pin Insulator flash over at Farah Masjid	----
3		Falaknuma	Chatrinaka	11KV	Charminar	18.15	21.00	02.45	EL	Tree branches fallen on lines at Bala Gunj	----
4		Aliabad	Shamsheer Gunj	11KV	Charminar	22.52	02.43	03.51	OL-Bph	3No. HG fuses blown off & 3No. Jumpers cut at Water Works	Arranged B/F on 11KV Sather Bagh feeder
5		Gunj	Farhath Hospital	11KV	Asmangadh	10.38	11.46	01.08	EL	No Visible Fault	----
6		Malakpet B-Block	LIC Colony	11KV	Asmangadh	16.27	21.35	05.08	OL-R&Yph	No Visible Fault	----
7		Malakpet B-Block	Anand Biscuit Factory	11KV	Asmangadh	16.29	21.22	04.53	All Indication	Under Breakdown	Arranged B/F on 11KV Saidabad Colony feeder
8		Malakpet	Azampura	11KV	Asmangadh	16.30	20.10	03.40	EL,OL-Rph	No Visible Fault	----

9	HYD S	Gunj	Farhath Hospital	11KV	Asmangadh	16.30	20.02	03.32	OL-Bph	Indra Sena Reddy DTR fault	----
10		Yakuthpura	Bada Bazar	11KV	Asmangadh	17.10	20.40	03.30	EL,OL-Bph	Big tree fallen on lines at Rain Bazar PS	----
11		Malakpet	Chaderghat	11KV	Asmangadh	17.35	19.50	02.15	All Indication	No Visible Fault	----
12		Malakpet B-Block	Samatha Degree College	11KV	Asmangadh	17.38	20.12	02.34	EL	No Visible Fault	----
13		Teegalaguda	Teegalaguda	11KV	Asmangadh	17.45	19.00	01.15	EL,OL-Bph	No Visible Fault	----
14		Malakpet	Noorkhan Bazar	11KV	Asmangadh	17.50	19.50	02.00	OL-Rph	No Visible Fault	----
15		Santosh Nagar	Jahangir Nagar	11KV	Asmangadh	17.52	19.05	01.13	EL,OL-Rph	No Visible Fault	----
16		Santosh Nagar	Bhavani Nagar	11KV	Asmangadh	18.03	19.40	01.37	EL	Disc Insulator flash over at Bhavani Nagar Post Office	----
17		Moosarambagh	Dilsukh Nagar	11KV	Asmangadh	19.30	02.30	07.00	All Indication	UG Cable fault at Icon Hosital	Arranged B/F on 11KV Shalivahana Nagar feeder
18	Santosh Nagar	Moon Star	11KV	Asmangadh	20.50	22.40	01.50	EL	Cut Jumper touching to DTR at Metro Hotel	----	
19	Karwan	R.S.Temple	11KV	Beugmbazar	03.20	05.50	02.30	EL	Cable fault at R.S.Temple	Arranged B/F on 11KV Dolphin Hotel fdr & 11KV Tappa Chabutha fdr	
1	HYD C	Hyderguda	Hyderguda	11KV	Saifabad	18.20	19.30	01.10	EL	Tree branches fallen on lines at Bahar Café	----
2		Amberpet	C.P.L	11KV	Azamabad	16.25	19.35	03.10	EL	No Visible Fault	----
3		Industrial Area	Azamabad Key SS	11KV	Azamabad	16.25	18.00	01.35	EL	No Visible Fault	----
4		Narayanguda	Narayanguda	11KV	Azamabad	16.30	17.45	01.15	EL	Tree branches fallen on lines at Achaiah Nagar	----
5		Fever Hospital	C.C Shroff Hospital	11KV	Azamabad	16.31	18.40	02.09	EL,OL-Rph	Tree branches fallen on lines & Pin Insulator flash over at Paragon Apts	----
6		Amberpet	6 Number	11KV	Azamabad	16.35	22.05	05.30	OL-R&Bph	HT Jumper cut at Bata Show Room	----
7		Industrial Area	Barkathpura	11KV	Azamabad	16.55	18.00	01.05	EL	Tree branches fallen on lines at Padma Colony	----
8		Industrial Area	Vidya Nagar	11KV	Azamabad	17.35	20.30	02.55	EL	HT Jumper cut at Vidya Nagar	----
9		Bathkamma Kunta	Ahobilmutt	11KV	Azamabad	17.35	18.38	01.03	EL	No Visible Fault	----
10		Industrial Area	RTC X-Roads	11KV	Azamabad	17.40	22.00	04.20	EL	Disc Insulator flash over at Matha Crane	----
11		Fever Hospital	Sri Ram Nagar	11KV	Azamabad	17.41	20.04	02.23	EL,OL-Rph	Tree branches fallen on lines at Sri Ram Nagar	----
12		Amberpet	Sanjeevaiah Nagar	11KV	Azamabad	17.45	21.25	03.40	EL,OL-Bph	No Visible Fault	----
13		Golnaka	Shivalayam	11KV	Azamabad	17.59	00.20	06.21	OL	Under Breakdown	Arranged B/F on 11KV Sanjeevaiah Nagar feeder
14		Amberpet	Zinda Tilismath	11KV	Azamabad	18.25	20.40	02.15	EL	No Visible Fault	----
15		S.D Hospital	Police Mess	11KV	Mehdipatanam	16.28	19.17	02.49	OL-R&Bph	Disc Insulator flash over at Opp: Police Mess	----
16		S.D Hospital	Humayun Nagar	11KV	Mehdipatanam	16.37	18.23	01.46	EL	No Visible Fault	----
17		Asif Nagar	Jyothi Nagar	11KV	Mehdipatanam	16.50	18.10	01.20	EL,OL	Tree branches fallen on lines at Jyothi Nagar	----
18		Nampally	Red Hills	11KV	Mehdipatanam	17.02	18.20	01.18	EL	No Visible Fault	----
19		Golconda	Darga Cable	11KV	Mehdipatanam	17.05	18.10	01.05	EL,OL-Bph	Pin Insulator flash over at Darga	----
20		Mothi Mahal	Heera Khana	11KV	Mehdipatanam	17.32	18.37	01.05	EL,OL	No Visible Fault	----
21		S.D Hospital	Ahmed Nagar OH	11KV	Mehdipatanam	18.01	20.36	02.35	EL	DTR fault at Bhola Nagar	----
22		Toli Chowki	Paramount Hills	11KV	Mehdipatanam	18.50	20.00	01.10	EL,OL-Yph	DTR fault at Baba Hotel	----
23		Langer House	Prashanth Nagar	11KV	Mehdipatanam	20.15	22.52	02.37	All Indication	Banner fallen on lines at Fly Over	----
24		Nampally	Amba Hospital	11KV	Mehdipatanam	21.00	23.00	02.00	EL	Twisted lines at Glory Talkies	----
25		S.D Hospital	Ahmed Nagar Cable	11KV	Mehdipatanam	21.46	00.04	02.18	EL	Tree branches fallen on lines at Syed Nagar Sista	----

26		Nampally	FAPCCI	11KV	Mehdipatanam	23.10	01.00	01.50	EL	Under Breakdown	Arranged B/F on 11KV Pearl Regency & 11KV Red Hills feeders
----	--	----------	--------	------	--------------	-------	-------	-------	----	-----------------	--

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		2		2		2			
5	RR(N)	82	407		30		30		30			
6	RR(E)	38	360		9		9		9			
7	Hyd	186	1014		81		81		81			
	Total	504	2929	0	122	0	122	0	122	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	9	9	9	9	9	9			
2	NLG	150	948		8		8		8			
3	MDK	87	828	12	1	5	1	5	1	7		7 nos.33kv still
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	21	18	14	18	14	18	7	0	
	Grand Total	908	6149	21	140	14	140	14	140	7	0	