

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effectcd	Alternate Supply Arranged
1	NLG	Kolanupaka	Raghunathpur	33KV	Bhongir	5:30	8:30	3:00	EL	33KV Insultor failed	Raghunathpur	No
2		Ramannapet	Aroor	33KV	Choutuppal	03.00	07.30	04.30	EL	33KV Disc failed near Aroor	Aroor	No
1	MDK	Kandi	BDL	33KV	Sangareddy	22:20	7:50	9:30		B/D Due to Pin Insulators failed	BDL	No
2		Kandi	ITW Signode	33KV	Sangareddy	22.20	12.20	14.00		B/D Due to Pin Insulators failed Rudraram Postoffice opposite	ITW Signode	No
3		R.C.Puram	Ambuja	33KV	Sangareddy	18.32	11.20	16.50		B/D Due to Conductor snapped at ICRISAT	Ambuja	No
4		Bollaram	Coca Cola	33KV	Sangareddy	11.50	16.50	05.00		B/D Due to Tree fallen on line	Coca Cola	No
5		Narayankhed	Sirgapur	33KV	Jogipet	22.20	17.00	18.40		B/D Due to Pin Insulators failed & supply given from 33KV Kalher feeder	Sirgapur	No
6		Narayankhed	Kalher	33KV	Jogipet	22.20	14.20	15.00		B/D Due to Pin Insulators failed	Kalher	No
7		Narayankhed	wasar	33KV	Jogipet	17.30	16.30	23.00		B/D Due to Pin Insulators failed	wasar	No
8		Muthayal	Musthayal	33KV	Siddipet	01.30	06.20	04.50		B/D Due to Insulator failure	Musthayal	No
9		Palamakula	Rampur	33KV	Siddipet	00.05	06.15	06.10		B/D Due to Lighting Arrested failure	Rampur	No
10		Husnabad	Koheda	33KV	Husnabad	00.05	06.00	05.55		B/D Due to Jumoer Cut	Koheda	No
11		Gajwel	Pregnapur	33KV	Siddipet	22.10	09.30	06.50		B/D Due to Insulator failure	Pregnapur	No
12		Gajwel	Jagadevpur	33KV	Siddipet	12.25	15.10	02.45		B/D Due to Insulator failure	Jagadevpur	No
13		Duddeda	Medhinipur	33KV	Siddipet	02.15	10.45	08.30		B/D Due to Disc failed at Thipparam	Medhinipur	No
14		Shenigaram	Ramachandarpur	33KV	Husnabad	01.15	13.15	12.00		B/D Due to Pin Insulators failed near Bagilapur	Ramachandarpur	No
15		Shenigaram	Chalimeda	33KV	Husnabad	00.50	13.25	12.35		B/D Due to Pin Insulators failed	Chalimeda	No
16		Manoharabad	Kallakal	33KV	Toopran	00.00	03.15	03.15		B/D Due to Insulator failure	Kallakal	No
17		Narsapur	RWS	33KV	Medak	20.45	07.40	11.55		B/D Due to Disc failure & Breker problem	RWS	No
18		Peddashankaampet	P. Shankarampet	33KV	Medak	00.00	08.15	08.15		B/D Due to Heavy rain & wind	P. Shankarampet	No
19		Peddashankaampet	Burgupally	33KV	Medak	00.00	13.20	13.20		B/D Due to Pin Insulator failed	Burgupally	No
20		Peddashankaampet	Alladurg	33KV	Medak	0:00	8:35	8:35		B/D Due to Lighting Arrested failure	Alladurg	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Sarjakhapet	Thogapur	11KV	Mahabubnagar	08.00	11.16	03.16		11KV Tree fallen on conductor Near Thogapur (Vi)	No
2		Sarjakhapet	Pothireddypally	11KV	Mahabubnagar	07.30	11.50	04.20		11KV Tree fallen on conductor Near Pothireddypally (Vi)	No
3		Kodangal	Parsapur	11KV	Mahabubnagar	07.10	10.00	02.50		11KV DTR Fault at Parsapur (Vi)	No
4		Machanpally	Pothanpally	11KV	Mahabubnagar	07.20	08.50	01.30		11KV Jumper cut at Pothanpally (vi)	No
5		Doulthabad	Allapur	11KV	Mahabubnagar	05.45	09.55	04.10		11KV Conductor cut at Allapur (Vi)	No
6		Bhoothupur	Amistapur Rural & AGL	11KV	Jadcherla	06.00	07.30	01.30		11 KV Insulator failure Near Goplapur(V) 11 Kv Wire Cut Near Nallakunta Tanda Side	No
7		Jaknalapally	Jaknalapally	11KV	Jadcherla	17.30	19.00	01.30		KV Disc failed Near Jaknalapally (V)	No
1	NLG	Yerkaram	Das Thanda	11KV	Suryapet	02.00	06.40	04.40	EL	Insulator failed	No
2		Kasarabad	Kesaram	11KV	Suryapet	03.00	07.00	04.00	EL	Disc failed	No
3		Nagaram	D.Kothapally	11KV	Suryapet	03.30	08.00	04.30	EL	Jumper cut	No
4		S.Gouraram	Vallala	11KV	Nalgonda	06.20	08.30	02.10	EL	11KV Jumper cut	No
5		Palem	Ogodu	11KV	Nalgonda	08.20	10.30	02.10	EL	11KV Pin insulators failed	No
6		Kadaparthi	P.Kondaram	11KV	Nalgonda	10.20	12.30	02.10	EL	11KV Disc failed	No
7		Nanadanam	Telephone Exchange	11KV	Bhongir	10.10	13.40	03.30	EL	11KV Insulator failed	No
8	Addaguduru	Ch.Ramaram	11KV	Bhongir	08.30	11.00	02.30	EL	11KV Line snapped	No	
9	Malkapur AGL	Malkapur AGL	11KV	Choutuppal	09.30	12.35	03.05	EL	11KV Line snapped	No	
1	MDK	SRD-T-II	Kalabgoor	11KV	Sangareddy	08.05	14.25	06.20		B/D Due to Pin Insulator failed	No
2		Cheryal	Julkal	11KV	Sangareddy	00.00	01.00	01.00		B/D Due to Heavy rain & wind	No
3		Cheryal	MYK	11KV	Sangareddy	00.00	10.00	10.00		B/D Due to Heavy rain & wind	No
4		Cheryal	Indrakaran	11KV	Sangareddy	06.00	14.00	08.00		B/D Due to Pin Insulator failed	No
5		Dharipally	Bhagirathpally	11KV	Medak	00.00	11.00	11.00		B/D due to Tree fallen on wires	No
6		Lingaipally	Kompally	11KV	Medak	08.15	11.30	03.15		B/D Due to Pin Insulator failed	No
7		Lingaipally	Thanda	11KV	Medak	08.15	11.30	03.15		B/D Due to Pin Insulator failed	No
8		Ramthiridham	Narsing Rao Pally	11KV	Medak	08.15	11.30	03.15		B/D Due to Pin Insulator failed	No
9		Ramthiridham	Ramthiridham	11KV	Medak	08.15	11.30	03.15		B/D Due to Pin Insulator failed	No
10		Ramthiridham	Mallampet AGL	11KV	Medak	08.15	11.30	03.15		B/D Due to Pin Insulator failed	No
11		Suraram	Dharpally	11KV	Medak	04.00	09.30	05.30		B/D due to tree fallen on 11 KV wires	No
12		Narsapur	Avanchara	11KV	Medak	09.25	12.48	03.23		B/d due to jumper cut.	No
13		Narsapur	Kagazmaddur	11KV	Medak	00.00	11.00	11.00		B/d due to jumper cut.	No
14		Venkatraopet	Railapur	11KV	Medak	07.00	11.50	04.50		B/d due to jumper cut.	No
15		Seelampally	Seelampally	11KV	Medak	09.00	11.00	02.00		B/d due to jumper cut.	No
16		Kanchanpally	Kanchanpally	11KV	Medak	00.00	12.30	12.30		B/d due to jumper cut.	No
17		Kanchanpally	Lingampally	11KV	Medak	00.20	09.00	08.40		B/D due to disc failed	No
18		Amsanpally	Amsanpally	11KV	Medak	02.15	11.00	08.45		B/D due to disc failed	No
19		Amsanpally	Kongode	11KV	Medak	11.00	12.00	01.00		B/D due to disc failed	No
20		Podchanpally	Podchanpally-I	11KV	Medak	00.00	10.30	10.30		B/d due to disc failed & insulator burst	No
21		Podchanpally	Yellapur	11KV	Medak	10.46	12.25	01.39		B/d due to jumper cut.	No
22		Podchanpally	Podchanpally-II	11KV	Medak	14.10	16.20	02.10		B/d due to 25 KV dtr failed	No
23		Minpur	Minpur	11KV	Medak	00.00	07.15	07.15		B/d due to jumper cut.	No
24		Minpur	Kurthiwada	11KV	Medak	00.00	07.00	07.00		B/d due to Insulator failed	No
25		Minpur	Yousufpet	11KV	Medak	14.15	18.00	03.45		B/d due to jumper cut.	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
26		Gadipeddapur	Gadipeddapur	11KV	Medak	00.00	14.00	14.00		B/d due to transformer burnt	No
27		Gajwada	Shad nagar	11KV	Medak	00.00	09.25	09.25		B/D due to EL tripped	No
28		Burugupally	Burugupally	11KV	Medak	00.00	13.17	13.17		B/d due to 11 KV insulator failed	No
29		Burugupally	Yelupugonda	11KV	Medak	00.00	13.17	13.17		B/d due to 11 KV insulator failed	No
30		Chegunta	Reddypally	11KV	Medak	06.20	10.48	04.28		B/d due to insulater failed	No
31		Chegunta	Sheripally	11KV	Medak	08.00	14.00	06.00		B/d due to insulater failed	No
32		Narsapur	Narsapur	11KV	Siddipet	13.25	14.05	00.40		B/D due to Insulater Failed	No
33		Narmetta	Narmetta	11KV	Siddipet	01.25	06.40	05.15		B/D due to Insulater Failed	No
34		Narmetta	Thimaipally	11KV	Siddipet	09.15	11.25	02.10		B/D due to Disk Failure	No
35		Ankshapur	Khanpur	11KV	Siddipet	08.00	14.00	06.00		B/D due to Insulater Failed	No
36		Irkode	Indstiral	11KV	Siddipet	02.30	06.00	03.30		B/D due to Insulater Failed	No
37		Ponnal	Rangadampally	11KV	Siddipet	07.30	12.00	04.30		B/D due to Insulater Failed	No
38		Pullur	Pullur	11KV	Siddipet	08.00	12.00	04.00		B/D due to Insulater Failed	No
39		Gonepally	Gonepally	11KV	Siddipet	00.30	07.20	06.50		B/D due to Insulater Failed	No
40	Pedda Chepyala	Chapyal 2	11KV	Siddipet	06.00	11.00	05.00		B/D due to Disc Failure	No	
41	Kondapur	Govardangiri	11KV	Siddipet	03.00	06.00	03.00		B/D due to Insulator Failed	No	
1	RR N	Nizampet	Bandari Lay-Out	11KV	Kukatpally	00.30	03.00	02.30		11kv line Disc failed at Road no:10A Bandari lay-Out	No
2		D P Pally	Bowrampet	11KV	Jeedimetla	13.30	15.30	02.00		11kv Pin Insultor failed at mallanna Temple pochamapally	No
3		Bowrampet	Junnurm	11KV	Jeedimetla	11.28	13.15	01.47		11kv Pin Insultor failed at Junnrum Road	No
4		Ravalkole	IDA	11KV	Medchal	15.55	18.05	02.10		11KV Cable failed at Kashimbavi Thanda	No
5		Kandlakoya	Godrej	11KV	Medchal	19.20	22.30	03.10		11KV Pin Insulator failed at Asian Paints Company	No
6		Aliabad	Majeedpur	11KV	Medchal	21.40	22.40	01.00		11KV Disc failed at Aliabad X Road	No
7		Medicity	Munirabad	11KV	Medchal	00.05	02.10	02.05		Tree fallen on the 11KV Line at Pudur Village	No
8		Athiwelly	Padmaja	11KV	Medchal	00.00	05.10	05.10		11KV Pin Insulator failed at Diwam Function Hall	No
9		Medicity	IDA-I	11KV	Medchal	14.20	16.30	02.10		11KV Pin Insulator failed at Venkateshwara gutta,Munirabad	No
10		Kandlakoya	Godrej	11KV	Medchal	13.30	15.30	02.00		Tree Branch fallen on the 11KV Line at Godrej Main Road	No
11		Gowdavelly	Basaragadi	11KV	Medchal	13.20	15.40	02.20		11KV Pin Insulator failed at Basaragadi Village	No
12		Ravalkole	IDA	11KV	Medchal	19.35	20.18	00.43		11KV Disc Failed at Kasimbhai Thanda	No
13		Medchal	IDA Kandlakoya	11KV	Medchal	19.50	21.10	01.20		11KV Pin Insulator Failed Toll Gate,ORR	No
14		ICICI	Bharath Biotech	11KV	Medchal	00.00	04.20	04.20		No visible fault	No
15		ICICI	Adama	11KV	Medchal	05.00	13.55	08.55		11KV Pin Insulator failed	No
16		Uddamarry	Usharpally	11KV	Medchal	05.00	08.30	03.30		11KV Pin Insulator failed & Replaced at Athiwelly Cheruvu	No
17		Uddamarry	Keshavpur	11KV	Medchal	05.00	17.15	12.15		2 Nos 11KV Poles damaged at Keshavapur & backfeeding from 11KV Usharpally feeder	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	Mallpur 2	Narshima nagar	11KV	Habsiguda	03.40	05.17	01.37		11KV Disc failed at MS Biryani point	No
2		Moula-Ali	Gayatri Nagar	11KV	Sainikpuri	23.30	00.45	01.15		Tree fallen on 11KV line at Borabanda	No
3		Keesara	Bogaram	11KV	Habsiguda	14.05	17.50	03.45		Pin insulator failed at keesaradayara	No
4		Aushapur	Aushapur	11KV	Habsiguda	09.20	12.20	03.00		Pin insulator, disc failed & jumper cut at Aushapur	No
5		rampallydyara	rampallydyara	11KV	Habsiguda	06.55	08.33	01.38		11KV Pole damaged ar rampilly (v)	No
1	HYD N	Macha Bollaram	Chinthal Bazar	11KV	Bowenpally	15.40	16.42	01.02	EL,OL-Rph	Kite Stick fallen on lines at Bollaram Market	No
1	HYD S	Moosarambagh	Moosarambagh	11KV	Asmangadh	03.30	05.10	01.40	EL,OL-Rph	3Way RMU fault at Sravan Dental Hospital	No
2		Falaknuma	Chatrinaka	11KV	Charminar	4:00	6:25	2:25	EL	Cable fault	Arranged B/F on 11KV Lal Darwaza fdr & 11KV G.M.Chowni fdr
3		E.N.T.	C.B.I.	11KV	Begumbazar	4:40	6:10	1:30	EL	HT Jumper cut at ENT Hospital	No
4		Malakpet	Noorkhan Bazar	11KV	Asmangadh	9:30	10:35	1:05	OL-Rph	No Visible Fault	No
5		Chanchalguda	Madannapet	11KV	Asmangadh	10:55	12:25	1:30	EL,OL-Rph	DTR fault at Madannapet	No
6		Malakpet	Noorkhan Bazar	11KV	Asmangadh	11:25	12:50	1:25	EL	No Visible Fault	No
7		Malakpet	Noorkhan Bazar	11KV	Asmangadh	12.55	15.53	02.58	EL	Cable fault	Arranged B/F on 11KV M.M.H fdr & 11KV Bi Bi Ka Alwa fdr
1	HYD C	Golnaka	Tulasi Nagar	11KV	Azamabad	00.34	01.50	01.16	OL	Disc Insulator flash over at S.R.K. Apts	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		17		17		17			
6	RR(E)	38	360		5		5		5			
7	Hyd	186	1014		9		9		9			
	Total	504	2929	0	31	0	31	0	31	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		7		7		7			
2	NLG	150	948	2	9	2	9	2	9			
3	MDK	87	828	20	41	20	41	20	41			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	22	57	22	57	22	57	0	0	
	Grand Total	908	6149	22	88	22	88	22	88	0	0	