

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407	1	5	1	5	1	5			
6	RR(E)	38	360		4		4		4			
7	Hyd	186	1014		7		7		7			
	Total	504	2929	1	17	1	17	1	17	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	3	4	3	4	2	4	1		1 no.33kv still
2	NLG	150	948		6		6		6			
3	MDK	87	828	1	4		4		4			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	4	14	3	14	2	14	1	0	
	Grand Total	908	6149	5	31	4	31	3	31	1	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Narayanpet	33kv	Mahabubnagar	06.30	09.10	02.40	E/L&O/L	Breaker Limb Failed at Utkoor SS	Narayanpet	-
2		Kodangal	Peddanandagima	33kv	Mahabubnagar	22.00	00.00	02.00	E/L	Not Rectified Due to Rain	Peddanandagima	-
3		Balanagar	Navadurga	33kv	Jadcherla	21.35	23.55	02.20	E/L&O/L	Insulator Failure at Highway Road	Navadurga	-
1	MDK	Gajwel	Shivams	33kv	Siddipet	14.40	15.50	01.10		B/D due to Jumper cut near Fire station	Shivams	-
1	RR N	Medchal	Kompally	33kv	Medchal	22.15	22.45	00.30	BD	Tripped on ELIndication (Back Feeding From 33/11KV Subhash Nagar SS)	Kompally	-

TSSPDCL - LMRC / Corporate office

Date: 07.10.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kodur	Dharmapur	11kv	Mahabubnagar	06.50	12.15	05.25		11KV Tree fallen on conductor Near Kodur(V)	-
2		Machanpally	Pothanpally	11kv	Mahabubnagar	08.00	14.30	06.30		11KV Conductor cut Near Pothanpally (V)	-
3		Machanpally	Ramchandrapur	11kv	Mahabubnagar	11.15	14.10	02.55		11KV Insulator Damage Near Ramchadrapur (V)	-
4		Nawabpet	Lokirev	11kv	Jadcherla	10.00	14.00	04.00		11 KV Insulator Failure Near Nawabpet	-
1	NLG	Pamanagundla	Ismailpally	11kv	Nalgonda	09.50	12.20	02.30	E/L	11KV Jumper cut	-
2		Rayaniguda	A.D.Pally	11kv	Nalgonda	05.20	08.10	02.50	E/L	11KV Pin insulators failed	-
3		Penpahad	Annaram	11kv	Suryapet	08.00	11.50	03.50	EL	Disk failed	-
4		Ramannapet	Siripuram	11kv	Bhongiri	08.00	13.00	05.00	OL	11 KV Insulator failed	-
5		Repala	Repala	11kv	Huzurnagar	10.30	13.00	03.30	EL	single phase Transformer failed at Repala village	-
6		Dondapahad	Kakatiya	11kv	Huzurnagar	15.00	16.30	01.30	EL	11 kv inslater failed	-
1	MDK	Wadi	Kothapally	11kv	Medak	12.45	16.00	03.15		B/D due to Jumper cut	-
2		Dharipally	Achampet	11kv	Medak	03.00	13.45	10.45		B/D due to Insulator failed	-
3		Narsapur	Reddypally	11kv	Medak	04.00	05.40	01.40		B/D due to Jumper cut	-
4		Palvancha	Danoora	11kv	Medak	10.00	12.00	02.00		B/D due to Insulator failed	-
1	RR S	Manikonda	Laxminagar	11kv	IBGH	15.26	17.15	01.49	B/D	11KV Insulator failed at Amrutha hills	-
1	RR N	Madinaguda	Bk Enclave	11kv	Kukatpally	06.55	08.15	01.20	EL	11kv AB Cable Failure at Sai krishanagar	-
2		ChandaNagar	shankerNagar	11kv	Kukatpally	16.00	17.05	01.05	EL	11kv Pin Insultor failure at Dena Bank Chandanagar	-
3		Athiwelly	Dabeerpur	11kv	Medchal	13.00	14.18	01.18	BD	11KV Disc failed at Bible College, Dabeerpur Village	-
4		Laxmapur	MC Pally	11kv	Medchal	15.30	17.40	02.10	BD	11KV Pin Insulator failed at Ravinder reddy Thota	-
5		Uddamarry	Usharpally	11kv	Medchal	15.30	17.30	02.00	BD	11KV Disc failed at Mallanna Temple, Uddamarry	-
1	RR E	Moula-Ali	FBP	11kv	Sainikpuri	07.15	07.45	00.30	BD	11Kv jumper cut at ZTC Compound (AE/Moula-Ali)	-
2		Moula-Ali	Jawahar Nagar	11kv	Sainikpuri	19.50	20.40	00.50	BD	11Kv Pin Insulator failed at Near Venkatadri Appartment Jawahar Nagar (AE/Moula-Ali)	-
3		Moula-Ali	Spectra	11kv	Sainikpuri	19.55	20.30	00.35	BD	Ground petrolling done but no visible fault found (AE/Moula-Ali)	-
4		Nacharam indore	gouthami pips	11kv	Habsiguda	22.16	23.33	01.17	BD	Tripped on EL/OL DUE to insulator fail near substation	-
1	HYD S	Attapur	Kishan Bagh OH	11kv	Asmangadh	16.40	18.10	01.30	EL	No Visible fault	-----
2		Malakpet	Chaderghat	11kv	Charminar	21.22	23.07	01.45	EL	Breaker fault at SS	Arranged B/F on 11KV Komatiwadi fdr
3		Malakpet	Noorkhan Bazar	11kv	Charminar	21.22	23.23	02.01	EL	Breaker fault at SS	Arranged B/F on 11KV Komatiwadi fdr
4	HYD N	Zamistanpur	Sanjeevaiah Puram	11kv	Clocktower	20.37	22.40	02.03	EL,OL-Rph	Pin Insulator flash over at Vara Laxmi Appt	-----
5		Macha Bollaram	Reddy Enclave	11kv	Bowenpally	21.25	22.30	01.05	EL,OL-Rph	No Visible fault	-----
6		Bhudevi Nagar	Yadamma Nagar	11kv	Erragadda	21.45	00.25	02.40	EL	Disc Insulator flash over at Shiva Nagar	-----
7	HYD C	Narayanguda	Chikkad Pally	11kv	Azamabad	22.10	23.10	01.00	EL	O/G Yph, Jumper cut at SS	-----