

TSSPDCL - LMRC / Corporate office

Date: 12.10.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Kondapur	33KV	Mahabubnagar	05.30	07.15	01.45	E/L	Water Gridd Line AB Switch Opened at Gotoor Village	Marikal	-
2		Balanagar	G R Cable	33KV	Mahabubnagar	15.40	18.50	03.10	E/L	33KV Jumper Connecting Work at 132KV SS Balanagar	Balanagar	-
3		Nagarkurnool	Telkapally	33KV	Nagarkurnool	17.10	20.45	03.35	E/L	Telkapally Feeder Load Tag on to 33KV Rakonda Feeder Supply Stud Ok	Nagarkurnool	-
1	NLG	Marriguda	Chandur	33KV	Nalgonda	03.00	06.30	03.30	E/L	Tree Branch Fallen on 33 KV Line	Marriguda	-
1	RR N	Chintal	Jagadgirigutta	33KV	Medchal	09.36	12.00	02.24	BD	Y-phase lighting arrested failed in SS	Chintal	-

TSSPDCL - LMRC / Corporate office

Date: 12.10.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Bopparam	M Kothagudem	11KV	Suryapet	14.20	16.35	02.15	EL	Jumper cut	-
2		Voligonda	Sunkishala	11KV	Bhongiri	04.15	07.15	03.00	EL	11KV Insultro failed and DTR failure	-
3		Keethavarigudem	Kattakommu thanda	11KV	Huzurnagar	08.30	12.40	04.10	EL	11kv line cutted near Kattakommu thanda village	-
4		N.B.Gudem	Redlakunta	11KV	Huzurnagar	11.50	13.10	01.20	OL	Due to Tree branch fall on 11Kv line near Redlakunta village	-
5		Mamidala	Aregudem	11KV	Nalgonda	00.00	06.20	06.20	E/L	11 KV Insulator Failed Under SS-2	-
1	MDK	Raghavapur	Bachaipally	11KV	Siddipet	00.30	09.40	09.10		B/d due to 11KV Disk fail	-
2		Mallaram	Sikindlapur	11KV	Siddipet	00.10	07.20	07.10		B/d due to Insulator fail	-
1	RR S	Ibrahimbagh	Military-II	11KV	RJNR	10.40	11.40	01.00	B/D	11KV Cable failed at Pathima majid Royal Residency	-
1	RR N	Nizampet	Rajadhani School	11KV	Kukatpally	16.10	17.10	01.00	BD	11kv pin insultor Failed near 19 block nizampet	-
2		J D M Ss-III	Pipe Line	11KV	Jeedimetla	17.55	22.00	04.05	BD	11Kv 3Nos Poles Diamage Tree Fallen On The 11kv Line At Gappala Basti	-
3		J D M Ss-I	NiTco	11KV	Jeedimetla	17.55	23.55	06.00	BD	11kv Jumper Cut touched To Channel at vasuda company	-
4		J D M Ss-I	Meashawari	11KV	Jeedimetla	17.55	21.55	04.00	BD	Tree Fallen on the 11kv Line At Meashawari company	-
5		J D M Ss-I	Balaj	11KV	Jeedimetla	17.55	00.30	06.35	BD	Tree Fallen on the 11kv Line At Balaji company	-
6		J D M Ss-I	SubashaNagar	11KV	Jeedimetla	17.55	19.05	01.10	BD	Tree Fallen on the 11kv Line At NokaDa company	-
7		J D M Ss-I	Su-drugs	11KV	Jeedimetla	17.55	22.00	04.05	BD	Tree Fallen on the 11kv Line At Sai kanta	-
8		J D M Ss-I	J E T EL	11KV	Jeedimetla	17.55	22.40	04.45	BD	11kv AB switch Opened at sai kanta	-
9		J D M Ss-I	CS wire	11KV	Jeedimetla	17.55	23.55	06.00	BD	11kv Conductor snapped at post Company	-
10		J D M Ss-I	Phase-II	11KV	Jeedimetla	17.55	22.00	04.05	BD	Tree Fallen on the 11kv Line At Sai kanta	-
11		J D M Ss-IV	Vasuda	11KV	Jeedimetla	17.55	19.25	01.30	BD	Lv-I Ct Clamp Failed In Sub station	-
12		J D M Ss-IV	Axies	11KV	Jeedimetla	17.55	19.25	01.30	BD	Lv-I Ct Clamp Failed In Sub station	-
13		Gowdavelly	IDA	11KV	Medchal	11.50	14.00	02.10	BD	Tree fallen on the 11KV Line at Sitham College, Gyanapur Village	-

1	RR E	Malkajiri	MK Nagar	11KV	SAINIKPURI	18.32	19.45	01.13	EL/OL	Due to Heavy Rain, No Vsible fault found	-
2		ALUMASGUDA	THURUMLA NAGAR	11KV	CHAMPAPET	15.00	16.15	01.15	OL	11KV LINE PERLLING NO FALT	-
3		TARAMATHIPET	GOWRELLY	11KV	SAROORNAGA R	06.33	08.00	01.27	OL	BRID FALL ON 11KV LINE AT GOWRELLY	-
4		NADERGAL	GURAMGUDA	11KV	IBRAHIMPATNA M	14.15	15.08	00.53	EL	BRID FALL ON 11KV LINE AT ADARESH NAGAR	-
5		Rampally Dayara	Rampally Dayara	11KV	Keesara	13.48	14.30	00.42		Line patrolling but no visible fault	-
6		Pocharam	Jodimetla	11KV	Keesara	18.50	21.15	02.25		Tree branches fallen on 11KV line near Revathi Rice Mill	-
7		Ghatkesar	Ghatkesar	11KV	Keesara	19.20	22.10	02.50		11KV line cut near Brook Band School, Jumper cut near Fish Market, Jumper cut near Vasavi Towers, HT/LT line cut near Govt Hospitgal	-
1	HYD N	K.I.M.S	Krishna Nagar	11KV	Sec-Bad	18.25	19.57	01.32	EL	HT Jumper cut at Asha Apts	-----
2		I.I.C.T	Dall Mill	11KV	Sec-Bad	18.42	19.56	01.14	EL,OL-Bph	Tree branches fallen on lines at Vaishali Garden	-----
3		Marredpally	Addagutta	11KV	Sec-Bad	19.40	20.40	01.00	EL,OL-Yph	Tree branches fallen on lines at Konda Reddy Park	-----
4		Toli Chowki	Road No.86	11KV	Banjarahills	18.30	20.00	01.30	All Indication	Tree branches fallen on lines at Plot No.19	-----
5		Muffakamja College	Amrutha	11KV	Banjarahills	18.30	20.05	01.35	EL,OL-Bph	Tree branches fallen on lines at Road No.14	-----
6		Road No.13	Namdhari	11KV	Banjarahills	20.30	23.03	02.33	EL,OL	Jumper cut & tree branches fallen on lines at Road No.10	-----
7		Road No.13	Road No.1	11KV	Banjarahills	20.30	22.49	02.19	EL,OL	No Visible Fault	Partial fdr charged & remaining loads added on 11KV Rainbow fdr
1	HYD C	Jawahar Nagar	Anjaiah Bhavan	11KV	Saifabad	18.40	21.20	02.40	OL-Bph	Tree fallen on Lines at Chikkadpally	-
2		Bathkammakunta	Shivam	11KV	Azamabad	18.40	20.05	01.25	EL,OL-Bph	HT Line snapped near Shivam Temple	-
3		Vittalwadi	Y.M.C.A.	11KV	Azamabad	20.50	22.30	01.40	All Indication	3Nos Pin Insulators flash over at Y.M.C.A. X Road	-
4		I.T.I Mallepally	Anjuman	11KV	Mehdipatanam	00.44	02.10	01.26	EL,OL	I/C Cable fault	Arranged B/F on 11KV Zaheera Masjid feeder

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407	1	13	1	13	1	13			
6	RR(E)	38	360		7		7		7			
7	Hyd	186	1014		11		11		11			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>1</b>	<b>32</b>	<b>1</b>	<b>32</b>	<b>1</b>	<b>32</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	3		3		3				
2	NLG	150	948	1	5	1	5	1	5			
3	MDK	87	828		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>4</b>	<b>7</b>	<b>4</b>	<b>7</b>	<b>4</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>5</b>	<b>39</b>	<b>5</b>	<b>39</b>	<b>5</b>	<b>39</b>	<b>0</b>	<b>0</b>	