

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360									
7	Hyd	186	1014		3		3		3			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	6	2	5	2	5	2			1-33KV Still
2	NLG	150	948		12		12		12			
3	MDK	87	828	2		2		2				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>8</b>	<b>14</b>	<b>7</b>	<b>14</b>	<b>7</b>	<b>14</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>8</b>	<b>19</b>	<b>7</b>	<b>19</b>	<b>7</b>	<b>19</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 16.10.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Hanwada	33KV	Mahabubnagar	10.15	13.00	02.45	E/L	B Phase Breaker to CT Jumper Cut	Hanwada	Alternate Supply Arranged From nawabpet at 13:00hrs
2		220KV Palkonda	33KV Bhoothpur	33KV	Mahabubnagar	10.00	11.40	01.40	E/L	Insulator Damaged	33KV Bhoothpur	-
3		Kalwakurthy	Rachur	33KV	Jadcherla	01.40	07.35	05.55	E/L	Due to Heavy Rain & Jupally Jumpers Opened at Vasavi Colony at Kalwakurthy Supply OK	Rachur	-
4		Midjil	Madaram	33KV	Jadcherla	01.08	10.46	09.38	E/L	Insulator Damaged near Madaram SS	Madaram	-
5		Nagarkurnool	lthole	33KV	Nagarkurnool	01.56	10.04	08.08	E/L	Insulator Damaged at Atmatapur (V)	lthole	-
6		Ghanapur	Lattupally	33KV	Wanaparthi	23.18	00.00	00.42	E/L	Not Rectified	Lattupally	-
1	MDK	Bollaram	Bollaram -II	33KV	Sangareddy	09.55	12.05	02.10		B/D due to Jumper cut near 132kv Bollaram SS	Bollaram -II	-
2		Narayankhed	Sirgapur	33KV	Jogipet	01.00	11.45	10.45		B/d due to Insulator fail Ralamadugu Village.	Sirgapur	-

TSSPDCL - LMRC / Corporate office

Date: 16.10.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Boothpur	Amistapur	11KV	Jadcherla	08.30	12.30	04.00		11KV Jumper cut near Seripally	-
2		Midjil	Munnanur	11KV	Jadcherla	14.00	16.00	02.00		11KV Jumper cut near Munnanur	-
1	NLG	Penpahad	Town feeder	11KV	Suryapet	07.30	09.30	02.00	EL	Disk failed	-
2		B.Chandupatla	Chandupatla	11KV	Suryapet	11.30	15.10	03.40	EL	Line Cut	-
3		Kalmalcheruvu	Ganganagar	11KV	Huzurnagar	06.40	08.30	01.50	EL	Due to 11Kv jumper cutted near Ganganagar village	-
4		Raghunadapalem	Gundlapally	11KV	Huzurnagar	08.00	11.40	03.40	EL	Due to 11Kv Insulator failure Gundlapally village	-
5		Sirikonda	Balluthanda	11KV	Huzurnagar	10.00	14.00	04.00	EL/OL	Due to 11Kv line melted near Balluthanda village	-
6		Addaguduru	Ch.ramaram	11KV	Bhongir	04.00	09.00	05.00	EL	11KV Insulator failed at Ch.ramarm	-
7		B.Vellemla	Avuravani	11KV	Nalgonda	06.00	10.15	04.15	E/L	11 KC Insulator Failed	-
8		Kattangur	Bollepally	11KV	Nalgonda	06.00	09.20	03.20	E/L	11 KV Jumper Cut	-
9		Madgulapally	Kukkadam	11KV	Nalgonda	08.00	13.15	05.15	E/L	11 KV Line Disc Failed	-
10		Marrur	Marrur	11KV	Nalgonda	06.00	09.00	03.00	E/L	11 KV Line Insulator Failed	-
11		Panagundla	Pittampally	11KV	Nalgonda	06.38	09.50	03.12	E/L	11 KV Jumper Cut at SC Colony	-
12		SLBC	Darveshpuram	11KV	Nalgonda	00.00	06.00	06.00	E/L	1-Ph DTR Dailed	-
1	RR N	Devarayamjal	Mandaipally	11KV	Medchal	09.45	12.10	02.25	BD	11KV Disc failed & Replaced at Mandaipally Village	-
2		Shameerpet	Leomeridian	11KV	Medchal	06.15	08.15	02.00	BD	11KV Cable Failed at Revis Resorts, Upparapally Village	-
1	HYD S	Jiyaguda	Tappa Chabutra	11KV	IX	07.35	08.50	01.15	EL,OL	No Visible Fault	-
2		Miralam	Ansari Road	11KV	III	18.55	20.20	01.25	All Indication	snapped HT Line Idly Hotel, Ansari Road	-
1	HYD C	Vittalwadi	Y.M.C.A.	11KV	II	05.10	06.20	01.10	EL,OL-R&Bph	Jumper cut at Bhumanna Galli	-