

TSSPDCL - LMRC / Corporate office

Date: 18.10.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	leeza	Madelabanda	33KV	Gadwal	04.35	09.05	04.30	O/L	33Kv Line Phase to Phase near Madelabanda Taping	Madelabanda	No
1	MDK	Minpur	Minpur	33KV	Medak	5:50	9:50	4:00		B/D Due to Jumper Cut	Minpur	No
1	RR E	Malkaram	Kushiguda-I	33KV	Sainikpuri	13:25	15:10	1:45		Lighting Arrested failed at Kushiguda SS	Kushiguda-I	No

TSSPDCL - LMRC / Corporate office

Date: 18.10.17

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cheedella	Gajulamalkapuram	11KV	Suryapet	5:30	9:00	3:30	E/L	11Kv Line Conductor cut	No
1	MDK	Thogita	Kuchanpally	11KV	Medak	7:50	10:00	2:10		B/D Due to Conductor Snapped	No
2		Pedda Shnkarampet	Gotimukkula	11KV	Medak	09.45	12.45	03.00		B/D Due to Jumper Cut	No
1	RR N	Jeedimetla-III	Ramreddynagar	11KV	Jeedimetla	12:20	14:30	2:10	EL	T/F Brass Patti Cut at Phase-V	No
2		ICICI	Eugia Pharma	11KV	Medchal	10.22	13.08	02.46	BD	11KV Pole bend & Pin Insulator Replaced in SS	No
1	RR E	Ramanthapur	Gokhale nagar	11KV	Habsiguda	11:10	12:25	1:15		11KV Brass Patti cut at Pragathi Nagar	No
2		Yadgarpally	Yadgarpally	11KV	Keesara	05.45	07.00	01.15		No visible fault	No
1	HYD N	Addagutta	Hanuman Temple	11KV	Sec'bad	21.35	23.42	02.07	EL	RMU sparking near Govt. Polytechnic	Arranged B/F on 11KV Teacher's Colony for
1	HYD S	Attapur	Puranapool	11KV	Charminar	11.30	15.06	03.36	EL	Cable fault at Golden Park	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360	1	2	1	2	1	2			
7	Hyd	186	1014		2		2		2			
	Total	504	2929	1	6	1	6	1	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1		1				
2	NLG	150	948		1		1		1			
3	MDK	87	828	1	2	1	2	1	2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	3	2	3	2	3	0	0	
	Grand Total	908	6149	3	9	3	9	3	9	0	0	