

TSSPDCL - LMRC / Corporate office

Date: 20.10.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Peddakadmoor	Peddakadmoor	11KV	Mahabubnagar	07.40	11.00	03.20		11KV Jumper cut Near Kalwal (vi)	-
1	NLG	Eduloor	Parada	11KV	Nalgonda	03.00	06.40	03.40	E/L	Jumper cut	-
2		Alair	CH.Kandukur	11KV	Bhongiri	03.00	06.00	03.00	E/L	11 KV Line Snapped	-
1	RR N	Gowdavelly	IDA	11KV	Medchal	12.45	14.30	01.45		11KV Conductor Snapped and Disc Failed at near by SS	-
2		J D M SS-I	N I T CO-	11KV	Jeedimetla	09.15	10.20	01.05	EL	11kv Jumper Cut In Sub station	-
1	RR E	Keesara	Anki Reddy Pally	11KV	Keesara	07.45	09.45	02.00		HT/LT line cut at Anki Reddy Pally	-
2		Pocharam	Jodimetla	11KV	Keesara	11.00	12.07	01.07		11KV Copper patti cut near Narayana College	-
1	HYD C	Fever Hospital	Kachiguda Railway Station	11KV	Azamabad	13.45	15.20	01.35	EL	Cable fault near SS	Arranged B/F on 11KV B.B.D feeder

TSSPDCL - LMRC / Corporate office

Date: 20.10.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Pebbair	33kv	Wanaparthi	03.10	03.45	00.35	E/L	Out Going Breker Open Line Stand	Pebbair	-
2		Wanaparthi	Peddmandaddi	33kv	Wanaparthi	09.56	10.30	00.34	O/L	Alternate Supply Arraged to 33KV Veltloor Feeder supply Stud Ok	Peddmandaddi	-

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2	1	2	1	2	1			
2	NLG	150	948		2		2		2			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	3	2	3	2	3	0	0	
	Grand Total	908	6149	2	8	2	8	2	8	0	0	