

TSSPDCL - LMRC / Corporate office

Date: 21.10.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Sh.Gowraram	Kondaram	11KV	Nalgonda	07.40	11.35	03.55	E/L	11KV Line Jumper Cut	-
2		Athmakur (S)	T. Penpahad	11KV	Suryapat	05.20	07.40	02.20	E/L	11KV Jumper Cut	-
3		Ramannapet	Dubbaka	11KV	Choutuppal	10.30	14.30	04.00	E/L	11KV Insulator failed at Dubbaka (V)	-
1	RR N	Madinaguda	J P N nagar	11KV	Kukatpally	16.28	17.25	00.57	EL	11kv AB cable Cut At jpn nagar { Arrange to Back Fedding supply Reddy Colony Feeder}	-
2		J D M SS-I	Su-Drugs	11KV	Jeedimetla	05.30	06.48	01.18	EL	11kv Endy Kit Failure At Phase-I	-
1	RR E	Keesara	Anki Reddy Pally	11KV	Keesara	07.45	09.45	02.00		HT/LT line cut at Anki Reddy Pally	-
2		Pocharam	Jodimetla	11KV	Keesara	11.00	12.07	01.07		11KV Copper patti cut near Narayana College	-

TSSPDCL - LMRC / Corporate office

Date: 21.10.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Krishna	33KV	Mahabubnagar	02.20	08.20	06.00	EL	Tree Branch follen on the lien and removed at Reddam (vi)	Krishna	-
1	RR N	132KV Malkaram	33KV Ratnalayam	33KV	Medchal	18.18	21.00	02.42	BD	33KV Cable failed at Bits Campus (Alternate supply arranged)	33KV Ratnalayam	-
2		IDPL	Vijayanagar	33KV	Kukatpally	00.50	08.10	07.20	BD	33kv Cable damaged by digging work of HMR	Vijayanagar	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407	2	2	2	2	2	2			
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014									
	Total	504	2929	2	4	2	4	2	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1		1				
2	NLG	150	948		3		3		3			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	3	1	3	1	3	0	0	
	Grand Total	908	6149	3	7	3	7	3	7	0	0	