

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		4		4		4			
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014		9		9		9			
	Total	504	2929	0	16	0	16	0	16	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		5		5		5			
3	MDK	87	828		4		4		4			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	9	0	9	0	9	0	0	
	Grand Total	908	6149	0	25	0	25	0	25	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.10.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Sh.Gowraram	Gurajala	11KV	Nalgonda	06.30	09.00	02.30	E/L	11KV Line Jumper Cut	-
2		Aipoor	Mukkududevlapally	11KV	Suryapet	07.50	09.00	01.10	E/L	11KV Line Jumper Cut	-
3		Ponugodu	Ponugodu	11KV	Huzurnagar	08.50	12.20	03.30	E/L	Due to 11Kv line cutted near Ponugodu village	-
4		Dirsincherla	Dirsincherla	11KV	Huzurnagar	14.00	15.30	01.30	E/L	Due to 11Kv jumper cutted near Dirsincherla village	-
5		Timmareddy gudem	Ganapavaram	11KV	Huzurnagar	15.00	17.00	02.00	E/L	Due to 11Kv line cutted near Ganapavaram village	-
1	MDK	Yenigandla	Yenigandla	11KV	Medak	14.00	15.30	01.30		B/D Due to Jumper Cut	-
2		Yenigandla	Y. Mandapur	11KV	Medak	14.00	15.30	01.30		B/D Due to Jumper Cut	-
3		Rangampet	Rangampet	11KV	Medak	11.45	11.50	00.05		B/D Due to Conductor Snapped	-
4		Achannapally	Achannapally	11KV	Medak	11.45	13.25	01.40		B/D Due to Insulator failure	-
1	RR S	Kismathpur	LV Prasad	11KV	RJNR	03.20	04.15	00.55	B/D	Tree branches fallen on 11KV Line at Sana function hall	-
1	RR N	Sumashila	R P Colony	11KV	KKP	05.40	09.20	03.40	BD	11kv line PinInsulater Failure at Deenabandu Colony	-
2		Madinaguda	Pragathi Eclave	11KV	KKP	16.26	17.26	01.00	BD	11kv line Disk failure at Thirumala Narsing Home, Miyapur	-
3		Jeedimetla-II	Kompally Forma {SRC Naik nagar }	11KV	JDM	20.18	21.18	01.00	BD	11kv line Endy Kit Failure at opp:Komally Forma , phase-III	-
4		DPPally-II	Indo-Fab	11KV	JDM	11.30	12.30	01.00	BD	Tree Fallon the 11kv line at Dppally	-
1	RR E	Keesara	Anki Reddy Pally	11KV	Keesara	07.45	09.45	02.00		HT/LT line cut at Anki Reddy Pally	-
2		Pocharam	Jodimetla	11KV	Keesara	11.00	12.07	01.07		11KV Copper patti cut near Narayana College	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Nehru Nagar	Contonement	11KV	V	17.24	18.50	01.26	EL,OL-Rph	Pin Insulator flash over at Tejaswini Arcade	-
2		Clock Tower	Anjali	11KV	V	17.34	18.53	01.19	EL,OL-Rph	Faulty 11KV Old Jail Khana fdr loads	-
3		Seethaphal Mandi	Namala Gundu	11KV	V	17.30	19.00	01.30	EL,OL	Cable End Kit failed at Venkateshwara Temple	-
4		Seethaphal Mandi	Gandhi Statue	11KV	V	17.30	19.15	01.45	EL,OL-Rph	Tree branches fallen on lines at Rama Talkies	-
1	HYD S	Santosh Nagar	Moin Bagh	11KV	III	07.30	09.34	02.04	EL,OL	Cable fault	Arranged B/F on 11KV Patel Nagar feeder
2		Asmangadh	P&T Colony	11KV	VIII	17.55	19.25	01.30	EL,OL-Rph	Tree branches fallen on lines at Sharada Nagar & Jumper cut at Community Hall	18:22 Hrs partial fdr charged
3		Falaknuma	Vattepally	11KV	III	20.15	22.35	02.20	EL	I/C Cable fault (5Nos DTR's kept Off)	Arranged B/F on 11KV Falaknuma UG Cable fdr
4		Falaknuma	Jangammet AB Cable	11KV	III	23.45	01.50	02.05	EL	3Nos HG fuses B/O & HT Jumper touching to neutral at Shamsheergunj	-
1	HYD C	Bathkammakunta	Saibaba Temple	11KV	II	23.40	01.05	01.25	EL	Disc Insulator flash over at Sai Rama Towers	-