

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 48 | 158 | | | | | | | | | |
| 2 | NLG | 18 | 406 | | | | | | | | | |
| 3 | MDK | 92 | 383 | | | | | | | | | |
| 4 | RR(S) | 40 | 201 | | | | | | | | | |
| 5 | RR(N) | 82 | 407 | | 3 | | 3 | | 3 | | | |
| 6 | RR(E) | 38 | 360 | | | | | | | | | |
| 7 | Hyd | 186 | 1014 | | 2 | | 2 | | 2 | | | |
| | Total | 504 | 2929 | 0 | 5 | 0 | 5 | 0 | 5 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 110 | 969 | 2 | | 2 | | 2 | | | | |
| 2 | NLG | 150 | 948 | | 5 | | 5 | | 5 | | | |
| 3 | MDK | 87 | 828 | | | | | | | | | |
| 4 | RR(S) | 31 | 338 | | | | | | | | | |
| 5 | RR(N) | 8 | 48 | | | | | | | | | |
| 6 | RR(E) | 18 | 89 | | | | | | | | | |
| | Total | 404 | 3220 | 2 | 5 | 2 | 5 | 2 | 5 | 0 | 0 | |
| | Grand Total | 908 | 6149 | 2 | 10 | 2 | 10 | 2 | 10 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 25.10.2017

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---|
| 1 | MBNR | Marikal | Devarkadra | 33KV | Mahabubnagar | 09.35 | 11.05 | 01.30 | E/L&O/L | Pin insulator replaced near CC Kunta | Devarkadra | Alternate Supply Arranged to 33KV Koukuntla Feeder at 9:45Hrs |
| 2 | | Wanaparthi | Narsaipally | 33KV | Wanaparthi | 12.20 | 13.25 | 01.05 | E/L | for AB Switch Open at Pangal SS Line Patrolling No Visible Fault | Narsaipally | Alternate Supply Arranged to 33KV Pangal SS at 13:05Hrs |

TSSPDCL - LMRC / Corporate office

Date: 25.10.2017

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|------------------------------------|
| 1 | NLG | Mellacheruvu | Madaram | 11KV | Huzurnagar | 08.20 | 10.20 | 02.00 | E/L | Insulator failure | - |
| 2 | | Ananthagiri | Shanthi nagar | 11KV | Huzurnagar | 08.40 | 09.40 | 01.00 | E/L | Insulator failure | - |
| 3 | | Kodur | Loyapally | 11KV | Suryapet | 04.45 | 06.55 | 02.10 | E/L | Jumper cut | - |
| 4 | | Addagudur | CH.Ramaram | 11KV | Bhongiri | 03.00 | 06.45 | 03.45 | E/L | Insulator failure | - |
| 5 | | Addagudur | Addagudur | 11KV | Bhongiri | 03.45 | 07.00 | 03.15 | E/L | Jumper cut | - |
| 1 | RR N | Nizampet | Bandri-Lay Out | 11KV | Kukatpally | 06.50 | 08.10 | 01.20 | EL&OL | NET Cable Fallen on the 11kv Line Near Road No2,3 Bandrilayout | - |
| 2 | | Kompally | Kompally | 11KV | Medchal | 02.10 | 03.00 | 00.50 | BD | 11KV Cable failed at Kompally Grama Panchayati | - |
| 3 | | Kandlakoya | Kandlakoya | 11KV | Medchal | 11.15 | 11.55 | 00.40 | BD | Tree Branch fallen on the 11KV Line at VK Agro Company, Suthariguda | - |
| 1 | HYD C | Industrial Area | V.S.T. (Dedicated) | 11KV | II | 03.40 | 22.20 | 18.40 | EL,OL-Rph | Cable End failed near SS | ----- |
| 2 | | Industrial Area | Mother Dairy | 11KV | II | 14.20 | 16.13 | 01.53 | EL | Cable fault | Arranged B/F on 11KV L.N.Nagar fdr |