

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407									
6	RR(E)	38	360									
7	Hyd	186	1014		2		2		2			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		5		5		5			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 27.10.17

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Tekumatla	Rayani Gudem	11KV	Suryapet	08.20	10.44	02.24	E/L	11KV Jumper cut	No
2		Chervupally	Dacharam	11KV	Nalgonda	06.30	10.30	04.00	E/L	11KV Jumper cut	No
3		Thimmannaguda	Thimmannaguda	11KV	Nalgonda	07.30	11.40	04.10	E/L	11KV Insulator failed	No
4		Ch.Annaram	Kothagudem	11KV	Nalgonda	08.00	11.00	03.00	E/L	11KV Insulator failed	No
5		Raghunathpur	Challuru Indus	11KV	Bhongir	05.00	09.00	04.00	E/L	DTR failed near Challuru	No
1	RR S	NIRD	Aravalli	11KV	Rajendranagar	8:45	11:10	2:25		Lizard fallen in RMU Breaker at Sports complex	No
1	HYD N	M.L.A Colony	Kalinga	11KV	Jublee Hills	11.35	12.50	01.15	All Indi	AB Cable fault at Kalinga Function Hall	Partial loads arranged B/F on 11KV Kanaka Durga feeder
1	HYD S	Attapur	N.M.Guda UG	11KV	Charminar	04.55	07.00	02.05	EL,OL	7No. Jumpers cut at Golden Plaza	No

