

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360		5		5		5			
7	Hyd	186	1014									
	Total	504	2929	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948		3		3		3			
3	MDK	87	828		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	6	0	6	0	6	0	0	
	Grand Total	908	6149	0	14	0	14	0	14	0	0	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Polkampally	11KV	Jadcherla	10.00	14.00	04.00		11KV Wire cut near Thimmapur	No
1	NLG	Athmakur (S)	T Penpahad	11KV	Suryapet	07.45	09.20	01.35	E/L	11Kv Jumper cut	No
2		Kalmalchervu	Kalmalchervu	11KV	Huzurnagar	06.02	08.10	02.08	E/L	Bird fallen on AB Switch near village	No
3		Narsingbatla	Chennugudem	11KV	Nalgonda	08.50	11.30	02.40	E/L	11KV Insulator failed	No
1	MDK	Wadi	Kothapally	11KV	Medak	15:30	18:00	2:30		Insulater failed	No
2		Bujarampet	Bujarampet	11KV	Medak	10.24	14.30	04.06		11KV Jumper cut.	No
1	RR N	Jeedimetla-II	NRSA	11KV	Jeedimetla	8:30	10:10	1:40	EI&OL	11KV Line AB cable end kit failed	No
2		Uddamarry	Usharpally	11KV	Madchal	08.35	10.20	01.45	BD	CT failed in SS	No
3		Medchal	Navadurga	11KV	Madchal	11.20	12.29	01.09	BD	11KV Pin Insulator failed	No
1	RR E	RR Court	Haripuri Colony	11KV	Sarooranagar	16:14	18:00	1:46		T/F Problem at Haripuri colony Road no-1	No
2		Yadgarpally	Cheryala	11KV	Keesara	13.20	14.40	01.20		11KV Line cut at Cheryala V Kaman	No
3		Aushapur	Maharam agl	11KV	Keesara	06.30	12.00	05.30		Insulator failed	No
4		cherlapally	Rampally	11KV	Keesara	04.00	04.50	00.50		No visible fault	No
5		Taramathipet	Gourelli	11KV	Sarooranagar	8:44	10:07	1:23		No visible fault	No

