

TSSPDCL - LMRC / Corporate office

Date: 01.09.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Minpur	Minpur	33KV	Medak	15.45	18.00	02.15		B/D due to Conductor snapped & Insulator failed		-

TSSPDCL - LMRC / Corporate office

Date: 01.09.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nuthankal	Chilpakuntla	11KV	Suryapet	15.30	17.20	01.50	E/L	Jumper cut	-
2		Palakeedu	Bothalapalem	11KV	Huzurnagar	11.20	14.10	02.50	EL	11kv line Snapped near Bothalapalem village	-
3		Keethavarigudem	Kothagudem	11KV	Huzurnagar	05.00	08.00	03.00	EL	11kv Jumper cutted near Kothagudem village	-
1	MDK	Cheryal	Kalivemula	11KV	Sangareddy	08.25	10.15	01.50		B/D Due to 11KV Jumper cut	-
2		Narmetta	Thimmaipally	11KV	Siddipet	11.55	16.40	04.45		B/D Due to 11 Kv Jumper cut location at Narmetta village Ramula temple	-
3		Dharmajipet	Dharmajipet	11KV	Siddipet	13.20	16.55	03.35		B/D Due to Insulater failed	-
4		Podichanpally	Yellapur	11KV	Medak	08.30	11.00	02.30		B/D Due to Tree Branches fallen on 11KV line	-
1	RR S	CBIT	Gandipet	11KV	RJNR	17.11	18.19	01.08		11KV line snapped at DGP Anurag sharma farm house	-
1	RR N	Guntur Vikas	Volvo	11KV	Kukatpally	14.30	15.20	00.50	BD	AB Switch Jumper cut near Volvo	-
2		Suraram	Venkatramnagar	11KV	JDM	09.18	10.22	01.04	BD	Line Petroling No Visble Falt	-
3		Chinthal	Ganesh nagar	11KV	Medchal	00.50	02.20	01.30	BD	11KV UG Cable End kit failed at Ganesh Nagar (Backfeeding Arranged from 11KV Padma Nagar Feeder)	-
4		Shameerpet	Shameerpet	11KV	Medchal	07.20	08.20	01.00	BD	Bird fallen on the 11KV Line at Ramalayam Temple, Bommarajpet	-
1	RR E	Peerzadiguda	Chenna Reddy Thota	11KV	Keesara	11.25	12.36	01.11		11KV Insulator failed at Boduppal Kaman	-
1	HYD S	Panjasha	Metherwadi	11KV	Charminar	20.45	22.07	01.22	EL	Cable fault	11KV Chatrinaka & 11KV Patel Nagar

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		4		4		4			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		3		3		3			
3	MDK	87	828	1	4	1	4	1	4			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	7	1	7	1	7	0	0	
	Grand Total	908	6149	1	14	1	14	1	14	0	0	