

TSSPDCL - LMRC / Corporate office

Date: 03.09.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Maganoor	Advi Satyaram	11KV	Mahabubnagar	15.00	17.00	02.00		11KV Phase to Phase at Oblapur (Vi)	-
2		Krishna	Tangidi	11KV	Mahabubnagar	12.00	14.00	02.00		11KV Jumper cut at Tangidi (vi)	-
1	NLG	Penpahad	Macharam	11KV	Suryapet	09.20	12.30	03.10	E/L	11Kv Jumper Cut	-
2		Urlugonda	Karkayalagudem	11KV	Huzurnagar	16.00	17.30	01.30	E/L	11kv jumper cut near Karkayalagudem (v)	-
1	MDK	Rajgopal pet	Rajgopal pet	11KV	SIDDIPET	03.30	08.15	04.45		B/d due to Jumper Cut	-
2		Irkode	Irkode	11KV	SIDDIPET	00.00	08.22	08.22		B/D due to Insulator Failed	-
3		Irkode	Chinna Gundavelly	11KV	SIDDIPET	07.57	09.20	01.23		B/d due to Jumper Cut	-
4		Jinnaram	Kodakanchi	11KV	Sangareddy	17.15	18.15	01.00		B/D due to Insulate Failed	-
1	HYD C	Toli Chowki	Hakeemsha	11KV	VII	03.49	05.10	01.21	All Indication	Cable fault	Partial fdr B/F arranged on 11KV Paramount Hills feeder
1	HYD N	Madhapur	Ven-En-Burg	11KV	X	08.55	10.30	01.35	EL,OL-Rph	HT Line snapped at Opp. Raheja	-----
2		Bowenpally	Ferozguda	11KV	VI	09.10	10.30	01.20	EL	Pole damaged at Ferozguda	Arranged B/F on 11KV Bala Nagar feeder
1	HYD S	Petlaburz	Murali Nagar	11KV	III	11.05	12.30	01.25	OL-Bph	Cable fault (4No. DTR's kept off)	Arranged B/F on 11KV Hussaini Alam feeder
2		Miralam	Ranjan Colony	11KV	III	12.10	13.30	01.20	EL	Twisted lines at Macca Hospital	-----
3		Attapur	Shareef Nagar	11KV	III	20.00	21.30	01.30	EL	Conductor snapped at Iqbal DTR	(2No DTR kept off)

TSSPDCL - LMRC / Corporate office

Date: 03.09.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Chegunta	Deccar	33KV	Toopran	09.40	14.30	04.50		B/D due to Insulator failed	Deccar	-
2		Narayankhed	Sirgapur	33KV	Jogipet	18.10	00.00	05.50		B/D due to Disc failed	Sirgapur	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360									
7	Hyd	186	1014		6		6		6			
	Total	504	2929	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		2		2		2			
2	NLG	150	948		2		2		2			
3	MDK	87	828	2	4	2	4	2	4			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	8	2	8	2	8	0	0	
	Grand Total	908	6149	2	14	2	14	2	14	0	0	