

TSSPDCL - LMRC / Corporate office

Date: 08.09.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kondapur	Hanmanpally	11KV	Mahabubnagar	04.40	08.00	03.20		11KV Conductor cut at Cherlapally (Vi)	-
2		Doultabad	Gokalfaswada	11KV	Mahabubnagar	10.00	11.30	01.30		11KV Tree fallen on conductor at GF wada (Vi)	-
3		Gangapur	Gangapur	11KV	Jadcherla	13.45	17.45	04.00		11 KV Insulator Failure Near Gollapally (Vi).	-
4		K.V.Pet	Town	11KV	Jadcherla	16.00	17.34	01.34		Tree Fallen on the 11 K V Line Near K V pet .	-
1	NLG	Gundepuri	Gundepuri	11KV	Suryapet	13.20	15.40	02.20	E/L	11Kv Insulator failed	-
2		Pamanagundla	Pittampally	11KV	Nalgonda	06.40	09.30	02.50	E/L	11 KV Jumper Cut at SS-4	-
3		Kethepally	Gudiwada	11KV	Nalgonda	07.45	09.35	01.50	E/L	11 KV Line Insulator Failure SS-21	-
4		Marror	Marror	11KV	Nalgonda	10.30	12.30	02.00	E/L	11 KV Line Insulator Failure SS-36	-
5		Marriguda	Y.G.Pally	11KV	Devarakonda	08.00	11.00	03.00	E/L	11Kv Jumper cut	-
6		Repala	Repala	11KV	Huzurnagar	01.00	05.00	04.00	E/L	Post of Insulator failure near Repale village	-
7		Chilukur	Bethovolu 02	11KV	Huzurnagar	04.10	07.10	03.00	E/L	11Kv insulator Failure near Bethovolu 02 (v)	-
1	MDK	Rajpally	Balnagar	11KV	Medak	04.00	08.00	04.00		Jumper cut	-
2		Shankarampet	Cherlapally	11KV	Medak	03.05	09.36	06.31		conductor snapped	-
3		Burugupally	Yelepugunda	11KV	Medak	01.00	10.30	09.30		insulator failed & jumper cut	-
4		Nangunoor	Nagrajally	11KV	Siddipet	06.00	11.00	05.00		conductor snapped	-
5		Nartmetta	Thimmaipally	11KV	Siddipet	02.00	08.00	06.00		conductor snapped	-
6		Nartmetta	Nartmetta	11KV	Siddipet	02.00	08.00	06.00		Jumper cut	-
7		Chowdaram	Yellamazalla	11KV	Siddipet	00.00	11.30	11.30		insulator & jumper cut	-
8		Mirdoddy	Mirdoddy	11KV	Siddipet	08.30	09.30	01.00		Disc failure	-
9		Gambirpur	Gambirpur	11KV	Siddipet	12.00	13.00	01.00		Jumper cut	-
10		Cheriyal	Cheriyal	11KV	Sangareddy	10.30	10.50	00.20		conductor snapped	-
11		Cheriyal	Derbowend	11KV	Sangareddy	09.20	10.25	01.05		insulator failed & jumper cut	-
12		Ismaikhanpet	Erdhanur	11KV	Sangareddy	08.10	11.45	03.35		insulator failed & jumper cut	-
13		Cheriyal	Kandi	11KV	Sangareddy	09.25	10.25	01.00		Jumper cut	-
14		Isnapur	Mutthangi	11KV	Sangareddy	01.10	11.55	10.45		AB switch problem	-
15		Isnapur	Kyathram	11KV	Sangareddy	09.01	10.30	01.29		AB switch problem	-
16		Paty	Paty	11KV	Sangareddy	04.35	12.35	08.00		11kv wire cut	-
1	RR N	Chinthal	Dwaraka nagar	11kv	Medchal	04.15	04.55	00.40	BD	11KV UG Cable Failed (backfeeding arranged from 11KV Chintal feeder from HMT SS)	-
2		Devarayamjal	Mandaipally	11kv	Medchal	01.10	02.20	01.10	BD	25KVA T/F Failed at sakali basthi,Pothaipally	-
3		Kandlakoya	Goderj	11kv	Medchal	06.15	07.50	01.35	BD	Tree Fallen on 11KV Line at Bommala Bavi,Pocham pally	-
1	RR E	Rampally Dayara	Vanneguda	11kv	Keesara	11.14	12.25	01.11		11KV Jumper cut at SS Yard	-
1	HYD N	H.A.L	H.A.L Town Ship	11kv	Bowenpally	03.35	05.05	01.30	All Indication	No Visible Fault	-

TSSPDCL - LMRC / Corporate office

Date: 08.09.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Nandine	33KV	Gadwal	14.35	16.55	02.20	E/L	Flash over disc failed at Dharoor	Nandine	-
2		Nagarkurnool	lthole	33KV	Nagarkurnool	16.37	18.08	01.31	E/L	33KV insulator failed near Indrakal Village	lthole	-
1	MDK	Tukkapur	Tukkapur	33KV	Siddipet	07.45	11.50	04.05		Conductor snapped	Tukkapur	-
2		Pashamylaram	Nandigama	33KV	Sangareddy	18.05	22.30	04.25		33KV insulator failed	Nandigama	-

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2	4	2	4	2	4			
2	NLG	150	948		7		7		7			
3	MDK	87	828	2	16	2	16	2	16			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	4	27	4	27	4	27	0	0	
	Grand Total	908	6149	4	32	4	32	4	32	0	0	