

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthly	Revally	33KV	Wanaparthly	21.30	24.00	02.30	O/L	Under Breakdown	Wanaparthly	-
1	MDK	Ramayampet	Laxmapur	33KV	Toopran	14.25	17.35	03.10		B/D due to After petroling no fault at found	Ramayampet	-
2		Medak	Ramayampet	33KV	Medak	17.25	21.45	04.20		B/D due to Jumper cut	Medak	-

TSSPDCL - LMRC / Corporate office

Date: 09.09.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gangapur	Gangapur	11KV	Jadcherla	11.10	15.20	04.10		HT/LT Near Nekkonda Village	-
1	NLG	N.Annaram	Dosapahad	11KV	Suryapet	09.30	12.00	02.30	E/L	Insulator failed	-
2		Keshrajupally	Keshrajupally AGL	11KV	Nalgonda	06.40	10.20	03.40	E/L	11KV jumper cut at nearby village	-
3		Thimmannaguda	Narsimhapuram	11KV	Nalgonda	08.30	11.40	03.10	E/L	11KV line cut at SS-2	-
4		Kodad	Komarabanda	11KV	Huzurnagar	07.00	10.00	03.00	E/L	11 kv snapped At komarabanda(v)	-
1	MDK	Kondamrajpally	Khata	11KV	Siddipet	08.40	10.40	02.00		B/D DUE TO AB Switch problem	-
2		Pullur	Pullur	11KV	Siddipet	08.00	10.00	02.00		B/D DUE TO Tree branche fall on the 11 Kv line	-
3		Thogita	Thogita	11KV	Medak	13.16	14.55	01.39		B/D DUE TO JUMPER CUT	-
4		Rangampet	Rangampet	11KV	Medak	06.30	09.30	03.00		B/D DUE TO 11KVA LINE CUT	-
5		Rangampet	Rangampet	11KV	Medak	06.35	07.45	01.10		B/D DUE TO JUMPER CUT	-
6		Cheryal	Turbo	11KV	Sangareddy	00.00	08.30	08.30		B/D DUE TO INSULTER FAILED	-
1	RR N	Suraram	Matrix	11KV	Jeedimetla	08.25	11.02	02.37	BD	11KV AB Cable Failure At Phase-4	-
1	RR E	TARAMATHIPET	BANDARAVIRALA	11KV	SAROORNAGAR	02.30	03.56	01.26	EL	TREE BRACHANS FALL ON 11KV LINE AT SADDUPALLY	-
1	HYD S	Malakpet	Noorkhan Bazar	ST	VIII	03.15	06.20	03.05	OL-Rph	Cable fault at Noor Café	Arranged B/F on 11KV Bibi Ka Alawafdr
2		Attapur	Puranaphool	ST	III	11.30	13.05	01.35	EL	Cable fault at Bahadurpura	Arranged B/F on 11KV Bahadurpura OH feeder
3		Asmangadh	Saibaba	ST	VIII	15.55	17.35	01.40	EL	Cut Jumper at JC Brothers, twisted lines at Andhra Bank	-----
4		Yakuthpura	Murtuza Nagar	ST	VIII	17.06	18.43	01.37	EL	Cable fault at Alusalam Function Hall	Arranged B/F on 11KV Sadath Nagar & Bhavani Nagar fdrs
5		Malakpet	Chaderghat	ST	VIII	22.40	00.45	02.05	EL,OL-R&Bph	No Visible fault	23:10 partial fdr charged (D/F line AB switch opened at Babumiya Doddi 5No DTR's Kept off)
1	HYD C	Amberpet	C.P.L	CEN	II	08.05	09.30	01.25	EL	Bird fault on lines at CPL Quarters	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		6		6		6			
	Total	504	2929	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	1	1	1	1	1			
2	NLG	150	948		4		4		4			
3	MDK	87	828	2	6	2	6	2	6			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	11	3	11	3	11	0	0	
	Grand Total	908	6149	3	19	3	19	3	19	0	0	