

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360									
7	Hyd	186	1014		3		3		3			
	Total	504	2929	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1		1				
2	NLG	150	948									
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	0	1	0	1	0	0	0	
	Grand Total	908	6149	1	6	1	6	1	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.09.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Revally	33KV	Wanaparthi	21.50	06.40	08.50	O/L	Alternative Supply Arranged from 33KV SS Peddakothapally 132KV SS Nagarkurnool at 06:40Hrs	Revally	Break Down Alternative Supply Arranged from 33KV SS Peddakothapally 132KV SS Nagarkurnool at 06:40Hrs

TSSPDCL - LMRC / Corporate office

Date: 10.09.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Suraram	Matrix	11KV	Jeedimetla	08.25	11.02	02.37	EL	11KV AB Cable Failure At Phase-4	-
2		Devarayamjal	Kottapet	11KV	Medchal	18.40	19.30	00.50	EL	Tree Fallen on 11KV Line at Ashok Poultry Farm,Devarayamjal	-
3		Ravalkole	IDA	11KV	Medchal	03.20	04.15	00.55	EL	11KV Jumper opened at Snehaform	-
1	HYD N	Prashasan Nagar	Nandagiri Hills	11KV	X	17.50	18.57	01.07	EL	AB Cable fault at Road No.78	-
1	HYD S	Asmangadh	Saibaba	11KV	VIII	02.50	06.29	03.39	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Tirumala Hills feeder
2		Gosha Mahal	M.J Market	11KV	IX	05.52	07.23	01.31	All Indication	Cable fault	Arranged B/F on 11KV Osmangunj fdr