

TSSPDCL - LMRC / Corporate office

Date: 13.09.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Jogipet	Dakur	33KV	Jogipet	9:40	12:55	3:15		Tree branch fallen on the line	Dakur	No
1	RR S	Upparpally-II	Parmareddy hills	33KV	RJNR	3:00	4:20	1:20		Tree branches fallen on the 11KV line at reliance Petrol pump	Parmareddy hills	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	K.V.Pet	Bandamedipally	11KV	Jadcherla	14.35	17.42	03.07		11KV Wire cut near Shankaraiah pally (V)	No
1	NLG	Rajapet	Renikunta	11KV	Bhongir	10:00	14:00	4:00	EL	11KV Line snapped At Begampet	No
2		Kolanupaka	Somaram	11KV	Bhongir	14.35	16.20	01.45	EL	Tree Branches fallen on the line	No
3		Keethavarigudem	Kothagudem	11KV	Huzurnagar	03.10	08.00	04.50	EL	Jumper cut near Kothagudem village	No
4		Mattampally	Allipuram	11KV	Huzurnagar	08.20	10.30	02.10	EL	11KV line cut near Allipuram village	No
1	MDK	Nangunoor	Nagarajpally	11KV	Siddipet	15:10	17:00	1:50		Disc failed	No
2		Mirdoddy	Mirdoddy	11KV	Siddipet	06.00	08.00	02.00		11KV Jumper cut	No
1	RR N	Madinaguda	H M T	11KV	KKP	15:10	17:50	2:40	BD	Tree fallen on the 11KV Line & 11KV Pin Insulator failure Near Laxmi Apt H M T	No
2		Mayuri nagar	Prashanthnagar	11KV	KKP	18.45	20.05	01.20	BD	11KV Jumper cut	No
3		KPHB	BhagyNagar	11KV	KKP	18.00	18.50	00.50	BD	Tree branches fallen on the 11KV Line Kameshawari tower Bhagynagar	No
4		Jeedimetla SS III	Pipeline Road	11KV	JDM	17.55	18.55	01.00	BD	Tree fallen on the 11KV line near Lasma Power Company at Pipeline	No
5		Jeedimetla SS II	Apurupa Colony	11KV	JDM	17.53	20.30	02.37	BD	11KV Pin insulator failed opp Goyal Timbers	No
6		Dulapally	Steelcity	11KV	Medchal	18.13	19.48	01.35	BD	11KV Pin insulator failed at Bhavani Industry	No
7		Subash Nagar	Suchitra	11KV	Medchal	18.40	19.40	01.00	BD	11KV Pin insulator failed at Teja Wines	No
8		Kandlakoya	Godrej	11KV	Medchal	18.15	19.00	00.45	BD	Tree fallen on the 11KV Line Rajadhani Rice Company	No
9		Nuthankal	Oystar	11KV	Medchal	18.40	20.40	02.00	BD	11KV Pin insulator failed at Oystar	No
10		Kandlakoya	Saigeetha Asramam	11KV	Medchal	17.50	21.35	03.45	BD	Tree fallen on the 11KV Line at Prestige Park	No
11		Aliabad	HBL	11KV	Medchal	18:55	21:20	2:25	BD	11KV Jumper cut & Replacement HBL Company Road	No

1	RR E	Yapral	Pradamapuri	11KV	Sainikpuri	17:10	18:00	0:50		Tree branches fallen on 11KV line at Chandrapuri Colony	No
2		Vinayak Nagar	Old Safilguda	11KV	Sainikpuri	16.45	17.30	00.45		Tree fallen on 11Kv line at East Chandragiri Colony	No
3		Anadbagh	Balaram Nagar	11KV	Sainikpuri	16.16	19.36	03.20		11KV Disc failed at Hanuman Temple	No
4		Anadbagh	VK Nagar	11KV	Sainikpuri	16.18	18.25	02.07		Tree fallen on LT line on LT Pole Dammege at NDH Colony Nava Barathi High School	No
5		Anadbagh	BS Nagar	11KV	Sainikpuri	16.36	19.05	02.29		11KV Pin Insulator failed	No
6		VP Nagar	Officers Colony	11KV	Sainikpuri	16.30	18.05	01.35		Tree branches fallen on 11KV line at Sainatha Puram	No
7		VP Nagar	Deendayal Nagar	11KV	Sainikpuri	16.55	18.10	01.15		Tree branches fallen on 11KV line at Githa Nagar	No
8		Kushaiguda	AS Rao Nagar	11KV	Sainikpuri	20.30	21.15	00.45		No visible fault	No
9		Moula-Ali	Mirzalaguda	11KV	Sainikpuri	16.30	22.50	06.20		Tree fallen on 11Kv line at Petrol Pump JTC Main Road	No
10		Moula-Ali	Gayatry Nagar	11KV	Sainikpuri	19.45	21.30	01.45		11KV Pin Insuletor failure at SP Nagar	No
11		Moula-Ali	Meerpet	11KV	Sainikpuri	16.30	20.05	03.35		Tree fallen on 11Kv line at Thirumala Nagar	No
12		Moula-Ali	Moulali	11KV	Sainikpuri	16.30	20.10	03.40		Tree fallen on 11kv line at JTC Main Road	No
13		Moula-Ali	Kailasagiri	11KV	Sainikpuri	16.30	20.00	03.30		Tree fallen on 11kv line at Indira Nagar due to Heavy Rain	No
14		Moula-Ali	FBP	11KV	Sainikpuri	16.30	21.14	04.44		Ground Petroling done but no Visible fault found	No
15		Yadgaripally	Thimmiapally	11KV	Habsiguda	17.40	23.30	05.50		11KV Insulator failed at Graveyard	No
16		Abdullapermet	Abdullapermet	11KV	Saroor Nagar	09.50	12.30	02.40		11KV Jumper cut	No
17		Taramathipet	Bandaravirala	11KV	Saroor Nagar	16:50	19:05	2:15		11KV Line cut	No
1	HYD N	Chilkaiguda	New Boiguda	11KV	Sec'bad	21.20	00.20	03.00	EL	AB Cable fault at Boiguda	2no DTR kept off
2		Gymkhana	Vayu Sena	11KV	Sec'bad	20:35	23:55	3:20	EL,OL	Breaker I/C top Jumper cut at SS	Arranged B/f on 11KV Pared Ground feeder
3		Gymkhana	Pared Ground	11KV	Sec'bad	21:37	23:10	1:33	EL	Tree fallen on lines at Tovoli	No
4		Gunrock	Gymkhana	11KV	Sec'bad	23:02	0:25	1:23	OL-Bph	Tree branches fallen on lines at AWHO Sector-A	No
5		Gunrock	Bowenpally	11KV	Sec'bad	22.42	01.05	02.23	EL	Tree branches fallen on lines at LIC Colony	No
1	HYD C	Fever Hospital	BKP Bus Depot	11KV	Azamabad	18.05	20.10	02.05	EL	Tree branches fallen on lines at Barkathpura	No

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201	1		1		1				
5	RR(N)	82	407		11		11		11			
6	RR(E)	38	360		17		17		17			
7	Hyd	186	1014		6		6		6			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>1</b>	<b>34</b>	<b>1</b>	<b>34</b>	<b>1</b>	<b>34</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948		4		4		4			
3	MDK	87	828	1	2	1	2	1	2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>2</b>	<b>41</b>	<b>2</b>	<b>41</b>	<b>2</b>	<b>41</b>	<b>0</b>	<b>0</b>	