

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Krishna	33KV	Mahabubnagar	03.30	07.55	04.25	E/L	Due to Bat Fallen on the Line	Makthal	-
2		Maddur	Damargidda	33KV	Mahabubnagar	09.20	11.55	02.35	E/L	LA Failed near at Kyathanpally SS	Maddur	-
1	NLG	Kolanpaka	Rajapet	33KV	Bhongir	06.00	09.20	03.20	EL	33KV Insulator Failed Near Pamukunta	Kolanpaka	-
1	MDK	Kandhi	BDL	33KV	Sangareddy	02.40	05.00	02.20		B/D due to heavy rain	Kandhi	-
2		Kandhi	HFC-II	33KV	Sangareddy	03.00	07.30	04.30		B/D due to Tree baranch fallen on line	Kandhi	-
3		Gummadidala	Dundigal	33KV	Patancheru	03.05	08.10	05.05		B/D due to Tree baranch fallen on line	Gummadidala	-
4		Gummadidala	GPSS-2	33KV	Patancheru	03.05	09.45	06.40		B/D due to Jumper cut & heavy rain.	Gummadidala	-
5		Jogipet	Laxmi sagar	33KV	Jogipet	02.30	08.25	05.55		B/D due to pin insulator failed	Jogipet	-
6		Zaheerabad	Mungi	33KV	Zaheerabad	02.45	10.30	07.45		B/D due to pin insulator failed.	Zaheerabad	-
7		Pashamailaram	Suven life science	33KV	Sangareddy	08.35	10.35	02.00		B/D due to Consumer Cable probleam falt was isolated line work charged.	Pashamailaram	-
8		Sadashivapet	Koheer	33KV	Sangareddy	10.35	11.15	00.40		Altrenate supply given Jharasagam Feeder to koheer Feeder	Sadashivapet	-
9		Narsapur	Reddypally	33KV	Medak	23:10 (13.09.2017)	08.05	08.55		B/D due to Tree baranch fallen on line & PVC pipe fallen on line	Narsapur	-
10		Minpur	Minpur	33KV	Medak	04.50	10.55	06.05		B/D due to jumper cut	Minpur	-
11		Gajwel	Pregnapur	33KV	Siddipet	02.55	14.00	11.05		Altrenate supply given Ganeshpally Feeder to Pregnapur Feeder	Gajwel	-
1	RR N	132KV Chintal	33KV Subash Nagar	33KV	Medchal	03.27	05.13	01.46	BD	33KV Jumper cut in SS	132KV Chintal	-

1	RR S	RJNR	Ibrahimbagh	11KV	Military-II	05.34	06.35	01.01	B/D	Tree branches Fallen on 11kv Line at fatima masjid	-
2		IBGH	Ibrahimbagh	11KV	Military-I	04.30	08.40	04.10	B/D	11KV Insulator failed at Pashacolony, Tree branches fallen at Nekhnapur	-
3		IBGH	CBIT	11KV	Gandipet	03.10	05.50	02.40	B/D	11KV Insulator failed at Srinagar Due to Rain	-
4		IBGH	Manikonda	11KV	Doller hills	10.05	11.06	01.01	B/D	11kv Disc Failed at Shivaji nagar	-
1	RR N	H M T Hills	Sri Ram Nagar	11KV	KKp	03.30	04.30	01.00	EL	Due Heavy Rain	-
2		Mayuri nagar	Prashanthnagar	11KV	KKp	03.15	05.55	02.40	EL	11kv Pin insulator Failure At Raghava reddy Funcation Hall	-
3		Chandanagar	Sri Ram Nagar	11KV	KKp	03.15	04.20	01.05	EL	Due Heavy Rain	-
4		Huda Truck Park	Sri Sai Nagar	11KV	KKp	03.00	06.30	03.30	EL	11kv Pin insulator Failure at Dayarguda	-
5		G Vikas	Aparana	11KV	KKp	04.10	06.10	02.00	EL	11kv Disk Failure at Aparana	-
6		Nizampet	Nizampet	11KV	KKp	04.40	06.10	01.30	EL	11kv Pin insulator Failure at Nizampet	-
7		Madina guda	C B R Estate	11KV	KKp	03.00	07.30	04.30	EL	11kv Disk Failure at Shanthinagar	-
8		Aleap	Dr Colony	11KV	JDM	05.50	06.50	01.00	EL	Tree FallenOn the 11kv Line At Pragathi Nagar	-
9		J d M Ss-II	Uttam Biscut	11KV	JDM	04.00	05.20	01.20	EL	Due Heavy Rain	-
10		J d M Ss-II	S R C naik nagar	11KV	JDM	04.00	05.20	01.20	EL	Due Heavy Rain	-
11		Aleap	Punchvati	11KV	JDM	05.30	09.30	04.00	EL	Tree FallenOn the 11kv Line At Pt 20 Punchavati colony	-
12		J d M Ss-IV	tagore	11KV	JDM	06.34	09.40	03.06	EL/OL	Tree fallen on the 11kv Line at Ethro Godown	-
13		J d M Ss-II	N R S A	11KV	JDM	06.43	10.05	03.22	EL/OL	Tree Branches fallen on The 11kv Line At M S R India L T D Phase -4	-
14		Chinthal	Bhagath Singh Nagar	11KV	Medchal	03.20	07.30	04.10	BD	11KV Disc failed at Bhagath singh nagar	-
15		Dulapally	Karthika vanam	11KV	Medchal	03.35	06.25	02.50	BD	11KV Pin Insulator failed at Dulapally Village	-
16		Subash Nagar	Ramaraj Nagar	11KV	Medchal	05.30	06.30	01.00	BD	Tree fallen on the 11KV Line at Ramaraj Nagar	-
17		Chinthal	Chinthal	11KV	Medchal	03.20	07.20	04.00	BD	11KV Post of Insulator failed at chintal	-
18		HMT	Gandhi Nagar	11KV	Medchal	06.55	10.30	03.35	BD	Incoming AB Switch female failed in SS, Backfeeding arranged from 11KV Bhagathsingh Nagar	-
19		Boerwampet	Bowrampet Vil	11KV	JDM	04.07	09.21	05.14	EL/OL	11kv Pin Insulator Failure at Industrial tower	-
20		Keshavaram	Keshavaram	11KV	Medchal	04.40	09.00	04.20	BD	11KV Disc failed at Potharam Chowrasta	-
21		Gowdavelly	Basaragadi	11KV	Medchal	05.00	08.50	03.50	BD	11KV Pin Insulator failed at MLR College	-
22		GP Pally	GP Pally	11KV	Medchal	05.10	07.10	02.00	BD	Tree fallen on the 11KV Line at Ayodhya X road	-
23		Medchal	Rural Kandlakoya	11KV	Medchal	04.00	08.50	04.50	BD	Tree fallen on the 11KV Line at Celkon Company and Line Cut at Adarsh Chemical Company	-
24		Athiwelly	Somaram	11KV	Medchal	04.35	08.25	03.50	BD	11KV Pin Insulator failed at Bharath Petrol Pump	-
25		Athiwelly	PHI	11KV	Medchal	04.30	09.50	05.20	BD	Backfeeding arranged from 11KV IDA Feeder from Yellampet SS	-
1		Vinayak Nagar	Tank Bund	11KV	Sainikpuri	04.00	06.15	02.15		Tree branches fallen on 11Kv line at Sharda nagar near little flower school (FOC Venkat Reddy)	-
2		Sainikpuri	Sainikpuri	11KV	Sainikpuri	03.31	06.01	02.30		Tree branches fallen on 11Kv line at Sainikpuri (AE)	-
3		Sainikpuri	Eshwarpuri	11KV	Sainikpuri	04.15	06.19	02.04		Tree branches fallen on 11Kv line at Madhapuri Colony (AE)	-
4		Sainikpuri	Ramalyam	11KV	Sainikpuri	04.53	06.46	01.53		Tree branches fallen on 11Kv line at Defence Colony (AE)	-
5		Sainikpuri	Kalyan Garden	11KV	Sainikpuri	05.22	06.54	01.32		Tree branches fallen on 11Kv line at Kandiguda (AE)	-
6		Sainikpuri	Vijaypuri	11KV	Sainikpuri	06.23	08.03	01.40		Tree branches fallen on 11Kv line at Vijaypuri (AE)	-
7		Kushaiguda	Kushaiguda	11KV	Sainikpuri	05.45	06.45	01.00		Tree branches fallen on 11Kv line at Dhanpal Reddy Venture (L.Insp Anil)	-

8	RR E	Cherelapally-I	Phase-I	11KV	Sainikpuri	02.45	07.40	04.55		Tree fallen on 11KV line HG fuse and jumper cut at TET India Spak Conductor Bhagya Laxmi (LM Prabhakar)	-	
9		Yapral	Tulasi Garden	11KV	Sainikpuri	06.40	08.40	02.00		Tre branches fallen on 11Kv and 11Kv pole broken at Krishnaveni DTR (FOC Koti)	-	
10		RGK	RGK	11KV	Sainikpuri	05.40	08.55	03.15		11KV Disk Failed at Sri Chaitanaya School (LM Rajendar)	-	
11		Moula Ali	Kailasgiri	11KV	Sainikpuri	03.30	07.48	04.18		Ground Patrolling done but no fault found (AE)	-	
12		NGRI	Kalyanipuri	11KV	Habsiguda	06.00	07.00	01.00		Tree fallen on 11KV Line at Survey Of India	-	
13		NGRI	Habsiguda	11KV	Habsiguda	04.00	10.50	06.50		11KV AB Switch Insulator failed due to heavy rain near st.no.08 at Habsiguda	-	
14		Ramanthapur	Gokhale Nagar	11KV	Habsiguda	02.20	03.30	01.10		Tree fallen on 11KV Line at Sharada Nagar	-	
15		Ramanthapur	Dooradarshan	11KV	Habsiguda	06.20	07.50	01.30		Tree fallen on 11KV Line at Dooradarshan	-	
16		Maruthi nagar	astalaxmi	11KV	saroomnagar	05.00	06.47	01.47	OL	11kv insulater fail at vasavicolony	-	
17		Maruthi nagar	alkapuri	11KV	saroomnagar	06.10	07.40	01.30	EL	tree brachans fall on 11kv line at alkapuri rd no 5	-	
18		Bandlaguda	gsi	11KV	saroomnagar	05.30	13.55	08.25	OL	trees brachans fall on 11kv line at gsi company	-	
19		Hayath nagar	Raghavendra Colony	11KV	saroomnagar	02.55	03.55	01.00	EL	2no s 11kv insulater fail at raghavendra colony rd no 3	-	
20		Auto nagar	Lb nagar	11KV	saroomnagar	20.40	21.50	01.10	EL/OL	11kv insulater fail at pragathi nagar	-	
21		Ghatkesar	HPCL	11KV	Keesara	07.00	08.50	01.50		Tree fallen on 11KV Line at HPCL Company	-	
22		Keesara	Anki Reddy Pally	11KV	Keesara	22.30	11.04	12.34		11KV Pin Insulator failed near Ganga Bhavani Ricemill at Keesara	-	
23		Singapur	RGK	11KV	Keesara	05.20	06.40	01.20		11KV AB Switch Insulator failed near RGK Block No.86	-	
24		Saketh	Dammaiguda	11KV	Keesara	03.00	06.20	03.20		11KV Insulator failed at Dammaiguda Main Road	-	
25		Nagaram	Bandlaguda	11KV	Keesara	03.00	07.00	04.00		11KV Insulator failed near VRR Construction at Bandlaguda	-	
26		Nadergal	botek	11KV	Ibrahimpattanam	10.30	12.25	01.55	OL	11kv disk fail at botek company	-	
1		HYD N	Kundanbagh	Brahmanwadi	11KV	Erragadda	04.40	06.05	01.25	W/O Indication	No Visible Fault	Arranged B/F on 11KV H.P.S feeder
2			I.D.P.L	Bharath Nagar	11KV	Erragadda	11.20	12.25	01.05	EL,OL-Rph	No Visible Fault	Loads taken from 33KV Janapriya SS
3			K.I.M.S	Mani Anjaiah	11KV	Sec-Bad	03.22	07.00	03.38	EL,OL-Rph	Jumper cut & touching to Channel at Mani Anjaiah Building	-
4			Gymkhana	Pared Ground	11KV	Sec-Bad	03.58	06.25	02.27	EL	Faulty loads of 11KV Vayusen fdr	-
5			K.I.M.S	Krishna Nagar	11KV	Sec-Bad	04.15	07.20	03.05	EL,OL-Rph	Tree branches fallen on lines at Krishna Nagar	-
6			Sanjeevaiah Park	Police Lines	11KV	Sec-Bad	04.55	08.10	03.15	EL,OL-Rph	Jumper cut at Chandra Nagar	-
7			Clock Tower	Rly.Reservation	11KV	Sec-Bad	05.15	07.05	01.50	EL	No Visible Fault	-
8	Gymkhana		Vasavi Nagar	11KV	Sec-Bad	05.15	07.20	02.05	EL	No Visible Fault	-	
9	K.I.M.S		S.P.Road	11KV	Sec-Bad	06.25	07.45	01.20	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV Natraj fdr	
10	Seethaphal Mandi		Gandhi Statue	11KV	Sec-Bad	09.55	11.05	01.10	EL,OL-Rph	Pin Insulator flash over at Ganesh DTR	-	
11	Vasanthapuri		Siripuri Colony	11KV	Sec-Bad	21.15	23.15	02.00	EL	Disc Insulator flash over at Chandra Babu Nagar Colony DTR	-	
12	Bowenpally		Sancharapuri Colony	11KV	Bowenpally	03.00	04.15	01.15	EL,OL-R&Bph	No Visible Fault	-	
13	Bowenpally		Plassy Line	11KV	Bowenpally	03.10	04.10	01.00	EL,OL-R&Bph	No Visible Fault	-	
14	Bowenpally		B.B.R Hospital	11KV	Bowenpally	03.20	04.50	01.30	EL,OL-Rph	No Visible Fault	-	
15	Bowenpally		I.A.F	11KV	Bowenpally	03.40	04.55	01.15	EL	No Visible Fault	-	
16	Bowenpally		Pension Line	11KV	Bowenpally	03.45	04.50	01.05	EL	No Visible Fault	-	
17	Hakimpet		Bollaram P.S	11KV	Bowenpally	04.10	05.20	01.10	EL	Tree branches fallen on lines at Bollaram	-	
18	Tirumalgiri		Chinna Kamela	11KV	Bowenpally	06.50	07.50	01.00	EL,OL-Rph	Tree branches fallen on lines at BSNL Colony	-	
19	I.D.P.L		Sakshi	11KV	Bowenpally	10.50	12.00	01.10	All Indication	Disc Insulator flash over at Sun City	-	

20		Macha Bollaram	Ayyappa Nagar	11KV	Bowenpally	06.00	07.05	01.05	EL,OL-Rph	No Visible Fault	-
21		Muffakamja College	Times of India	11KV	Banjarahills	02.17	07.56	05.39	EL,OL	Tree branches fallen, UG Cable fault & Insulator flash over at College Road	-
22		Prashasan Nagar	D.N.R Hills	11KV	Banjarahills	03.08	04.30	01.22	OL-R&Bph	No Visible Fault	-
23		Toli Chowki	Hanuman Temple	11KV	Banjarahills	03.15	04.20	01.05	EL	No Visible Fault	-
24		Prashasan Nagar	Ashwini Heights	11KV	Banjarahills	03.15	06.44	03.29	EL,OL-Rph	Pin Insulator flash over at Plot No.45	-
25		N.I.M.S	Panjagutta	11KV	Banjarahills	03.55	05.30	01.35	EL	Tree branches fallen on lines at Lazee Hospital	-
26		M.L.A Colony	Cancer Hospital	11KV	Banjarahills	03.45	05.00	01.15	All Indication	No Visible Fault	-
27		Road No.2	Lumbini Mall	11KV	Banjarahills	04.25	07.00	02.35	EL	Tree fallen on lines & CT PT fault at Umesh Co.Op	-
28		M.L.A Colony	Shopping Complex	11KV	Banjarahills	05.45	08.15	02.30	EL	HG fuse & Jumper cut at D.Srinivas House	Arranged B/F on 11KV Cineghar fdr
29		Road No.2	Shabdalaya	11KV	Banjarahills	04.15	07.03	02.48	EL	Cable fault	Arranged B/F on 11KV Amurtha fdr
1	HYD S	C.R.P.F	Baba Nagar	11KV	Charminar	03.06	06.00	02.54	EL	Pin Insulator flash over at H.B.Nagar	-
2		Attapur	N.M.Guda OH	11KV	Charminar	03.20	04.40	01.20	EL,OL-Rph	HG fuse blown off at N.M.Guda	-
3		Petlaburz	Petlaburz	11KV	Charminar	19.10	20.52	01.42	OL-Bph	Cable fault at MLA Pasha Quadri Residence	-
4		Salarjung	Sadath Nagar	11KV	Asmangadh	03.50	06.00	02.10	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV Murtuza Ngr fdr
5		Moosarambagh	Sripuram Colony	11KV	Asmangadh	04.20	05.45	01.25	EL	No Visible Fault	-
6		Santosh Nagar	Bhavani Nagar	11KV	Asmangadh	04.35	06.20	01.45	Master Relay	AB Cable fault at Bibi Bazar	-
7		Gunj	Judges Colony	11KV	Asmangadh	18.40	20.10	01.30	OL-Rph	Road Crossing Cable End Kit failed at Sohail Hotel	-
8		E.N.T	Jambagh	11KV	BegumBazar	06.10	08.05	01.55	EL	AB Switch sparking at Jambagh	-
1	HYD C	Indira Park	Datta Nagar	11KV	Saifabad	01.15	02.34	01.19	EL	Pin Insulator flash over at Street No.8, Kabab Hotel	-
2		Indira Park	Gagan Mahal	11KV	Saifabad	01.15	02.50	01.35	EL	Pin Insulator flash over at Lower Tankbund	-
3		Lumbini Park	A.P.Tourism	11KV	Saifabad	05.01	06.05	01.04	EL	No Visible Fault	Arranged B/F on 11KV T.T.D feeder
4		Erramanzil	Padmavathi Nagar	11KV	Saifabad	05.00	06.25	01.25	EL	Pin Insulator flash over at Padmavathi Nagar	-
5		Jawahar Nagar	Anjaiah Bhavan	11KV	Saifabad	07.26	08.42	01.16	EL	No Visible Fault	-
6		Malakpet	Prabath	11KV	Azamabad	03.10	04.29	01.19	EL,OL-Yph	No Visible Fault	-
7		Chilkaiguda	Parsigutta	11KV	Azamabad	03.25	06.30	03.05	EL,OL-Rph	Tree branches fallen on lines at Kaladi Nagar	-
8		Zamistanpur	L.N.Nagar	11KV	Azamabad	03.45	09.25	05.40	OL-Rph	Tree branches fallen on lines at Amber Nagar Katta	-
9		Industrial Area	Vidya Nagar	11KV	Azamabad	03.30	09.15	05.45	EL	No Visible Fault	-
10		Fever Hospital	Nalla Kunta	11KV	Azamabad	03.25	06.40	03.15	EL,OL-Rph	Tree branches fallen on lines at Nallakunta	-
11		Fever Hospital	Fever Hospital	11KV	Azamabad	03.38	05.30	01.52	EL	No Visible Fault	-
12		Amberpet	Golnaka	11KV	Azamabad	05.00	07.30	02.30	EL,OL	Tree branches fallen on lines at Thirumala Hotel	-
13		Industrial Area	Shankarmutt	11KV	Azamabad	05.40	08.50	03.10	EL	No Visible Fault	-
14		Bathkammakunta	D.D.Colony	11KV	Azamabad	06.00	07.30	01.30	EL	Tree branches fallen on lines at D.D.Colony	-
15	Asif Nagar	Military	11KV	Mehdipatanam	03.12	10.55	07.43	EL,OL-Rph	Tree fallen on lines at Military Area	-	
16	S.D.Hospital	Humayun Nagar	11KV	Mehdipatanam	03.15	07.32	04.17	EL,OL-Rph	Pin Insulator flash over at Mytri Jr.College	-	
17	Asif Nagar	Jyothi Colony	11KV	Mehdipatanam	03.12	06.51	03.39	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV Military Hospital fdr	
18	A.S.R.Raju Nagar	A.S.R.Raju Nagar	11KV	Mehdipatanam	03.35	04.50	01.15	EL,OL-Rph	No Visible Fault	-	
19	Toli Chowki	Paramount Hills	11KV	Mehdipatanam	04.40	08.50	04.10	EL	Insulator flash over at Baba Hotel	-	
20	Toli Chowki	B.S.N.L	11KV	Mehdipatanam	05.15	09.30	04.15	EL,OL	AB Switch sparking at P.M.Colony	-	
21	S.D.Hospital	Police Mess	11KV	Mehdipatanam	06.34	08.23	01.49	EL	No Visible Fault	Arranged B/F on 11KV Ahmed Ngr OH feeder	
22	Golconda	Darga Cable	11KV	Mehdipatanam	08.40	10.15	01.35	EL,OL-Bph	No Visible Fault	-	

23	Asif Nagar	N.S.F Colony	11KV	Mehdipatanam	08.45	10.10	01.25	EL	Pin Insulator flash over at M.D.Lines	-
----	------------	--------------	------	--------------	-------	-------	-------	----	---------------------------------------	---

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		4		4		4			
5	RR(N)	82	407	1	25	1	25	1	25			
6	RR(E)	38	360		26		26		26			
7	Hyd	186	1014		60		60		60			
	Total	504	2929	1	115	1	115	1	115	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2	2	2	2	2	2			
2	NLG	150	948	1	7	1	7	1	7			
3	MDK	87	828	11	19	11	19	11	19			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	14	28	14	28	14	28	0	0	
	Grand Total	908	6149	15	143	15	143	15	143	0	0	