

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407	1	9	1	9	1	9			
6	RR(E)	38	360	1	5	1	5	1	5			
7	Hyd	186	1014		3		3		3			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>2</b>	<b>17</b>	<b>2</b>	<b>17</b>	<b>2</b>	<b>17</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948		11		11		11			
3	MDK	87	828	2	6	2	6	2	6			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>2</b>	<b>18</b>	<b>2</b>	<b>18</b>	<b>2</b>	<b>18</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>4</b>	<b>35</b>	<b>4</b>	<b>35</b>	<b>4</b>	<b>35</b>	<b>0</b>	<b>0</b>	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Singoor	Muddaipet	33kv	Sangareddy	01.00	08.30	07.30		B/D Due to Jumper Cut and Disc Failure	Muddaipet	-
2		Jogipet	Laxmi sagar	33kv	Sangareddy	01.00	08.15	07.15		B/D Due to Insulator Failure	Laxmi sagar	-
1	RR N	132KV Medchal	33KV Athiwelly	33kv	Medchal	11.30	13.41	02.11	BD	Tree Brach fallen on the 33KV line at CMR College	33KV Athiwelly	-
1	RR E	Ghanapur	Cherlapally	33kv	Sainikpuri	00.50	10.45	09.55		NBFC Issued to AE/OP/Cherlapally Line petroling done but No Visble Fault	Cherlapally	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kalwakurthy	Kurmidda	11kv	Jadcherla	15.00	16.30	01.30		DTR Failed At NGKL Road.	-
1	NLG	Penpahad	Singireddy Palem	11kv	Suryapet	06.50	09.30	02.40	E/L	11Kv Jumper cut	-
2		Jublakpally	Jublakpally	11kv	Bhongir	01.00	05.00	04.00	E/L	11KV Jumper Snapped & Bird Fallen On Line	-
3		Addaguduru	Ch.ramaram	11kv	Bhongir	02.00	05.00	03.00	E/L	11Kv Insultor failed SS-5	-
4		Gurraladadni	Jampally	11kv	Bhongir	08.40	11.40	03.00	E/L	11Kv Insultor failed near Rice mill Jampally	-
5		Ramannapet	Kommaigudem	11kv	Choutuppal	02.00	06.00	04.00	E/L	Tree Fallen On Line & 11Kv Insulator failed	-
6		Mushampally	Mushampally	11kv	Nalgonda	10.00	11.30	01.30	E/L	11Kv Jumper Cut and insulator failed	-
7		Edulur	Kurumarthi	11kv	Nalgonda	09.00	11.00	02.00	E/L	11 KV Disk failure	-
8		Kethepally	Korlapahad	11kv	Nalgonda	09.35	12.00	02.25	E/L	11KV line milting	-
9		Kethepally	Kasanagode	11kv	Nalgonda	06.30	08.00	01.30	E/L	11Kv Jumper Cut	-
10		Thimmapuram	Kallepally	11kv	Miryalguda	02.00	06.00	04.00	E/L	11Kv pin insulator failed	-
11		Repala	Repala	11kv	Huzurnagar	06.00	09.00	03.00	E/L	11 KV Line snapped at Repala (v)	-
1	MDK	Burugupally	Yelupugonda	11kv	Medak	19.45	09.05	13.20		B/D Due to Conductor Snapped and Insulator failure	-
2		Narmetta	Venkatapur	11kv	Siddipet	07.00	09.00	02.00		B/D Due to Insulator failure	-
3		Mallaram	Sikindulapur	11kv	Siddipet	05.00	08.40	03.40		B/D Due to tree branches fall on the 11 Kv line	-
4		Pedda Gudavally	Dumpalapally	11kv	Siddipet	11.00	13.00	02.00		B/D Due to Insulator failure	-
5		SRD T I	Tallapally	11kv	Sangareddy	14.10	16.55	02.45		B/D Due to conductor snapped at Tilapall	-
6		Cheryal	Kalivemula	11kv	Sangareddy	03.15	07.15	04.00		B/D Due to Jumper Cut heavy wind & gail	-
1	RR N	Jeedimetla-II	Phase-V	11kv	Jeedimetla	20.05	20.45	00.40	BD	11kv line AB Cable Tached the Chanal near Real Cor at phase-V	-
2		Bowrampet	Co-ca-Cola	11kv	Jeedimetla	01.25	02.10	00.45	BD	A Bird fallon the 11kv line at Bowrampet Main Road	-
3		Subash Nagar	Jeedimetla	11kv	Medchal	16.05	16.45	00.40	BD	Tree fallen on the 11KV Line at Deevan Dhaba	-
4		Kompally	Kompally	11kv	Medchal	02.10	02.55	00.45	BD	Tree Branch fallen 11KV Line at Devendhar Colony, Kompally	-
5		Kandlakoya	Godrej	11kv	Medchal	00.00	01.40	01.40	BD	Tree Branch fallen 11KV Line at Bommalagadda, Petrol Bunk Opposite	-
6		Gowdavelly	Ayodhya	11kv	Medchal	06.00	09.18	03.18	BD	11KV Conductor Snapped at Gowdavelly Railway Station	-
7		KPHB	JALAVAYUNAGAR	11kv	Kukatpally	01.10	02.50	01.40	BD	Tree branchesh fallon the 11kv line at Narayana Collage	-
8		Mayurinagar	KTR Colony	11kv	Kukatpally	01.10	04.50	03.40	BD	11kv Line Petroling No Falt & 11kv lode Added to Gakarajurangaraju	-
9		Vikas	Apparna	11kv	Kukatpally	01.10	06.30	05.20	BD	11kv line Disk & Pininsulater failure at Aparna ,Hai Pavani Indistrial	-
1	RR E	ABDULLAPERMET	ABDULLAPERMET	11kv	SAROORNAGAR	18.30	21.30	03.00		11KV INSULATER FAIL AT BALAJAGUDA	-
2		Singapur	Annojiguda	11kv	Habsiguda	23.15	01.30	02.15		11KV Disc failed at Annojiguda	-
3		Cherlapally	Rampally	11kv	Habsiguda	22.35	06.30	07.55		Tree fallen on 11KV Line & Line twisted near Godhavari Company due to heavy rain	-
4		FRUITMARKET	HANUMAN NAGAR	11kv	SAROORNAGAR	09.30	10.38	01.08		11KV LINE AB SWITCH JUPER CUT AT HANUMAN NAGAR	-
5		Cherlapally-I	Phase-I	11kv	Sainikpuri	15.05	15.35	00.30		Tree branches fallen on 11Kv line at Manne Engineering (AE/OP)	-
1	HYD S	Malakpet	Malakpet	11kv	Asmangadh	00.45	02.10	01.25	OL-Bph	DTR fault at Rain Bagh New Apts	-----
2		Khilwath	Khilwath	11kv	Charminar	01.00	02.04	01.04	EL,OL-Rph	DTR fault at Khilwath	-----
1	HYD C	Indistrial Area	Azamabad I.E	11kv	Azamabad	11.15	13.30	02.15	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Adikmett fdr