

TSSPDCL - LMRC / Corporate office

Date: 19.09.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Narayanpet	33KV	Mahabubnagar	09.45	10.20	00.35	E/L	Pin binding failed and conductor snapped near cotton mill cut point	Narayanpet	At Alternate supply arranged from 132KV Marikal at 10:20hrs.
2		Ghanapur	Lattupally	33KV	Nagarkurnool	15.15	15.58	00.43	E/L	No visible fault	Lattupally	No
1	MDK	Narayankhed	Wasar	33KV	Jogipet	10:50	12:05	1:15		Tree branches fallen on the line near Naganpally Village.	Wasar	No
1	RR S	132KV Tandur	Karankote	33KV	Vikarabad	15:05	16:20	1:15	EL	Insulator failed near NTR Colony at Tandur (V)	Karankote	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Udithyal	Macharam	11KV	Jadcherla	15.00	16.00	01.00		11KV Insulator faied near Macharam	No
2		Boothpur	Boothpur	11KV	Jadcherla	12.30	14.30	02.00		11KV wire cut near Goplapur	No
1	NLG	Gaddipally	Kuthubushapuram	11KV	Huzurnagar	12:00	14:30	2:30	O/L	11KV Insulator failed near Kuthubushapuram (V)	No
2		Gondiryala	Gondiryala 01	11KV	Huzurnagar	10.15	11.55	01.40	E/L	11KV Line cut near Gondiryala (V)	No
3		Siripuram	Vallapuram	11KV	Huzurnagar	15.30	16.30	01.00	E/L	11KV Jumper cut near Vallapuram (V)	No
4		Chinnasuraram	Chinnasuraram	11KV	Nalgonda	11.00	12.50	01.50	E/L	11KV Jumper Cut	No
5		Maruru	gorenkalapalem	11KV	Nalgonda	15.00	16.40	01.40	E/L	11KV Jumper Cut	No
6		Pamangundla	A.P.Lingotam	11KV	Nalgonda	08.00	11.30	03.30	E/L	11KV Disc failed	No
7		Marriguda	Kodur	11KV	Devarakonda	8:00	11:00	3:00	E/L	11KV Jumper Cut	No
1	MDK	Kondamrajpally	Gatlamalyala	11KV	Siddipet	11:30	14:30	3:00		11KV Disc failed	No
2		Raghothampally	Raghothampally	11KV	Siddipet	09.48	12.45	02.57		Tree branches fallen on the 11KV line	No
3		Khajipur	Bhoompally	11KV	Siddipet	12.00	14.45	02.45		11KV Disc failed	No
1	RR E	Moula-Ali	Spectra	11KV	Sainikpuri	13:10	13:48	0:38		No visible fault	No
2		Cherlapally	Rampally	11KV	Keesara	15.30	16.35	01.05		No visible fault	No
1	HYD N	I.D.P.L	Shivalayam	11KV	Bowenpally	10.00	11.00	01.00	EL,OL-Bph	Jumper cut at Vimal Theater back side	No
2		Prashanth Nagar	Prashanth Nagar	11KV	Bowenpally	10:55	12:00	1:05	OL-Rph	Tree branches fallen on lines at Prashanth Nagar Cheruvu	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2	2	2	2	2	2			
2	NLG	150	948		7		7		7			
3	MDK	87	828	1	3	1	3	1	3			
4	RR(S)	31	338	1		1		1				
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	4	12	4	12	4	12	0	0	
	Grand Total	908	6149	4	16	4	16	4	16	0	0	