

TSSPDCL - LMRC / Corporate office

Date: 22.09.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Manoharabad	Shivampet	33KV	Toopran	15.30	19.30	04.00		B/D due to Insulator fail near Kanukunta Venugopaldaswamy temple	Manoharabad	-

TSSPDCL - LMRC / Corporate office

Date: 22.09.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Mastipur	Mastipur	11KV	Mahabubnagar	10.00	12.00	02.00		11KV Phase to Phase at Mastipur (V)	-
2		Hamsanipally	Chilmulmailwar	11KV	Mahabubnagar	09.00	11.45	02.45		Tree fallen on conductor Near Bolabai Thanda(V)	-
1	NLG	G.T. Giri	Bakthalapuram	11KV	Suryapet	13.40	16.30	02.50	EL	Insulator failed	-
2		Palakeedu	Palakeedu	11KV	Huzurnagar	12.00	13.20	02.25	EL	Jumper cut	-
3		Thogarrai	Ganapavaram	11KV	Huzurnagar	11.00	12.10	01.10	EL	AB Swtich fault	-
4		Addagudur	Ramaram	11KV	Bhongir	13.05	15.30	02.25	EL	Jumper cut	-
5		Bondudgula	Godumakunta	11KV	Bhongir	06.16	08.00	01.44	EL	Jumper cut	-
1	RR S	NIRD	Appa	11KV	Rajendranagar	12.27	13.45	01.18		11 KV Cable fail at NIRD	-
2		Rajendranagar	Univercity	11KV	Rajendranagar	17.00	18.16	01.16		CTPT Fail fail at Near univercity	-
3		Gaganphad	Jai Bavani	11KV	Rajendranagar	14.30	15.50	01.20		11 KV Line twisted at Venkateshwara Inds	-
1	RR E	Yapral	Yapral	11KV	Sainikpuri	05.50	06.50	01.00		Bird fallen on 11Kv line at Mani Enclave (Foc Shiva Raju/Bala Krishna)	-
2		Cherlapally	Rampally	11KV	Keesara	16.55	18.05	01.10		Line patrolling but no visible fault	-
1	HYD C	Golconda	Mothi Mahal	11KV	Mehdipatanam	22.48	00.10	01.22	OL-Yph	Cable fault at Nadeem Colony (1No. DTR kept Off)	-
2		Asif Nagar	Alapati Nagar	11KV	Mehdipatanam	23.15	00.20	01.05	EL,OL-Rph	DTR Cable fault at Pillar No.55	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		3		3		3			
5	RR(N)	82	407									
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014		2		2		2			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		2		2		2			
2	NLG	150	948		5		5		5			
3	MDK	87	828	1		1		1				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>1</b>	<b>14</b>	<b>1</b>	<b>14</b>	<b>1</b>	<b>14</b>	<b>0</b>	<b>0</b>	