

TSSPDCL - LMRC / Corporate office

Date: 23.09.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV Chintal	33KV Chintal	33KV	Medchal	2:40	3:00	0:20		UG Cable failed at Chintal Bus Stop	Chintal	No

TSSPDCL - LMRC / Corporate office

Date: 23.09.17

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Gundepuri	Pasthala	11KV	Suryapet	06.30	07.30	01.00	E/L	Tree branches fallen on the line	No
2		Palakeedu	Nagireddy gudem	11KV	Huzurnagar	05.00	08.40	03.40	E/L	11KV Line cut near Nagireddigudem(V)	No
3		Mukundapuram	Somaram	11KV	Huzurnagar	07.42	10.32	02.50	E/L	11KV Jumper cut near Somaram village	No
4		Pamanagundla	Yerrasanigudem	11KV	Nalgonda	08.28	12.00	03.32	E/L	11KV Insulator failed	No
5		Eduloor	Parada	11KV	Nalgonda	07.00	09.00	02.00	E/L	11KV Insulator failed	No
1	MDK	Rudram	Mallupally	11KV	Siddipet	07.15	13:12	05.57		11 KV Jumper cut	No
2		Jakkapur	Gopulapur	11KV	Siddipet	08.00	08.30	00.30		AB Switch Problem	No
1	RR E	Fruit Market	Shivalayam	11KV	Sarooragar	4:55	6:20	1:25	OL/EL	11KV Line cut at Durganagar	No

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407	1		1		1				
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014									
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		5		5		5			
3	MDK	87	828		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>1</b>	<b>8</b>	<b>1</b>	<b>8</b>	<b>1</b>	<b>8</b>	<b>0</b>	<b>0</b>	