

TSSPDCL - LMRC / Corporate office

Date: 23.09.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Gaddipally	Ponugodu	11KV	Huzurnagar	06.50	12.15	05.25	OL	Due to 11kv Disk failure near Ponugodu village	-
2		Palem	Palem	11KV	Nalgonda	13.15	15.00	01.45	E/L	11KV insulator failed	-
3		Edulur	Parada	11KV	Nalgonda	09.00	11.00	02.00	E/L	Tree fallen on line	-
4		Maryala	Chouderpally	11KV	Bhongir	10.00	13.00	03.00	EL	Bird Fallen On Line	-
1	RR S	APPA	Aziznagar(APPA)	11KV	IBGH	01.15	03.15	02.00	BD	11KV Pole bend at REV Company	-
1	RR N	Shameerpet	Shameerpet	11KV	Medchal	16.05	16.45	00.40	BD	Bird fallen on the 11KV Line at Bommarajpet Village	-
1	RR E	Moula-Ali	Mirzalguda	11KV	Sainikpuri	09.00	09.30	00.30		Tree fallen on 11Kv line at Upperguda (L.Insp Ravi)	-
1	HYD C	Bathkammakunta	D.D Colony	11KV	Azamabad	00.42	02.33	01.51	EL,OL	Disc Insulator flash over at Bindu Prestage Apts	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Amarchintha	Amarchintha	33KV	Mahabubnagar	04.59	08.22	03.23	O/L	Pin insulator replaced near Mastipur (vi)	Amarchintha	-
2		Ghanpur	Lattupally	33KV	Wanaparthy	18.30	20.02	01.32	E/L	Alternate Supply Arranged 33KV Bijinapally SS at 20:50Hrs	Lattupally	-
3		Ieeza	Madalabanda	33KV	Gadwal	09.33	11.50	02.17	E/L	Bird follen on the crassarm near KR Cheruvu Road	Madalabanda	-
4		Polepally	Gangapur	33KV	Jadcherla	02.13	11.18	09.05	E/L	33KV line Isolator Disc Failed and replaced ar 33KV SS Avancha	Gangapur	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	4		4		4				
2	NLG	150	948		4		4		4			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	4	4	4	4	4	4	0	0	
	Grand Total	908	6149	4	8	4	8	4	8	0	0	