

## TSSPDCL - LMRC / Corporate office

Date: 25.09.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Rajapur	Mallepally	11kv	Jadcherla	14.00	18.20	04.20		11KV Wire Cut near Edganipally	-
1	NLG	Penpahad	Dubbathanda	11kv	Suryapet	07.45	10.00	02.15	E/L	11Kv Jumper cut	-
2		Arlagaddagudem	Chinnasuraram	11kv	Nalgonda	13.00	14.00	01.00	E/L	11Kv Jumper cut	
3		Veliminedu	Pittampally	11kv	Nalgonda	15.00	16.20	01.20	E/L	11Kv Jumper cut	
4		Y.Singaram	Magdum nagar	11kv	Huzurnagar	09.00	12.00	03.00	E/L	11Kv Jumper cut near Magdum nagar village	
5		Raghunadapalem	Gundlapally	11kv	Huzurnagar	05.00	09.00	04.00	E/L	11kv line cut near Gundlapally village	
6		Ananthagiri	V.R.Puram	11kv	Huzurnagar	14.25	16.15	01.50	EL/OL	11Kv line snapped near V.R.Puram village	
7		Ponugodu	Ponugodu	11kv	Huzurnagar	14.00	18.00	04.00	E/L	11Kv Jumper cut near Ponugodu village	
8		Kalmalcheruvu	Kalmalcheruvu	11kv	Huzurnagar	16.30	18.20	01.50	E/L	11Kv Jumper cut near Kalmalcheruvu village	
9		Kalmalcheruvu	Ganugabanda	11kv	Huzurnagar	14.00	18.00	04.00	O/L	11Kv line snapped near Ganugabanda village	
10		Kandibanda	Gandi nagar thanda	11kv	Huzurnagar	14.30	16.00	01.30	E/L	11Kv line snapped near Gandi nagar thanda village	
11		Mellacheruvu	Y madaram	11kv	Huzurnagar	14.20	17.45	03.25	E/L	11Kv Jumper cut near Y madaram village	-
12		Mellacheruvu	Revooru	11kv	Huzurnagar	14.10	18.00	03.50	O/L	11Kv Jumper cut near Revooru village	-
13		Raghunadapalem	Raghunadapalem	11kv	Huzurnagar	17.00	18.30	01.30	E/L	11Kv Jumper cut near Raghunadapalem village	-
14		Maryala	Mailaram	11kv	Bhongir	11.00	14.00	03.00	E/L	AB switch post type insulator failed near Medipally (V)	-
1	MDK	Ismailkhanpet	Arutla	11kv	Sangareddy	15.20	18.00	02.40		B/D due to Insulator failed	-
2		Muthangi	Muthangi	11kv	Sangareddy	12.55	14.55	02.00		B/D due to Tree branch fallen on line	-
1	RR S	Gaganpahad	NPA	11kv	RJNR	09.40	11.40	02.00	B/D	11kv Insulator Failed at Old Kurnool Road,	-
2		NPA	Babulreddy Nagar	11kv	RJNR	13.40	18.09	04.29	B/D	33kv Pole Damaged Fallen on 11kv line babulreddy nagar line at Railway gate	-
3		NPA	Hasan nagar	11kv	RJNR	13.30	15.40	02.10	B/D	T/F HG Fuse Insulator Failed at Baba nagar	-
4		NIRD	NIRD	11kv	RJNR	13.34	16.23	02.49	B/D	11kv Insulator Failed at RTP	-
5		NIRD	Aravalli	11kv	RJNR	14.03	16.54	02.51	B/D	lizard Fallen on 11kv Line at NIRD Office	-
6		Manikonda	Friends colony	11kv	IBG	13.50	15.20	01.30	B/D	Tree branches Fallen on 11kv Line at Friends colony Park	-

## TSSPDCL - LMRC / Corporate office

Date: 25.09.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Shameerpet	Leo Maridian	11kv	Medchal	01.10	05.30	04.20	BD	11KV Conductor Snapped at Grampanchayathi	-
2		Jeedimetla-I	APIIC Colony	11kv	Jeedimetla	10.05	11.30	01.25	EL	11kv line Jumper Cut at Banana Godam New Shapur Nagar	-
3		Jeedimetla-IV	Axies	11kv	Jeedimetla	14.00	15.10	01.10	EL	11kv lin AB Cable Endkit Failure at OPP:Axies Company	-
1	RR E	Aushapur	Madharam AGL	11kv	Keesara	09.30	13.00	03.30		Bird fallen on 11kv line at Janareddy bavi madharam (V)	-
2		P&T colony	Budda nagar	11kv	Keesara	14.45	17.55	03.10		11kv Disk fail at life spring hospital budda nagar	-
3		P&T colony	Medipally	11kv	Keesara	14.45	15.55	01.10		11kv Disk fail at karnthi nagar	-
4		Cherlapally	Rampally	11kv	Keesara	12.15	15.30	03.15		Pin insulator fail at Rampally charevu due to rain	-
5		PEDDA AMBERPET	INDUSTRIAL	11kv	SAROORNAGAR	14.50	16.05	01.15	EL	TREE BRACHANS FALL ON 11KV LINE AT KUNTLOOR	-
6		Moula-Ali	Venkateshwar Nagar	11kv	Sainikpuri	12.32	13.11	00.39		11Kv line Twisting at APIIC Colony (AE/OP)	-
7		BANJARA COLONY	BEERAPPATEMPLE	11kv	SAROORNAGAR	13.02	15.06	02.04	EL	11KV PIN INSULATER FAIL AT SAI COLONY	-
1	HYD S	Khilwath	Khazipura	11kv	Charminar	11.02	12.30	01.28	EL,OL-Bph	I/C Cable fault	-
2		Moosarambagh	Sripuram Colony	11kv	Asmangadh	13.15	14.20	01.05	EL	DTR fault at Vaishnavi Apts	-
3		Kandikal Gate	Saibaba Nagar	11kv	Charminar	13.20	15.30	02.10	EL	Tree branches fallen on lines at Saibaba Nagar	-
4		Malakpet	M.M.H	11kv	Asmangadh	13.25	15.05	01.40	EL	Tree branches & Kite Stick fallen on lines at Azampura	-
5	HYD C	Ibrahimbagh	New Military	11kv	Mehdipatnam	13.50	15.25	01.35	OL	Conductor snapped at Assurakhan	-
6		Ibrahimbagh	New Military	11kv	Mehdipatnam	16.49	17.50	01.01	EL,OL	Jumper cut at Military Area	-
7	HYD N	Bhudevi Nagar	Rama Raju Nagar	11kv	Erragadda	14.33	16.05	01.32	EL	Jumper cut at Rama Raju Nagar	-

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Disincherla	Mukundapuram	33kv	Huzurnagar	08.10	09.40	01.30	E/L	33Kv Jumper cut gaddipally SS	Mukundapuram	-
2		Disincherla	Mukundapuram	33kv	Huzurnagar	13.25	16.30	03.05	E/L	33Kv Jumper cut	Mukundapuram	-
3		Disincherla	Palkeedu	33kv	Huzurnagar	14.15	16.30	02.15	E/L	33Kv Insulator failure	Palkeedu	-
1	MDK	Jogipet	Dakur	33kv	Jogipet	15.35	21.50	06.15		B/D due to Pin Insulator failed & loads tag on Laxmisagar Feeder	Dakur	-
2		Jogipet	Gadipeddapur	33kv	Jogipet	17.30	00.00	06.30		Still	Gadipeddapur	-
3		Kandhi	HFC-I	33kv	Sangareddy	13.15	15.40	02.25		B/D due to Tree branch fallen on line	HFC-I	-
4		Siddipet	Narayanraopet	33kv	Siddipet	11.25	12.20	00.55		B/D due to Line problem	Narayanraopet	-
5		Habsipur	Peddachikode	33kv	Siddipet	08.10	13.30	05.20		B/D due to Jumper cut & AB switch failed	Peddachikode	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		6		6		6			
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360		7		7		7			
7	Hyd	186	1014		7		7		7			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>23</b>	<b>0</b>	<b>23</b>	<b>0</b>	<b>23</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948	3	14	3	14	3	14			
3	MDK	87	828	5	2	5	2	4	2	1		1 No.33kv still
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>8</b>	<b>17</b>	<b>8</b>	<b>17</b>	<b>7</b>	<b>17</b>	<b>1</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>8</b>	<b>40</b>	<b>8</b>	<b>40</b>	<b>7</b>	<b>40</b>	<b>1</b>	<b>0</b>	