

TSSPDCL - LMRC / Corporate office

Date: 26.09.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Polepally	Gangapur	33KV	Jadcherla	11.10	14.27	03.17	E/L&O/L	Due to breaker problem	Gangapur	Alternate supply arranged from 132KV SS Midjil at 13:00Hrs
1	NLG	Nalgonda	Rayanguda	33KV	Nalgonda	17:40	21:30	3:50		Flexi fallen on the 33 KV Line	Rayanguda	No
1		Ramayampet	Konapur	33KV	Medak	4:45	9:20	4:35		B/D due to earth fault	Konapur	No
2	MDK	Habshipur	Raghothampally	33KV	Siddipet	14.40	15.40	01.00		Insulator failed	Raghothampally	No
3		Palamakula	Rampur	33KV	Siddipet	23.41	06.32	06.51		Insulator failed	Rampur	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Arlagaddagudem	Thatikal	11KV	Nalgonda	13:00	15:00	2:00	E/L	11KV Jumper cut	No
2		Penpahad	Dubbathanda	11KV	Suryapet	07.45	10.00	02.15	EL	11KV Jumper cut	No
3		Voligonda	Lothukunta	11KV	Bhongir	07.40	11.40	04.00	EL	11KV Jumper cut	No
4		Yellanki	BSNL	11KV	Bhongir	10.40	13.40	03.00	EL	11KV Disc failed near Peddkaparthu	No
5		Mukundapuram	Dacharam	11KV	Huzurnagar	08.30	10.50	02.20	EL	11KV Jumper cut	No
6		Mukundapuram	Somaram	11KV	Huzurnagar	14.00	16.00	02.00	E/OL	11KV Jumper cut	No
7		Bheelyanaik thanda	Pathathanda	11KV	Huzurnagar	08.00	12.00	04.00	OL	Bird to fallen on the 11Kv line	No
8		Bheelyanaik thanda	Bheelyanaik thanda	11KV	Huzurnagar	08.00	12.00	04.00	EL	11KV Disc failed	No
9		Gaddipally	Gaddipally	11KV	Huzurnagar	6:30	9:15	2:45	EL	11KV Disc failed	No
1	MDK	Sardhana	Sardhana	11KV	Medak	7:05	11:30	4:25		11KV Disc failed	No
2		Shalipet	Khajapur	11KV	Medak	14.30	18.00	03.30		11KV Jumper cut	No
3		Seelampally	Seelampally	11KV	Medak	14.30	17.15	02.45		11KV Jumper cut	No
4		Gandharipally	Jaipuram	11KV	Medak	15.00	17.00	02.00		11KV Jumper cut	No
5		Kondamrajally	Ganapur	11KV	Siddipet	07.30	08.30	01.00		11KV Disc failed	No
6		Narmetta	Thimmaipally	11KV	Siddipet	08.40	14.00	05.20		11KV Disc failed	No
7		Irkode	Irkode	11KV	Siddipet	07.30	08.30	01.00		11KV Jumper cut	No
8		Ponnal	Bakerichepyal	11KV	Siddipet	05.50	12.30	06.40		11KV Disc failed	No
9		Thadakapally	Venkatapur	11KV	Siddipet	05.00	08.00	03.00		B/D due Lorry dashed to Tranfarmar	No
10		Thadakapally	Thadakapally	11KV	Siddipet	1:00	3:00	2:00		B/D due RB phase to phase	No
1	RR N	Devarayamjal	DMC	11KV	Medchal	1:20	2:50	1:30		Tree fallen on the 11KV Line at DMC	No
2		Kandlakoya	Kandlakoya	11KV	Medchal	02.05	05.10	03.05		11KV Pin insulator failed at Kandlakoya School	No
1	RR E	Narapally	Narapally	11KV	Keesara	6:40	7:25	0:45		Tree branches fallen on the 11KV line at Vijayapuri Colony	No
1	HYD C	Amberpet	C.P.L	11KV	Azamabad	14.30	15.45	01.15	OL-R&Yph	Tree fallen on the line at Church DTR	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1		1				
2	NLG	150	948	1	9	1	9	1	9			
3	MDK	87	828	3	10	3	10	3	10			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	5	19	5	19	5	19	0	0	
	Grand Total	908	6149	5	23	5	23	5	23	0	0	