

TSSPDCL - LMRC / Corporate office

Date: 27.09.17

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---|
| 1 | MBNR | Wanaparthy | Peddmandadi | 33KV | Wanaparthy | 13.08 | 17.33 | 04.25 | E/L | Insulator failed at Achyutapuram(V) | Peddmandadi | No |
| 2 | | Wanaparthy | Rajapur | 33KV | Wanaparthy | 19.05 | 20.15 | 01.10 | O/L | Insulator damaged at Appaipally (V) | Rajapur | Alternate Supply Arranged from 33KV Kodair feeder |
| 3 | | leeza | Mittadoddi | 33KV | Gadwal | 14.05 | 14.40 | 00.35 | E/L | Insulator Burst | Mittadoddi | No |
| 4 | | Kalwakurthy | Vangoor | 33KV | Jadcherla | 16:50 | 21:05 | 4:15 | E/L | 1 No Pin Insulator failed and repalced and conductor snapped near Servareddy pally(V) | Vangoor | No |
| 5 | | Midjil | Vemula | 33KV | Jadcherla | 21:47 | 0:00 | 2:13 | E/L | Tree branches fallen on the line due to heavy rain | Vemula | No |
| 6 | | Achampet | Inole | 33KV | Nagarkurnool | 19.25 | 21.55 | 02.30 | E/L | 1 No Pin insulator failed and repalced at Laxmidevi Gandhi | Inole | No |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | MBNR | Atmakur | Mullamalla | 11KV | Mahabubnagar | 12.10 | 15.10 | 03.00 | | 11KV Tree fallen on conductor near Khanapur(Vi) | No |
| 2 | | Peddakadmoor | Peddakadmoor | 11KV | Mahabubnagar | 14.00 | 14.45 | 00.45 | | 11KV Phase to Phase at Kothapally (Vi) | No |
| 3 | | Damaragidda | Maddelabeedu | 11KV | Mahabubnagar | 10.00 | 11.00 | 01.00 | | 11KV Insulator Damage Near Maddelabeedu (vi) | No |
| 4 | | Gudeballore | Kothapally | 11KV | Mahabubnagar | 6:10 | 9:30 | 3:20 | | 11KV Conductor cut at Lingampally (Vi) | No |
| 5 | | Karkonda | Kuchur | 11KV | Mahabubnagar | 8:55 | 10:44 | 1:49 | | 11KV Disk failure near Kuchur (vi) | No |
| 6 | | Hunwada | Nainonipally | 11KV | Mahabubnagar | 11:00 | 13:00 | 2:00 | | 11KV Conductor cut at Bhuddarama (Vi) | No |
| 7 | | Amistapur | Town | 11KV | Jadcherla | 3:00 | 7:15 | 4:15 | | 11Disc failed At Amistapur(Vi). | No |
| 8 | | Kalwakurthy | Kotra | 11KV | Jadcherla | 10:15 | 13:52 | 3:37 | | 11 Insulator failed near Kvk Road. | No |
| 9 | | Kalwakurthy | Kurmidda | 11KV | Jadcherla | 10:15 | 14:40 | 4:25 | | 11Kv Disc failed near Panjugul(Vi). | No |
| 10 | | Veldanda | Veldanda(R) | 11KV | Jadcherla | 10:00 | 13:00 | 3:00 | | 11 KV Conductor cut near Pothinenibavi Side. | No |
| 11 | | Veldanda | Kuppagandla | 11KV | Jadcherla | 8:45 | 12:35 | 3:50 | | Pole Errection Work At Kuppagandla (Vi). | No |
| 12 | | Udithyal | Macharam | 11KV | Jadcherla | 12.04 | 14.42 | 02.38 | | HT/LT Near Macharam(VI). | No |
| 1 | NLG | Penpahad | S R Palem | 11KV | Suryapet | 5:55 | 8:00 | 2:05 | EL | Jumper cut | No |
| 2 | | Gondiryala | Gondiryala 01 | 11KV | Huzurnagar | 01.50 | 04.00 | 02.10 | E/OL | 11Kv Jumper cut near Gondiryala 01 village | No |
| 3 | | Dondapadu | Kakatiya | 11KV | Huzurnagar | 11.00 | 12.00 | 01.00 | EL | 11KV line cut Kakatiya village | No |
| 4 | | Arlagaddagudem | Tatikal | 11KV | Nalgonda | 07.00 | 10.00 | 03.00 | EL | HT/LT Line Meltings | No |
| 5 | | Narketpally | Mandra | 11KV | Nalgonda | 12.00 | 15.30 | 03.30 | EL | 11 KV Jumper Cut | No |
| 6 | | Narsigbatla | Narsigbatla | 11KV | Nalgonda | 11.30 | 13.10 | 01.40 | EL | 11 KV Jumper Cut | No |
| 7 | | B.P.Pally | Deshmukh | 11KV | Bhongir | 09.10 | 10.45 | 01.35 | EL | 11KV Jumper snapped | No |
| 8 | | B.P.Pally | B.P.Pally Town | 11KV | Bhongir | 10.20 | 12.00 | 01.40 | EL | 11Kv Insulator failed | No |
| 9 | | Ramannapet | Janampally | 11KV | Bhongir | 9:00 | 12:35 | 3:35 | EL | 11KV Disc failed | No |
| 1 | RR S | Appa | Darga | 11KV | Rajendranagar | 14:40 | 16:00 | 1:20 | | Tree branches fallen the 11KV line at Water Tank | No |
| 1 | RR N | Madinaguda | Bk Enclave | 11KV | Kukatpally | 14:48 | 16:08 | 1:20 | EL | 11KV AB Cable failed at Krishana Nagar | No |
| 2 | | Shameerpet | Devarayamjal | 11KV | Medchal | 09.00 | 11.05 | 02.05 | BD | Bird fallen on the 11KV line at Outer Ring Road | No |
| 1 | RR E | Moula-Ali | Malkajiri | 11KV | Sainikpuri | 12:50 | 14:05 | 1:15 | | 11KV Disc failed at RTC Colony | No |
| 2 | | Mallapur | IDA | 11KV | Habsiguda | 09.45 | 11.05 | 01.20 | | 11KV Disc failed near Vandana Industries at IDA Mallapur | No |
| 1 | HYD N | Bowenpally | Pension Line | 11KV | Bowenpally | 10.10 | 11.20 | 01.10 | EL | No Visible Fault | No |
| 2 | | Zamistanpur | M.C.H Park | 11KV | Sec'bad | 14:04 | 16:29 | 2:25 | EL,OL-Rph | Tree branches fallen on lines at park | No |
| 3 | | James Street | Chikoti Complex | 11KV | Sec'bad | 14:05 | 16:22 | 2:17 | EL | Tree branches fallen on lines at Jogulamba Temple | No |
| 4 | | Bansilalpet | C.C.Nagar | 11KV | Sec'bad | 14:35 | 16:25 | 1:50 | EL,OL | Tree branches fallen on lines | No |
| 5 | | Patigadda | Rasoolpura | 11KV | Sec'bad | 14:20 | 16:00 | 1:40 | EL,OL | No Visible Fault | No |
| 6 | | Patigadda | Jeera | 11KV | Sec'bad | 14:25 | 16:25 | 2:00 | EL,OL | Tree branches fallen on lines | No |
| 7 | | Clock Tower | St.Meries | 11KV | Sec'bad | 14:05 | 17:20 | 3:15 | EL | Tree branches fallen on lines at Sangeeth Line | No |
| 8 | | Film Nagar | M.L.A Colony | 11KV | Banjara Hills | 14:40 | 15:55 | 1:15 | OL-Rph | Tree branches fallen on lines at Road No.5 | No |
| 9 | | Clock Tower | Natraj | 11KV | Sec'bad | 14:10 | 15:15 | 1:05 | EL,OL-Rph | No Visible Fault | No |
| 10 | | Clock Tower | Sangeeth | 11KV | Sec'bad | 14.05 | 15.55 | 01.50 | EL,OL-Rph | Tree branches fallen on lines at Deccan Chambers | No |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---|
| 1 | HYD S | Petlaburz | Petlaburz | 11KV | Charminar | 03.50 | 06.05 | 02.15 | EL | Cable fault | Partial fdr charged & Remaining loads added on 11KV Puranapool feeder |
| 2 | | Salarjung | Sadath Nagar | 11KV | Asmangadh | 4:10 | 5:25 | 1:15 | EL | Breaker problem at SS | Arranged partial B/F on 11KV Bada Bazar fdr |
| 3 | | Miralam | Teegala Kunta | 11KV | Charminar | 14:30 | 16:20 | 1:50 | EL,OL | Tree branches fallen on lines at Gudika Dawakana | No |
| 4 | | Ch' Baradari | Doodh Bowli | 11KV | Charminar | 14:20 | 15:55 | 1:35 | EL | Tree branches fallen on lines at Kamatipura | No |
| 5 | | Jiyaguda | Samartha Narayana | 11KV | Begumbazar | 14:30 | 15:55 | 1:25 | EL | Tree branches fallen on lines | No |
| 6 | | Petlaburz | Murali Nagar | 11KV | Charminar | 14:45 | 16:10 | 1:25 | EL,OL | No Visible Fault | No |
| 7 | | Attapur | Puranapool | 11KV | Charminar | 14:30 | 16:50 | 2:20 | EL,OL-Rph | Tree branches fallen on lines at B.Pura Colony | No |
| 8 | | Seetharam Bagh | Dhoolpet OH | 11KV | Begumbazar | 14:45 | 16:10 | 1:25 | EL,OL | Tree branches fallen on lines at R.K.Pet | No |
| 9 | | Sultan Bazar | Sultan Bazar | 11KV | Begumbazar | 23.05 | 01.02 | 01.57 | EL,OL | No Visible Fault | No |
| 1 | HYD C | Zamistanpur | L.N.Nagar | 11KV | Azamabad | 14.06 | 15.29 | 01.23 | EL,OL-Y&Bph | Tree branches fallen on lines at L.N.Nagar | No |
| 2 | | Nampally | FAPCCI | 11KV | Mehdipatnam | 14.18 | 16.00 | 01.42 | OL-Rph | Tree branches fallen on lines at S.K.Medical & U.S.Printers | No |
| 3 | | Jawahar Nagar | Anjaiah Bhavan | 11KV | Saifabad | 14.00 | 16.35 | 02.35 | OL-Bph | No Visible Fault | No |
| 4 | | Indira Park | Talla Basti | 11KV | Saifabad | 14:25 | 16:30 | 2:05 | OL-Bph | No Visible Fault | No |
| 5 | | Indira Park | Gagan Mahal | 11KV | Saifabad | 14:30 | 17:00 | 2:30 | EL,OL | HT Jumper cut at Lake View Hotel | No |
| 6 | | Narayanguda | Preventive Medicine | 11KV | Azamabad | 14:20 | 16:20 | 2:00 | EL,OL | End Kit failed at Narayanguda Fly over | No |
| 7 | | Nizam College | Babukhan Estate | 11KV | Saifabad | 14:12 | 15:56 | 1:44 | All Indication | DTR Fault at Deccan Tower | No |
| 8 | | Nizam College | Little Flower | 11KV | Saifabad | 15:05 | 16:16 | 1:11 | OL-Rph | No Visible Fault | No |
| 9 | | Hussain Sagar | Adarsh Nagar | 11KV | Saifabad | 14:10 | 15:25 | 1:15 | EL,OL | Lightening Arrestor failed | No |
| 10 | | Hussain Sagar | Nasar School | 11KV | Saifabad | 14:14 | 15:30 | 1:16 | EL,OL | Tree branches fallen on lines at Nasar School | No |
| 11 | | Hussain Sagar | Gunfoundry | 11KV | Saifabad | 14.20 | 15.55 | 01.35 | EL,OL | No Visible Fault | No |

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 48 | 158 | | | | | | | | | |
| 2 | NLG | 18 | 406 | | | | | | | | | |
| 3 | MDK | 92 | 383 | | | | | | | | | |
| 4 | RR(S) | 40 | 201 | | 1 | | 1 | | 1 | | | |
| 5 | RR(N) | 82 | 407 | | 2 | | 2 | | 2 | | | |
| 6 | RR(E) | 38 | 360 | | 2 | | 2 | | 2 | | | |
| 7 | Hyd | 186 | 1014 | | 30 | | 30 | | 30 | | | |
| | Total | 504 | 2929 | 0 | 35 | 0 | 35 | 0 | 35 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 110 | 969 | 6 | 12 | 6 | 12 | 6 | 12 | | | |
| 2 | NLG | 150 | 948 | | 9 | | 9 | | 9 | | | |
| 3 | MDK | 87 | 828 | | | | | | | | | |
| 4 | RR(S) | 31 | 338 | | | | | | | | | |
| 5 | RR(N) | 8 | 48 | | | | | | | | | |
| 6 | RR(E) | 18 | 89 | | | | | | | | | |
| | Total | 404 | 3220 | 6 | 21 | 6 | 21 | 6 | 21 | 0 | 0 | |
| | Grand Total | 908 | 6149 | 6 | 56 | 6 | 56 | 6 | 56 | 0 | 0 | |